

---

## Central Coast Regional Water Quality Control Board

September 9, 2016

Mr. Craig Stoller  
Stoller C&N Family Trust Winery  
[Craig@sextantwines.com](mailto:Craig@sextantwines.com)

**Sent via Electronic Mail**

Dear Mr. Stoller:

### **NOTICE OF APPLICABILITY FOR GENERAL WASTE DISCHARGE REQUIREMENTS ORDER NO. R3-2008-0018 FOR WINERY WASTEWATER, STOLLER C&N FAMILY TRUST WINERY, PASO ROBLES, SAN LUIS OBISPO COUNTY**

Central Coast Regional Water Quality Control Board (Water Board) staff has reviewed your Notice of Intent to Comply with the terms of the General Waste Discharge Requirements of winery waste (General WDRs) and the first annual fee for Stoller C&N Family Trust Winery. From your submittals we understand the following:

- The facility is located at 2624 HWY 46 West, in Paso Robles CA (APN # 040-111-024).
- The facility has been enrolled in the waiver portion of General Order No. R3-2008-0018 since September 23, 2011, and has produced no more than 10,000 cases of wine per year during that time.
- The facility is increasing its production up to 60,000 cases/year, with an expected peak daily flow of 7,500 gallons per day during crush.
- The owners have upgraded the wastewater treatment and disposal systems to include:
  - An industrial Bioreactor capable of treating two 3,750 batches each day, for a total of 7,500 gallons treated per day;
  - The new facility includes flow equalization, screening, and pH adjustment;
  - Final effluent will be pumped to a 5,000-gallon HDPE effluent equalization tank;
  - Reactor solids will be managed by an automatic sludge pump which will transfer solids to a sludge storage tank;
- Treated effluent will be utilized for irrigation of the facility's 7 acres of vineyard, at a loading rate not to exceed 300 mg/L of BOD<sub>5</sub> per acre per day.

Based upon the information provided, Stoller C&N Family Trust Winery is hereby enrolled in General WDR No. R3-2008-0018 and is now required to comply with the associated monitoring and reporting program. A copy of the General WDR, the monitoring and reporting requirements, and a monitoring report template can be viewed and downloaded at the following Central Coast Water Board website:

[http://www.waterboards.ca.gov/centralcoast/board\\_decisions/enrollees/](http://www.waterboards.ca.gov/centralcoast/board_decisions/enrollees/)

If you have questions regarding this letter, please contact Water Board staff Jon Rokke at (805) 549-3892, ([jon.rokke@waterboards.ca.gov](mailto:jon.rokke@waterboards.ca.gov)) or Chris Adair at (805) 549-3761, ([chris.adair@waterboards.ca.gov](mailto:chris.adair@waterboards.ca.gov)).

Sincerely,

for  
John M. Robertson  
Executive Officer

Cc: Lacey Zubak – Kirk Consulting  
[Lacy@kirk-consulting.net](mailto:Lacy@kirk-consulting.net)

Shannon Jessica PE – Wallace Consulting  
[ShannonJ@Wallacegroup.us](mailto:ShannonJ@Wallacegroup.us)

Chris Adair – Central Coast Water Board  
[chris.adair@waterboards.ca.gov](mailto:chris.adair@waterboards.ca.gov)

Lacey Zubac – Associate Planner  
Kirk Consulting  
[Lacey@kirk-consulting.net](mailto:Lacey@kirk-consulting.net)

[ECM# 771383](#)

[R:\RB3\Shared\WDR\WDR Facilities\San Luis Obispo Co\Stoller Family Trust Winery\Stoller NOA Increased Production.doc](#)