

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
CENTRAL COAST REGION
81 Higuera Street, Suite 200
San Luis Obispo, California 93401**

**MONITORING AND REPORTING PROGRAM ORDER NO. R3-2002-0019
Waste Discharger Identification No. 401014001
For
LOS ROBLES MOBILE HOME ESTATES
SAN LUIS OBISPO COUNTY**

Reporting responsibilities are specified in Sections 13225(a), 13267(b), 13383, and 13387(b) of the California Water Code. This Monitoring and Reporting Program is issued in accordance with Provision D.2. of Regional Board Order No. RB3-2002-0019.

Water Supply Monitoring

Representative samples of the community water supply shall be collected and analyzed for the constituents and at the frequency specified below:

Parameter/Constituent	Units	Sample Type	Sampling Frequency
Total Dissolved Solids	mg/l	Grab	Semi-Annually (January and July)
Sodium	mg/l	Grab	Semi-Annually (January and July)
Chloride	mg/l	Grab	Semi-Annually (January and July)
Total Hardness	mg/l	Grab	Semi-Annually (January and July)
Sulfate	mg/l	Grab	Semi-Annually (January and July)
Nitrate	mg/l	Grab	Semi-Annually (January and July)
pH	--	Grab	Semi-Annually (January and July)

Effluent Monitoring

Septic tank effluent samples shall be collected and analyzed for the following:

Parameter/Constituent	Units	Sample Type	Sampling Frequency
Flow	GPD	Measured*	Monthly
Settleable Solids	ml/l	Grab	Quarterly
Total Dissolved Solids	mg/l	Grab	Semi-Annually (January and July)
Sodium	mg/l	Grab	Semi-Annually (January and July)
Chloride	mg/l	Grab	Semi-Annually (January and July)
Total Hardness	mg/l	Grab	Semi-Annually (January and July)
Sulfate	mg/l	Grab	Semi-Annually (January and July)
pH	--	Grab	Semi-Annually (January and July)

* The flow meter shall be approved by the Regional Board Executive Officer.

Septic Tank Monitoring

Parameter	Units	Type of Measurement	Minimum Inspection Frequency
Sludge depth and scum thickness in each compartment of each tank	Feet	Staff Gauge	Monthly
Distance between bottom of scum layer and bottom of outlet device	Inches	Staff Gauge	Monthly
Distance between top of sludge layer and bottom of outlet device	Inches	Staff Gauge	Monthly

Disposal Area Monitoring

The disposal areas shall be inspected monthly for surfacing effluent, saturated surface areas, and odors. Evidence of any condition of this nature shall be promptly investigated and remedied. A record shall be kept of dates and nature of observations and remedies and of alternated or suspended use of disposal areas. Additionally, the sewage pipe creek crossing should be inspected at least monthly. Observations shall be recorded and summarized in each quarterly monitoring report.

Reporting

Quarterly Reports shall be submitted as follows:

Sampling Performed in...	Shall be Reported by...
November, December, and January	February 20 th
February, March, and April	May 20 th
May, June, and July,	August 20 th
August, September, and October	November 20 th

The Quarterly reports shall contain all data collected or calculated and all observations made during the previous three sampling months. It shall also contain a narrative summary of any exceptions to the requirements of Waste Discharge Requirements Order RB3-2002-0019.

ORDERED BY



Executive Officer

3-26-02

Date