

California Regional Water Quality Control Board Central Valley Region

ORDER NO. R5-2011- 0088
NPDES NO. CA0083861

REVISED WASTE DISCHARGE REQUIREMENTS FOR AEROJET-GENERAL CORPORATION INTERIM GROUNDWATER EXTRACTION AND TREATMENT SYSTEMS ARGET, GET E/F, GET H-A, GET J, GET K-A, GET L-A, GET L-B, SAILOR BAR PARK WELL, CHETTENHAM WELL, GOLDEN STATE WATER WELLS AND LOW THREAT DISCHARGES SACRAMENTO COUNTY

The following Discharger is authorized to discharge in accordance with the conditions set forth in this Order:

Discharger	Aerojet-General Corporation
Name of Facility	Groundwater Extraction and Treatment Systems ARGET, GET E/F, GET H-A, GET J, GET K-A, GET L-A, GET L-B, Sailor Bar Park Well, Chettenham, Golden State Water Wells and Low-Threat Discharges
Facility Address	Aerojet Road
	Sacramento, CA 95813-6000
	Sacramento County

The Discharger is authorized to discharge from the following discharge points as set forth below:

Discharge Point	Effluent Description	Discharge Point Latitude	Discharge Point Longitude	Receiving Water
Outfall 001	Treated Groundwater from ARGET, GET E/F, GET J	38°, 38', 00" N	121°, 16', 07" W	Buffalo Creek to American River
Outfall 002*	Treated Groundwater from GET L-A	38°, 36', 29" N	121°, 18', 33" W	American River
Outfall 002A	Treated Groundwater from GET L-B	38°, 37', 31" N	121°, 18', 13" W	Drainage Ditch to American River
Outfall 003*	Outfall no longer proposed for use	38°, 36', 53" N	121°, 18', 10" W	Drainage Ditch to American River
Outfall 004	Treated Groundwater from GET K-A and AC-6	38°, 36', 07" N	121°, 19', 02" W	Drainage Ditch to American River

Outfall 005	Treated Groundwater from Chettenham Well and AC-23	38°, 34', 46" N	121°, 19', 42" W	Boyd Station Channel to American River
Outfall 006	Treated Groundwater from GET H-A an AC-18	38°, 32', 18" N	121°, 18', 59" W	Morrison Creek
Outfall 007	Treated Groundwater from Sailor Bar Well	38°, 37', 59" N	121°, 14', 21" W	Sailor Bar Pond
Outfall 008*	Treated Groundwater from Various GETs	38°, 38', 6" N	121°, 13', 13" W	American River at Natomas Stilling Basin
Outfall 009*	Treated Groundwater from Various GETs	38°, 38', 12" N	121°, 12', 11" W	Alder Creek – Tributary to the American River

*Future outfall

This Order was adopted by the Regional Board on:	1 December 2011
This Order shall become effective on:	1 December 2011
This Order shall expire on:	1 December 2016
The U.S. Environmental Protection Agency (U.S. EPA) and the Regional Board have classified this discharge as a minor discharge.	
The Discharger shall file a Report of Waste Discharge in accordance with Title 23, California Code of Regulations, not later than 180 days in advance of the Order expiration date as application for issuance of new waste discharge requirements.	

IT IS HEREBY ORDERED, that Order No.R5-2010-0039 is rescinded upon the effective date of this Order except for enforcement purposes, and, in order to meet the provisions contained in Division 7 of the CWC and regulations adopted thereunder, and the provisions of the federal CWA, and regulations and guidelines adopted thereunder, the Discharger shall comply with the requirements herein.

I, Pamela C. Creedon, Executive Officer, do hereby certify the following is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, Central Valley Region, on 21 December 2011.

Original signed by: _____
 PAMELA C. CREEDON, Executive Officer

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
 REGION 5, CENTRAL VALLEY REGION**

**ORDER NO. R5-2011-0088
 NPDES NO. CA0083861**

TABLE OF CONTENTS

I.	Facility Information	4
II.	Findings	4
III.	Discharge Prohibitions.....	10
IV.	Effluent Limitations and Discharge Specifications	10
	A. Effluent Limitations – Discharge Point 001	10
	B. Land Discharge Specifications – Not Applicable.....	19
	C. Reclamation Specifications – Not Applicable.....	19
V.	Receiving Water Limitations	19
	A. Surface Water Limitations.....	19
	B. Groundwater Limitations – Not Applicable	21
VI.	Provisions.....	21
	A. Standard Provisions.....	21
	B. Monitoring and Reporting Program Requirements.....	25
	C. Special Provisions.....	25
	1. Reopener Provisions	25
	2. Special Studies, Technical Reports and Additional Monitoring Requirements....	26
	3. Best Management Practices and Pollution Prevention - Not Applicable.....	28
	4. Compliance Schedules	28
	5. Construction, Operation and Maintenance Specifications.....	28
	6. Special Provisions for Municipal Facilities (POTWs Only) – Not Applicable.....	29
	7. Other Special Provisions –	29
VII.	Compliance Determination	36
	A. Average Monthly Effluent Limitation (AMEL).....	36
	B. Maximum Daily Effluent Limitation (MDEL).....	36
	C. Instantaneous Minimum Effluent Limitation.....	36
	D. Instantaneous Maximum Effluent Limitation.....	37
	E. Maximum 1-Hour Average.....	37
	Attachment A – Definitions	A-1
	Attachment B – Topographic Map	B-1
	Attachment C – Flow Schematics.....	C-1
	Attachment D – Federal Standard Provisions.....	D-1
	Attachment E – Monitoring and Reporting Program (MRP).....	E-1
	Attachment F – Fact Sheet.....	F-1

I. FACILITY INFORMATION

The following Discharger is authorized to discharge in accordance with the conditions set forth in this Order:

Discharger	Aerojet-General Corporation
Name of Facility	Groundwater Extraction and Treatment Systems
Facility Address	Aerojet Road
	Sacramento, CA 95813-6000
	Sacramento County
Facility Contact, Title, and Phone	Mr. Chris Fennessy, (916) 355-3341
Mailing Address	P.O. Box 13222 Sacramento, CA 95813-6000
Type of Facility	Groundwater Extraction and Treatment Plants
Facility Design Flows	ARGET – 4.96 million gallons per day (mgd) – Discharge 001, Outfall 001 GET E/F – 8.64 mgd – Discharge 002, Outfall 001 GET H-A – 2.88 mgd – Discharge 004, Outfall 005 and/or 006 GET J – 5.98 mgd – Discharge 005, Outfall 001 GET K-A – 4.03 mgd – Discharge 007, Outfall 004 GET L-A – 2.88 mgd – Discharge 008, Outfall 002 GET L-B – 1.44 mgd – Discharge 009, Outfall 002 Sailor Bar Pond – 0.36 mgd – Discharge 010, Outfall 007 Chettenham – 1.08 mgd, Discharge 011, Outfall 005 AC-6 – 1.08 mgd – Discharge 013, Outfall 004 AC-18 – 2.59 mgd - Discharge 014, Outfall 006 AC-23 – 3.17 mgd – Discharge 015, Outfall 006

II. FINDINGS

The California Regional Water Quality Control Board, Central Valley Region (hereinafter Regional Water Board), finds:

- A. **Background.** The Aerojet-General Corporation (hereafter, Discharger) is currently discharging under Order No. R5-2010-0039 and National Pollutant Discharge Elimination System (NPDES) Permit No. CA0083861. The Discharger originally submitted a Report of Waste Discharge, dated 11 April 2005 and supplemental information dated 28 April 2005 and 12 May 2005, and applied for a NPDES permit revision to discharge up to 39.09 mgd of treated groundwater from up to eleven groundwater extraction and treatment systems (GETs), with two of them being temporary.

The Discharger submitted a request dated 9 July 2007 to modify the effluent limitation for N-nitrosodimethylamine (NDMA) for GET J, and future treatment systems GET K-A, GET L-A and GET L-B. The adopted permit at the time, Order No. R5-2006-013, contained an interim effluent limit for NDMA for GET J of 0.010 micrograms per liter (µg/L) to allow an evaluation of the technical and economical issues regarding removal of NDMA. The Discharger provided sufficient information to allow the effluent limitation for NDMA for GETs J, K, L-A and L-B to be set at 0.007 µg/L. Further detailed discussion of this issue is found in Attachment F. In addition, in June 2007 the California Office of Health Hazard Assessment revised the Public Health Goal for NDMA from 0.002 µg/L to 0.003 µg/L. The

Regional Water Board revised the NPDES permit with the adoption of Order No. R5-2007-0165, modifying the effluent limitations for NDMA.

In 2008, the Discharger requested a revision to the effluent limitation for trichloroethylene (TCE) for the GET E/F discharge (Discharge 002). The combination of treatment technologies at the GET E/F system, utilizing the best available technologies for removal of volatile organics (which includes TCE), NDMA and perchlorate was demonstrated to not consistently meet the effluent limitation for TCE due to low concentrations of biosolids carryover from the perchlorate treatment system. The original effluent limitations for TCE were 0.5 µg/L for the monthly average and 0.7 µg/L for the daily maximum. The Primary Maximum Contaminant Level for TCE is 5.0 µg/L and the California Public Health Goal (one-in-a-million excess cancer risk) has been established by the California Office of Health Hazard Assessment at 1.7 µg/L. Resolution No. R5-2009-0016 revised the Effluent Limitation for TCE for GET E/F to 1.5 µg/L. None of the other discharge effluent limitations for TCE covered by the order were modified.

Since adoption of Order No. R5-2007-0165, the Discharger completed the construction of GET K-A and discontinued the operation of interim GET K and interim GET H. The Discharger submitted a revised Report of Waste Discharge dated 21 May 2009 requesting the addition of three new discharges associated with municipal water supply wells and several minor modifications. Three municipal water supply wells will be equipped with treatment units to remove pollutants associated with plumes in groundwater emanating from the Discharger's property. The treated water would initially be discharged to the stormwater drainage system for two to four months prior to allowing the water to be supplied for potable purposes. One well would be operated on a continuous basis to help cleanup the groundwater. Thus, at times, the treated water from the well would be discharged to the storm drain when the water was not needed for potable supply. The other two wells would be operated on an as-needed basis with the water going to the distribution system. All the wells would have periodic discharges of 1-2 minutes in duration during well startup and shutdown to minimize pressure issues within the distribution system.

The minor changes requested by the Discharger included:

- a. Changing the names of GET L-1 to GET L-B, GET L to GET L-A, and GET K to GET K-A;
- b. moving the outfall from GET L-A to the American River (Outfall 002) approximately 1,900 feet downstream; and
- c. moving the discharge from GET K-A from Outfall 003 to Outfall 004 in response to a request from the City of Rancho Cordova.

In addition, the Discharger requested allowing removal of the perchlorate treatment system on the Chettenham well, while continuing to operate the well with discharge to the storm drain in order to evaluate the continued operation on groundwater pollution containment. The concentrations of perchlorate have dropped from a high of over 90 µg/L to less than 4 µg/L. The effluent limitation in the existing permit is 4 µg/L. The PHG and MCL for

perchlorate are both 6 µg/L. The effluent limitation for perchlorate for the discharge from the Chettenham well treatment system is revised to 6 µg/L when there is no treatment system on the well. However, if treatment is subsequently restarted, the effluent reverts to the 4 µg/L value, based on best available technology.

Since adoption of Order No. R5-2010-0039, the Discharger has constructed the three treatment systems on the three municipal supply wells, AC-6, AC-18 and AC-23 and commenced operation of the AC-6 well system. The construction and potential operation of the three systems has changed from what was anticipated in the 2010 revision to this permit. During initial testing of the treatment systems for AC-18 and AC-23 it was noted that fine particles entered the system during the first 10 minutes of startup of the water supply well. In order to prevent clogging of the ion exchange resin, the two systems will be plumbed to allow the fines to dissipate prior to sending the water through the resin. Those first few minutes of flow will be discharged to the storm drain.

As these discharges are not through the treatment system, the discharges during startup and shutdown of the wells are considered well purging and covered under Discharge Point 12 of this permit. Generally during well startup and shutdown, the discharge occurs for 1 to 3 minutes, but may be up to 15 -20 minutes at AC-18 and AC-23 to minimize the concentration of fines. Subsequent discharges that are not during well startup and shutdown are covered under Discharge Point 13 for AC-6, Discharge Point 14 for AC-18 and Discharge Point 15 for AC-23.

In addition to the discharges during operation of the wells, there will be discharges of water during resin exchange and during well rehabilitation. Resin exchange discharge occurs during draining of the vessel, rinsing the vessel and adding the new resin. These discharges are generally of low volume (1000-8000 gallons) and occur infrequently. There may be instances where the discharge will last up to four days if bacteria are found after resin change-out. This fits within the parameters listed for Discharge Point 12. Well rehabilitation for these three wells occurs every 3-5 years and also falls within the parameters of Discharge Point 12.. Since these discharges are either of low volume or occur very infrequently, they are considered low threat and are covered under Discharge Point 12.

The last change being made at this time is to the time schedule for compliance with the effluent limitation for the ARGET facility. As USEPA was delayed in its order to Aerojet to implement the Record of Decision for Operable Unit 5 (issued September 2011), that includes the ARGET facility, implementation of the remedy and upgrade of the ARGET facility has also been delayed. It is estimated that the construction of the perchlorate treatment facility at ARGET will occur by 1 December 2013. The schedule has been changed to reflect this information.

This permit also continues to allow Aerojet to discharge low-threat discharges consisting of monitor well, extraction well and water supply well development water, purge water and

extraction and supply well aquifer test water. Those discharges are subject to similar effluent limitations as established for the GETs.

- B. Facility Descriptions.** The Discharger currently owns and operates eight groundwater extraction and treatment systems (hereafter "Facilities") that discharge treated groundwater to surface waters in accordance with an NPDES permit. One facility, GET L-A, is still under construction.
- a. ARGET (Discharge 001). The American River Study Area (ARSA) treatment facility is on the Aerojet site. The facility consists of a ozone and hydrogen peroxide advanced oxidation process to reduce concentrations of volatile organic compounds (VOCs) and 1,4-dioxane, and air-stripping to remove any remaining VOCs. See Attachment C-1.
 - b. GET E/F (Discharge 002). The GET E/F facility is also on Aerojet property. It uses biological reduction to remove perchlorate, an ultraviolet light and hydrogen peroxide process to destroy NDMA and VOCs, and air stripping to remove remaining VOCs from up to 6000 gpm of influent. There is also a sand filter and clarifier for solids control. The solids from the clarifier are discharged to the sanitary sewer under a Sacramento County Regional Sanitation District (SCRSD) issued permit. The GET E/F facility has been operating in its current configuration since 2000. See Attachment C-2.
 - c. GET H-A (Discharge 004). The interim GET H facility (Discharge 003) discontinued operation in 2006 and all of the GET H extraction wells feed into the GET H-A facility. The GET H-A facility (Discharge 004), completed in 2006, utilizes granular activated carbon (GAC) to remove VOCs and ion exchange resin to remove perchlorate from approximately 2000 gpm of extracted groundwater. See Attachment C-4.
 - d. GET J (Discharge 005). The GET J facility is similar to GET H-A, but with the addition of ultraviolet/hydrogen peroxide treatment for the destruction of NDMA and particulate filtration to help the ultraviolet system. The facility was recently upgraded to allow for hydrogen peroxide addition to be used with the UV treatment to additionally destroy VOCs. The Discharger may discontinue use of the GAC treatment provided the advanced UV oxidation meets VOC effluent limitations The system is designed to treat 4150 gpm and is found on Pyrites Way in Gold River. See Attachment C-5.
 - e. GET K-A (Discharge 007). Use of the interim GET K facility (Discharge 006) was discontinued in 2009 with the completion of the GET K-A facility. The GET K-A facility uses particulate removal, hydrogen peroxide addition and ultraviolet light for treatment of NDMA and low concentrations of VOCs from an influent of 2880 gpm. The facility is located on Coloma Road in Rancho Cordova. See Attachment C-7.
 - f. GET L-A (Discharge 008). GET L-A (Discharge 008) is in Carmichael, near Ancil Hoffman Park and is currently under construction with completion anticipated in 2010. The facility will initially treat for NDMA using ultraviolet light. In the future, if VOCs and/or perchlorate are detected in the influent, VOC and/or perchlorate treatment will be added utilizing the same processes described above fro the GET K-A and GET J facilities. Whenever possible, the discharge from GET L-A will be applied to the adjacent Ancil Hoffman Golf Course.
 - g. GET L-B (Discharge 009). GET L-B is in Carmichael northeast of GET L-A and is adjacent to the Carmichael Water District water treatment plant. The plant utilizes ultraviolet light to destroy NDMA. The facility has been constructed to allow for

- expansion for perchlorate and VOC treatment units if the influent is determined to contain those pollutants. See Attachment C-9.
- h. Sailor Bar Park (Discharge 010). The Sailor Bar Park system provides for removal of VOCs by GAC on a water supply well for the pond in Sailor Bar Park. The park is on the north side of the American River adjacent to the village of Fair Oaks, approximately one half mile west of the Hazel Avenue Bridge.
 - i. Chettenham (Discharge 011). The Discharger has negotiated with California American Water Company (CalAm), owner of the Chettenham Well, to use the Chettenham Well on an interim basis as an extraction point to control a portion of the groundwater pollution and evaluate the effects of pumping the well on the groundwater pollution containment system. Wellhead treatment consisting of ion exchange for perchlorate removal is installed at the well site and will be used when necessary to keep the effluent concentration of perchlorate below 6 µg/L. The discharge is to the Boyd Station Channel.
 - j. Purge and Aquifer Test Waters (Discharge 012). The Discharger develops and purges wells prior to sampling and conducts aquifer tests on extraction/supply wells to determine aquifer characteristics to allow GET systems to be designed. These activities take place over vast areas on and off the Discharger's property. The purge water is generally low in volume (100's – 5000 gallons) and is provided treatment prior to discharge. Treatment is provided on the discharges to remove the pollutants of concern. If treatment is not practical, the water is contained and discharged through the sanitary sewer system with the Discharger's wastewater discharge permit with the SRCSD. In addition to these well discharges, low volumes of water are discharged from three wellhead treatment systems described below in Discharges 013, 014 and 015 during replacement of the ion exchange resin. The discharges occur infrequently and depend on the concentration of perchlorate in the influent to the treatment system which affects the useable life of the resin.
 - k. AC-6 (Discharge 013). Golden State Water Company's (Golden State) water supply well AC-6 on Dolecetto Drive in Rancho Cordova has been found to contain perchlorate. The Discharger has reached agreement with Golden State whereby a treatment system for perchlorate removal using ion-exchange has been added to the well site. The treated water will usually be placed into the potable water distribution system. During periods of low water demand, treated water produced by the well in excess of the demand may also be discharged to the storm drain.
 - l. AC-18 (Discharge 014). Golden State's water supply well AC-18 on International Drive in Rancho Cordova has been found to contain perchlorate. Similar to well AC-6, perchlorate removal using ion-exchange has been added to AC-18 well site. This well will only be operated on-demand and so the discharge to the storm drain will only occur during well startup and shutdown to minimize pressure issues within the distribution system.
 - m. AC-23 (Discharge 015). Golden State's water supply well (AC-23) on Capital Center Drive in Rancho Cordova also requires treatment to remove perchlorate. This system is identical to that described above for Discharge 014, Well AC-18.

Treated groundwater is discharged from Discharges 001, 002 and 005 to Buffalo Creek (tributary to the American River), from Discharges 004 and 014 to Morrison Creek (tributary

to the Sacramento River), from Discharges 007, 008, 009, 011, 013 and 015 to drainage channels to the American River, and from Discharge 010 to a pond in Sailor Bar Park (see table on cover page), waters of the United States and part of the Sacramento-San Joaquin Delta (Delta) within the American River and Sacramento River watersheds. Sacramento County requested during development of the previous permit to allow for the potential discharge from some or all of the GETs covered in this permit to Alder Creek, to assist in their reuse of the treated groundwater. The previous NPDES permit and this permit include a provision allowing for the discharge to Alder Creek pending completion of acceptable studies of the potential thermal and toxicity impacts on Alder Creek, Lake Natoma, the American River and the Nimbus Fish Hatchery. Attachment B-1 provides a map describing the locations of the Facilities. Attachments C-1 through C-11 provide wastewater flow schematics of the Facilities.

- C. **Legal Authorities.** This Order is issued pursuant to section 402 of the Federal Clean Water Act (CWA) and implementing regulations adopted by the U.S. Environmental Protection Agency (USEPA) and Chapter 5.5, Division 7 of the California Water Code (CWC). It shall serve as a NPDES permit for point source discharges from these facilities to surface waters. This Order also serves as Waste Discharge Requirements (WDRs) pursuant to Article 4, Chapter 4 of the CWC for discharges that are not subject to regulation under CWA section 402.
- D. **Background and Rationale for Requirements.** The Regional Water Board developed the requirements in this Order based on information submitted as part of the application, through monitoring and reporting programs, and through special studies. Attachments A through G, which contain background information and rationale for Order requirements, are hereby incorporated into this Order and, thus, constitute part of the Findings for this Order.
- E. **California Environmental Quality Act (CEQA).** This action to adopt an NPDES permit is exempt from the provisions of the California Environmental Quality Act (Public Resources Code Section 21100, et seq.) in accordance with Section 13389 of the CWC. The Department of Toxic Substances Control certified a final Negative Declaration and Initial Study for the American River Study Area project in accordance with CEQA and State CEQA Guidelines. The Board has reviewed the negative declaration and these waste discharge requirements will mitigate or avoid any significant impacts on water quality due to the discharges from the ARGET facility.
- F. **Technology-based Effluent Limitations.** The Code of Federal Regulations (CFR) at 40 CFR §122.44(a) requires that permits include applicable technology-based limitations and standards. This Order includes technology-based effluent limitations that protect the beneficial uses of the receiving waters. The Regional Water Board has considered the factors listed in CWC §13241 in establishing these requirements. A detailed discussion of the technology-based effluent limitations development is included in the Fact Sheet (Attachment F).
- G. **Water Quality-based Effluent Limitations.** Section 122.44(d) of 40 CFR requires that permits include water quality-based effluent limitations (WQBELs) to attain and maintain

applicable numeric and narrative water quality criteria to protect the beneficial uses of the receiving water. Where numeric water quality objectives have not been established, 40 CFR §122.44(d) specifies that WQBELs may be established using USEPA criteria guidance under CWA section 304(a), proposed State criteria or a State policy interpreting narrative criteria supplemented with other relevant information, or an indicator parameter.

H. **Water Quality Control Plans.** The Regional Water Board adopted a *Water Quality Control Plan for the Sacramento River and San Joaquin River Basins, Fourth Edition* (hereinafter Basin Plan) that designates beneficial uses, establishes water quality objectives, and contains implementation programs and policies to achieve those objectives for all waters addressed through the plan.

The Basin Plan at page II-2.00 states that the beneficial uses of any specifically identified water body generally applies to its tributary streams. The Basin Plan does not specifically identify beneficial uses for Buffalo Creek and Alder Creek, or Morrison Creek, tributary to the American River and Sacramento River, respectively, but does identify present and potential uses for the American and Sacramento Rivers. These beneficial uses are municipal and domestic supply (MUN); agricultural supply, irrigation and stock watering (AGR); water contact recreation (REC-1); non-contact water recreation (REC-2); warm freshwater habitat (WARM); cold freshwater habitat (COLD); warm and cold migration of aquatic organisms (MIGR); warm and cold spawning (SPWN); wildlife habitat (WILD). In addition, State Water Resources Control Board (State Water Board) Resolution No. 88-63 requires that, with certain exceptions, the Regional Water Board assign the municipal and domestic supply use to water bodies that do not have beneficial uses listed in the Basin Plan. Thus, as discussed in detail in this Fact Sheet, beneficial uses applicable to the American River, Sacramento River, Buffalo Creek, Alder Creek, Morrison Creek and Sailor Bar Park Pond are as follows:

Discharge Point	Receiving Water Name	Beneficial Use(s)
001, 002 and 005	Buffalo Creek and Alder Creek, Tributary of the American River	<u>Existing:</u> MUN, AGR, REC-1, REC-2, WARM, COLD, MIGR, SPWN, WILD.
004 and 014	Morrison Creek, Tributary of the Sacramento River	<u>Existing:</u> MUN, AGR, REC-1, REC-2, WARM, COLD, MIGR, SPWN, WILD.
007, 008, 009, 011, 012, 013 and 015	American River	<u>Existing:</u> MUN, AGR, REC-1, REC-2, WARM, COLD, MIGR, SPWN, WILD.
010	Sailor Bar Pond, Potentially tributary to American River	<u>Existing:</u> MUN, AGR, REC-1, REC-2, WARM, COLD, MIGR, SPWN, WILD.

The Basin Plan includes a Wastewater Reuse Policy that encourages the reclamation and reuse of wastewater, including treated groundwater resulting from a cleanup action, where practicable. Those reuse options include municipal and industrial supply, crop irrigation, groundwater recharge, and wetland restoration. At this time, demonstrated cost-effective options that provides for reuse of the treated groundwater have been identified in the

Discharger's Reuse Plan, and agreements with water users are being negotiated. The Discharger and Sacramento County had entered into an agreement whereby the water discharged from the GETs was transferred to the County. The County analyzed a project for reuse of the treated groundwater whereby the County would take the water out of the Sacramento River and transfer the water back up to eastern Sacramento County. The County determined that the project was not cost-effective and terminated the agreement. New negotiations between the Discharger, Sacramento County and other water purveyors are on-going.

Several of the Dischargers GET facilities and future facilities are already providing or will be providing beneficial reuse of the treated groundwater. The discharge from the Sailor Bar Park facility (Discharge 010) is to the pond at the park maintaining the habitat provided by the pond throughout the year. The proposed use of treated water at Golden State wells AC-6, AC-18, and AC-23 is a beneficial use of this water that would otherwise be required to be taken from another source. A majority of the treated water from the GET L-A facility (Discharge 008) will be used for the direct irrigation of the Ancil Hoffman Golf Course whenever practical.

Until it is feasible for the remaining GET discharges to be reused, discharge to the American River and Sacramento River, and their tributaries, for a limited duration is a reasonable use of the treated groundwater on an interim basis since it implements the goals of cleaning up the aquifer, restoring its beneficial uses, and preventing additional public supply wells from being polluted as other alternatives are considered.

The remediation project has a potential effect on the sustainable yield of the groundwater basin from which the extraction fields takes its water. The Discharger, in accordance with requirements of a previous version of this Order, evaluated the sustainable yield of the aquifer south of the American River in a report dated 12 September 2003. That report stated that there would be an additional drawdown in the eastern part of Sacramento County in the vicinity of OU-3 of up to 30 feet. Implementation of the reuse alternatives contained in the Reuse Plan will help substantially mitigate the impact of the withdrawal of groundwater for remediation purposes. The required evaluations allowed the Regional Board to determine whether there are additional environmental impacts of the Discharger's pumping and will encourage the reuse of treated groundwater consistent with the Wastewater Reuse Policy set forth in the Basin Plan.

The State Water Board adopted a *Water Quality Control Plan for Control of Temperature in the Coastal and Interstate Water and Enclosed Bays and Estuaries of California* (Thermal Plan) on May 18, 1972, and amended this plan on September 18, 1975. This plan contains temperature objectives for inland surface waters.

Requirements of this Order specifically implement the applicable Water Quality Control Plans.

- I. **National Toxics Rule (NTR) and California Toxics Rule (CTR).** USEPA adopted the NTR on December 22, 1992, which was amended on May 4, 1995 and November 9, 1999,

and the CTR on May 18, 2000, which was amended on February 13, 2001. These rules include water quality criteria for priority pollutants and are applicable to this discharge.

- J. **State Implementation Policy.** On March 2, 2000, State Water Board adopted the *Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California* (State Implementation Policy or SIP). The SIP became effective on April 28, 2000, with respect to the priority pollutant criteria promulgated for California by the USEPA through the NTR and to the priority pollutant objectives established by the Regional Water Boards in their basin plans, with the exception of the provision on alternate test procedures for individual discharges that have been approved by USEPA Regional Administrator. The alternate test procedures provision was effective on May 22, 2000. The SIP became effective on May 18, 2000. The SIP includes procedures for determining the need for and calculating WQBELs and requires dischargers to submit data sufficient to do so.
- K. **Compliance Schedules and Interim Requirements.** This permit has interim effluent limits for perchlorate at ARGET. The interim effluent limitation for perchlorate at ARGET is 11 µg/L until 1 December 2012, or earlier if perchlorate treatment has been added to ARGET. See Attachment F, Sections IV(E)(1) and VII(1)(3).
- L. **Antidegradation Policy.** Section 131.12 of 40 CFR requires that State water quality standards include an antidegradation policy consistent with the federal policy. The State Water Board established California's antidegradation policy in State Water Board Resolution 68-16, which incorporates the requirements of the federal antidegradation policy. Resolution 68-16 requires that existing quality of waters be maintained unless degradation is justified based on specific findings. As discussed in detail in the Fact Sheet (Attachment F) the permitted discharge is consistent with the antidegradation provision of 40 CFR Section 131.12 and State Water Board Resolution 68-16.
- M. **Anti-Backsliding Requirements.** Sections 402(o)(2) and 303(d)(4) of the CWA and federal regulations at 40 CFR § 122.44(l) prohibit backsliding in NPDES permits. These anti-backsliding provisions require effluent limitations in a reissued permit to be as stringent as those in the previous permit, with some exceptions where limitations may be relaxed. All effluent limitations in this Order are at least as stringent as the effluent limitations in the previous Order.
- N. **Monitoring and Reporting.** Section 122.48 of 40 CFR requires that all NPDES permits specify requirements for recording and reporting monitoring results. Sections 13267 and 13383 of the CWC authorize the Regional Water Boards to require technical and monitoring reports. The Monitoring and Reporting Program establishes monitoring and reporting requirements to implement federal and State requirements. This Monitoring and Reporting Program is provided in Attachment E.
- O. **Standard and Special Provisions.** Standard Provisions, which in accordance with 40 CFR §§122.41 and 122.42, apply to all NPDES discharges and must be included in every NPDES permit, are provided in Attachment D. The Regional Water Board has also included

in this Order special provisions applicable to the Discharger. A rationale for the special provisions contained in this Order is provided in the attached Fact Sheet (Attachment F).

- P. Notification of Interested Parties.** The Regional Water Board has notified the Discharger and interested agencies and persons of its intent to prescribe Waste Discharge Requirements for the discharge and has provided them with an opportunity for a public hearing and to submit their written comments and recommendations. Details of notification are provided in the Fact Sheet (Attachment F) of this Order.
- Q. Consideration of Public Comment.** The Regional Water Board, in a public meeting, heard and considered all comments pertaining to the discharge. Details of the Public Hearing are provided in the Fact Sheet (Attachment F) of this Order.
- R.** This Order contains restrictions on individual pollutants that are no more stringent than required by the federal CWA. Individual pollutant restrictions consist of technology-based restrictions and water quality-based effluent limitations. The technology-based effluent limitations consist of restrictions on VOCs, perchlorate, and NDMA. Water quality-based effluent limitations have been scientifically derived to implement water quality objectives that protect beneficial uses. Both the beneficial uses and the water quality objectives have been approved pursuant to federal law and are the applicable federal water quality standards. To the extent that toxic pollutant water quality-based effluent limitations were derived from the CTR, the CTR is the applicable standard pursuant to 40 CFR section 131.38. The scientific procedures for calculating the individual water quality-based effluent limitations are based on the CTR-SIP, which was approved by USEPA on May 1, 2001. All beneficial uses and water quality objectives contained in the Basin Plan were approved under state law and submitted to and approved by USEPA prior to May 30, 2000. Any water quality objectives and beneficial uses submitted to USEPA prior to May 30, 2000, but not approved by USEPA before that date, are nonetheless “applicable water quality standards for purposes of the [Clean Water] Act” pursuant to 40 CFR section 131.21(c)(1). Collectively, this Order’s restrictions on individual pollutants are no more stringent than required to implement the technology-based requirements of the CWA and the applicable water quality standards for purposes of the CWA.

III. DISCHARGE PROHIBITIONS

- A. Discharge of wastewater at a location or in a manner different from that described in the Findings is prohibited.
- B. The by-pass or overflow of wastes to surface waters is prohibited, except as allowed by Standard Provision I.G of Attachment D, Federal Standard Provisions.
- C. Neither the discharge nor its treatment shall create a nuisance as defined in Section 13050 of the California Water Code.
- D. Discharge of wastewater to Outfall 008 and 009 is prohibited until approved by the Executive Officer. Completion of an adequate assessment of the thermal impacts,

including a dilution study in Alder Creek/Lake Natoma, and potential impacts on the Natomas Fish Hatchery associated with those discharges at those two outfalls is required before consideration of approval by the Executive Officer.

IV. EFFLUENT LIMITATIONS AND DISCHARGE SPECIFICATIONS

A. Effluent Limitations – Discharge Points 001, 002, 004, 005, 007, 008, 009, 010, 011, 012, 013, 014 and 015 (Discharge Points 003 and 006 are no longer used)

1. Final Effluent Limitations

a. Discharge Point 001.

- i. The discharge of effluent from the ARGET facilities shall maintain compliance with the following effluent limitations at Discharge Point 001, with compliance measured at Monitoring Location M-001, as described in the attached Monitoring and Reporting Program (Attachment E):

Parameter	Units	Effluent Limitations			
		Average Monthly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
Flow – Discharge 001	mgd	5.0	5.0	--	--
Volatile Organic Contaminants ¹	µg/L	0.5	0.7	--	--
	lbs/day	0.02	0.03	--	--
1,2-Dichloroethane	µg/L	0.38	0.5	--	--
	lbs/day	0.016	0.02	--	--
1,4-Dioxane	µg/L	3	6	--	--
	lbs/day	0.125	0.25	--	--
N-nitrosodimethylamine	µg/L	0.002	0.010	--	--
	lbs/day	0.000083	0.00042	--	--
Perchlorate ²	µg/L	4	6	--	--
	lbs/day	0.167	0.25	--	--
Total Copper	µg/L	11	17	--	--
	lbs/day	0.46	0.71	--	--
pH	standard units	--	--	6.5	8.5

¹ All volatile organic constituents listed in EPA Methods 8010/8020 or 8260. The concentration of each constituent shall not exceed 0.5 µg/L, except for those constituents that have a specific limit in the table.

² See interim effluent for perchlorate, Section IV, 2.

- ii. Survival of aquatic organisms in 96-hour bioassays shall be no less than 70% for any one bioassay and 90% for the median of any three or more consecutive bioassays.

b. Discharge Point 002

- i. The discharge of effluent from the GET E/F facilities shall maintain compliance with the following effluent limitations at Discharge Point 002, with compliance measured at Monitoring Location M-002, as described in the attached Monitoring and Reporting Program (Attachment E):

Parameter	Units	Effluent Limitations			
		Average Monthly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
Flow – Discharge 002	mgd	8.64	8.64	--	--
Volatile Organic Contaminants ¹	µg/L	0.5	0.7	--	--
	lbs/day	0.036	0.050	--	--
Trichloroethylene	µg/L	--	1.5, 3.0 ²	--	--
	lbs/day	--	0.11, 0.22 ²		
1,2-Dichloroethane	µg/L	0.38	0.5	--	--
	lbs/day	0.028	0.036	--	--
1,4-Dioxane	µg/L	3	6	--	--
	lbs/day	0.23	0.43	--	--
N-nitrosodimethylamine	µg/L	0.002	0.010	--	--
	lbs/day	0.00015	0.00072	--	--
Perchlorate	µg/L	4	6	--	--
	lbs/day	0.300	0.43	--	--
Total Copper	µg/L	11	17	--	--
	lbs/day	0.82	1.22	--	--
Acetaldehyde	µg/L	5	5	--	--
	lbs/day	0.38	0.36	--	--
Formaldehyde	µg/L	50	50	--	--
	lbs/day	3.7	3.6		
pH	standard units	--	--	6.5	8.5

¹ All volatile organic constituents listed in EPA Methods 8010/8020 or 8260. The concentration of each constituent shall not exceed 0.5 µg/L, except for those constituents that have a specific limit in the table.

² The daily maximum value is 1.5 µg/L, except during times when the Discharger is making operational changes to correct effluent exceedences from GET E/F. During those times, the daily maximum effluent limitation is 3.0 µg/L when approved by the Executive Officer.

- ii. Survival of aquatic organisms in 96-hour bioassays shall be no less than 70% for any one bioassay and 90% for the median of any three or more consecutive bioassays.

c. Discharge Point 003

- i. This Discharge Point is no longer used as all extracted groundwater from Area 1 is sent to the GET H-A (Discharge 004) facility.

d. Discharge Point 004

- i. The discharge of effluent from the GET H-A facility shall maintain compliance with the following effluent limitations at Discharge Point 004, with compliance measured at Monitoring Location M-004, as described in the attached Monitoring and Reporting Program (Attachment E):

Parameter	Units	Effluent Limitations			
		Average Monthly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
Flow – Discharge 004	mgd	2.88	6.5	--	--
Volatile Organic Contaminants ¹	µg/L	0.5	0.7	--	--
	lbs/day	0.012	0.017	--	--
1,2-Dichloroethane	µg/L	0.38	0.5	--	--
	lbs/day	0.009	0.012	--	--
Perchlorate	µg/L	4	6	--	--
	lbs/day	0.096	0.14	--	--
pH	standard units	--	--	6.5	8.5

¹ All volatile organic constituents listed in EPA Methods 8010/8020 or 8260. The concentration of each constituent shall not exceed 0.5 µg/L, except for those constituents that have a specific limit in the table.

- ii. Survival of aquatic organisms in 96-hour bioassays shall be no less than 70% for any one bioassay and 90% for the median of any three or more consecutive bioassays.

e. Discharge Point 005

- i. The discharge of effluent from the GET J facilities shall maintain compliance with the following effluent limitations at Discharge Point 005, with compliance measured at Monitoring Location M-005, as described in the attached Monitoring and Reporting Program (Attachment E):

Parameter	Units	Effluent Limitations			
		Average Monthly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
Flow – Discharge 005	mgd	5.98	5.98	--	--
Volatile Organic Contaminants ¹	µg/L	0.5	0.7	--	--
	lbs/day	0.025	0.035	--	--

Parameter	Units	Effluent Limitations			
		Average Monthly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
1,2-Dichloroethane	µg/L	0.38	0.5	--	--
	lbs/day	0.019	0.025	--	--
1,4-Dioxane	µg/L	3	6	--	--
	lbs/day	0.15	0.30	--	--
N-nitrosodimethylamine	µg/L	0.007	0.010	--	--
	lbs/day	0.00035	0.0005	--	--
Perchlorate	µg/L	4	6	--	--
	lbs/day	0.20	0.30	--	--
pH	standard units	--	--	6.5	8.5
Chloroform	µg/L	3.0	5.0		
	lbs/day	0.15	0.3		

¹ All volatile organic constituents listed in EPA Methods 8010/8020 or 8260. The concentration of each constituent shall not exceed 0.5 µg/L, except for those constituents that have a specific limit in the table.

- ii. Survival of aquatic organisms in 96-hour bioassays shall be no less than 70% for any one bioassay and 90% for the median of any three or more consecutive bioassays.

f. Discharge Point 006

- i. Discharge Point 006 is no longer used. The extracted groundwater is now being sent to GET K-A described under Discharge Point 007.

g. Discharge Point 007

- i. The discharge of effluent from the GET K-A facilities shall maintain compliance with the following effluent limitations at Discharge Point 007, with compliance measured at Monitoring Location M-007, as described in the attached Monitoring and Reporting Program (Attachment E):

Parameter	Units	Effluent Limitations			
		Average Monthly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
Flow – Discharge 007	mgd	4.03	4.03	--	--
Volatile Organic Contaminants ¹	µg/L	0.5	0.7	--	--
	lbs/day	0.017	0.024	--	--
1,2-Dichloroethane	µg/L	0.38	0.5	--	--
	lbs/day	0.013	0.017	--	--
N-nitrosodimethylamine	µg/L	0.007	0.010	--	--
	lbs/day	0.00023	0.00034	--	--
Perchlorate	µg/L	4	6	--	--
	lbs/day	0.134	0.202	--	--

Parameter	Units	Effluent Limitations			
		Average Monthly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
pH	standard units	--	--	6.5	8.5

¹ All volatile organic constituents listed in EPA Methods 8010/8020 or 8260. The concentration of each constituent shall not exceed 0.5 µg/L, except for those constituents that have a specific limit in the table.

- ii. Survival of aquatic organisms in 96-hour bioassays shall be no less than 70% for any one bioassay and 90% for the median of any three or more consecutive bioassays.

h. Discharge Point 008

- i. The discharge of effluent from the GET L-A facilities shall maintain compliance with the following effluent limitations at Discharge Point 008, with compliance measured at Monitoring Location M-008, as described in the attached Monitoring and Reporting Program (Attachment E):

Parameter	Units	Effluent Limitations			
		Average Monthly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
Flow – Discharge 008	mgd	2.88	2.88	--	--
Volatile Organic Contaminants ¹	µg/L	0.5	0.7	--	--
	lbs/day	0.012	0.017	--	--
1,2-Dichloroethane	µg/L	0.38	0.5	--	--
	lbs/day	0.009	0.012	--	--
N-nitrosodimethylamine	µg/L	0.007	0.010	--	--
	lbs/day	0.00017	0.00024	--	--
Perchlorate	µg/L	4	6	--	--
	lbs/day	0.096	0.14	--	--
pH	standard units	--	--	6.5	8.5

¹ All volatile organic constituents listed in EPA Methods 8010/8020 or 8260. The concentration of each constituent shall not exceed 0.5 µg/L, except for those constituents that have a specific limit in the table.

- ii. Survival of aquatic organisms in 96-hour bioassays shall be no less than 70% for any one bioassay and 90% for the median of any three or more consecutive bioassays.

i. Discharge Point 009

- i. The discharge of effluent from the GET L-B facilities shall maintain compliance with the following effluent limitations at Discharge Point 009, with compliance measured at Monitoring Location M-009, as described in the attached Monitoring and Reporting Program (Attachment E):

Parameter	Units	Effluent Limitations			
		Average Monthly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
Flow – Discharge 009	mgd	1.44	1.44	--	--
Volatile Organic Contaminants ¹	µg/L	0.5	0.7	--	--
	lbs/day	0.006	0.0084	--	--
1,2-Dichloroethane	µg/L	0.38	0.5	--	--
	lbs/day	0.0046	0.006	--	--
N-nitrosodimethylamine	µg/L	0.007	0.010	--	--
	lbs/day	0.000084	0.00012	--	--
Perchlorate	µg/L	4	6	--	--
	lbs/day	0.048	0.072	--	--
pH	standard units	--	--	6.5	8.5

¹ All volatile organic constituents listed in EPA Methods 8010/8020 or 8260. The concentration of each constituent shall not exceed 0.5 µg/L, except for those constituents that have a specific limit in the table.

- ii. Survival of aquatic organisms in 96-hour bioassays shall be no less than 70% for any one bioassay and 90% for the median of any three or more consecutive bioassays.

j. Discharge Point 010

- i. The discharge of effluent from the Sailor Bar Park Well facilities shall maintain compliance with the following effluent limitations at Discharge Point 010, with compliance measured at Monitoring Location M-010, as described in the attached Monitoring and Reporting Program (Attachment E):

Parameter	Units	Effluent Limitations			
		Average Monthly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
Flow – Discharge 010	mgd	0.36	0.36	--	--
Volatile Organic Contaminants ¹	µg/L	0.5	0.7	--	--
	lbs/day	0.0015	0.0021	--	--
1,2-Dichloroethane	µg/L	0.38	0.5	--	--
	lbs/day	0.00127	0.0015	--	--
Perchlorate	µg/L	4	6	--	--
	lbs/day	0.012	0.018	--	--
pH	standard units	--	--	6.5	8.5

¹ All volatile organic constituents listed in EPA Methods 8010/8020 or 8260. The concentration of each constituent shall not exceed 0.5 µg/L, except for those constituents that have a specific limit in the table.

- ii. Survival of aquatic organisms in 96-hour bioassays shall be no less than 70% for any one bioassay and 90% for the median of any three or more consecutive bioassays.

k. Discharge Point 011

- i. The discharge of effluent from the Chettenham Well facilities shall maintain compliance with the following effluent limitations at Discharge Point 011, with compliance measured at Monitoring Location M-011, as described in the attached Monitoring and Reporting Program (Attachment E):

Parameter	Units	Effluent Limitations			
		Average Monthly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
Flow – Discharge 011	mgd	1.1	1.1	--	--
Volatile Organic Contaminants ¹	µg/L	0.5	0.7	--	--
	lbs/day	0.0046	0.0064	--	--
1,2-Dichloroethane	µg/L	0.38	0.5	--	--
	lbs/day	0.0035	0.0046	--	--
Perchlorate	µg/L	4, 6 ²	6	--	--
	lbs/day	0.036/0.055	0.055	--	--
pH	standard units	--	--	6.5	8.5

¹ All volatile organic constituents listed in EPA Methods 8010/8020 or 8260. The concentration of each constituent shall not exceed 0.5 µg/L, except for those constituents that have a specific limit in the table.

² When perchlorate treatment system is being used the monthly average limitation is 4 µg/L. When no treatment system is being used the monthly average is 6 µg/L.

- ii. Survival of aquatic organisms in 96-hour bioassays shall be no less than 70% for any one bioassay and 90% for the median of any three or more consecutive bioassays.

l. Discharge Point 012 - Purge and Aquifer Test Waters

- i. The discharge of purge water and aquifer test water from monitor wells, extraction wells, and supply wells shall maintain compliance with the following effluent limitations with compliance measured at Monitoring Point M-012, as described in the attached Monitoring and Reporting Program (Attachment E):

Parameter	Units	Effluent Limitations			
		Total Maximum Discharge ¹	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
Flow – Per Monitor Well	mgd	0.01	0.01		

Parameter	Units	Effluent Limitations			
		Total Maximum Discharge ¹	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
Flow – Per Aquifer Test or water supply well startup/shutdown ¹	million gallons	14.4	3.6		
Volatile Organic Contaminants ²	µg/L	--	5.0	--	--
1,4-Dioxane	µg/L		10		
N-nitrosodimethylamine	µg/L		0.020	--	--
Perchlorate	µg/L		12		
pH	standard units	--	--	6.5	8.5

¹ Based on a well purge or aquifer test rehabilitation at 2500 gpm for a duration of 4 days.

² All volatile organic constituents listed in EPA Methods 8010/8020 or 8260. The concentration of each constituent shall not exceed 5.0 µg/L, except for those constituents that have a specific limit in the table.

m. Discharge Point 013

- i. The discharge of effluent from the Golden State’s water well AC-6 facilities shall maintain compliance with the following effluent limitations at Discharge Point 013, with compliance measured at Monitoring Locations M-013, as described in the attached Monitoring and Reporting Program (Attachment E):

Parameter	Units	Effluent Limitations			
		Average Monthly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
Flow – Discharge 013	mgd	1.08	1.08	--	--
Volatile Organic Contaminants ¹	µg/L	0.5	0.7	--	--
	lbs/day	0.0046	0.0064	--	--
1,2-Dichloroethane	µg/L	0.38	0.5	--	--
	lbs/day	0.0034	0.0045	--	--
Tetrachloroethene	µg/L	5.0	5.0		
	lbs/day	0.046	0.046		
Perchlorate	µg/L	4, 6 ²	6	--	--
	lbs/day	0.036, 0.055	0.055	--	--
pH	standard units	--	--	6.5	8.5

¹ All volatile organic constituents listed in EPA Methods 8010/8020 or 8260. The concentration of each constituent shall not exceed 0.5 µg/L, except for those constituents that have a specific limit in the table.

² When perchlorate treatment system is being used the monthly average limitation is 4 µg/L. When no treatment system is being used the monthly average is 6 µg/L.

- ii. Survival of aquatic organisms in 96-hour bioassays shall be no less than 70% for any one bioassay and 90% for the median of any three or more consecutive bioassays.

n. Discharge Point 014

- i. The discharge of effluent from the Golden State’s water well AC-18 facilities shall maintain compliance with the following effluent limitations at Discharge Point 014, with compliance measured at Monitoring Locations M-014, as described in the attached Monitoring and Reporting Program (Attachment E):

Parameter	Units	Effluent Limitations			
		Average Monthly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
Flow – Discharge 014	mgd	2.59	2.59	--	--
Volatile Organic Contaminants ¹	µg/L	0.5	0.7	--	--
	lbs/day	0.011	0.015	--	--
1,2-Dichloroethane	µg/L	0.38	0.5	--	--
	lbs/day	0.0082	0.011	--	--
Perchlorate	µg/L	4, 6 ²	6	--	--
	lbs/day	0.086, 0.12	0.12	--	--
pH	standard units	--	--	6.5	8.5

¹ All volatile organic constituents listed in EPA Methods 8010/8020 or 8260. The concentration of each constituent shall not exceed 0.5 µg/L, except for those constituents that have a specific limit in the table.

² When perchlorate treatment system is being used the monthly average limitation is 4 µg/L. When no treatment system is being used the monthly average is 6 µg/L.

- ii. Survival of aquatic organisms in 96-hour bioassays shall be no less than 70% for any one bioassay and 90% for the median of any three or more consecutive bioassays.

o. Discharge Point 015

- i. The discharge of effluent from the Golden State’s water well AC-23 facilities shall maintain compliance with the following effluent limitations at Discharge Point 015, with compliance measured at Monitoring Locations M-015, as described in the attached Monitoring and Reporting Program (Attachment E):

Parameter	Units	Effluent Limitations			
		Average Monthly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
Flow – Discharge 015	mgd	3.17	3.17	--	--
Volatile Organic Contaminants ¹	µg/L	0.5	0.7	--	--
	lbs/day	0.013	0.018	--	--
1,2-Dichloroethane	µg/L	0.38	0.5	--	--

Parameter	Units	Effluent Limitations			
		Average Monthly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
Perchlorate	lbs/day	0.010	0.013	--	--
	µg/L	4, 6 ²	6	--	--
	lbs/day	0.11, 0.16	0.16	--	--
pH	standard units	--	--	6.5	8.5

¹ All volatile organic constituents listed in EPA Methods 8010/8020 or 8260. The concentration of each constituent shall not exceed 0.5 µg/L, except for those constituents that have a specific limit in the table.

² When perchlorate treatment system is being used the monthly average limitation is 4 µg/L. When no treatment system is being used the monthly average is 6 µg/L.

- ii. Survival of aquatic organisms in 96-hour bioassays shall be no less than 70% for any one bioassay and 90% for the median of any three or more consecutive bioassays.

2. Interim Effluent Limitations

- a. **Effective immediately and ending on 1 December 2013, or until the treatment system to remove perchlorate at the ARGET facility is constructed, whichever is sooner**, the discharge of treated effluent from the ARGET facility shall maintain compliance with the following effluent limitation for perchlorate at Discharge Point 001, as described in the attached Monitoring and Reporting Program (Attachment E). This interim effluent limitation shall apply in lieu of the corresponding final effluent limitation for perchlorate specified during the time period indicated in this Order.

Parameter	Units	Effluent Limitations			
		Average Monthly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
perchlorate	µg/L	8	8	--	--

B. Land Discharge Specifications – Not Applicable

C. Reclamation Specifications – Not Applicable

V. RECEIVING WATER LIMITATIONS

A. Surface Water Limitations

Receiving surface water limitations are based on water quality objectives contained in the Basin Plan and are a required part of this Order. The discharge shall not cause the following in Alder Creek, Buffalo Creek, Morrison Creek, and the American River:

1. **Bacteria:** The fecal coliform concentration based on a minimum of not less than five samples for any 30-day period shall not exceed a geometric mean of 200/100 ml, nor shall more than ten percent of the total number of samples taken during any 30-day period exceed 400/100 ml.
2. **Dissolved Oxygen:** The monthly median of the mean daily dissolved oxygen (DO) concentration shall not fall below 85 percent of saturation in the main water mass, and the 95 percentile concentration shall not fall below 75 percent of saturation. The DO concentration shall not be reduced below 7.0 mg/L at any time.
3. **Oil and Grease:** Oils, greases, waxes, or other materials in concentrations that cause nuisance, result in a visible film or coating on the water surface or on objects in the water, or otherwise adversely affect beneficial uses.
4. **Color:** Discoloration that causes nuisance or adversely affects beneficial uses.
5. **pH:** The ambient pH to be depressed below 6.5, nor raised above 8.5, nor changes in normal ambient pH levels to be exceeded by more than 0.5 units. A monthly averaging period may be used for determining compliance with the above 0.5 receiving water pH limitation.
6. **Temperature:** The natural receiving water temperature to increase more than 5°F.
7. **Settleable Matter:** Substances in concentrations that result in the deposition of material that causes nuisance or adversely affects beneficial uses.
8. **Radioactivity:**
 - a. Radionuclides to be present in concentrations that are harmful to human, plant, animal or aquatic life nor that result in the accumulation of radionuclides in the food web to an extent that presents a hazard to human, plant, animal or aquatic life.
 - b. Concentrations of radionuclides in excess of the maximum contaminant levels (MCLs) specified in Table 4 (MCL Radioactivity) of Section 64443 of Title 22 of the California Code of Regulations.
9. **Toxicity:** Toxic substances in concentrations that produce detrimental physiological responses in human, plant, animal, or aquatic life. This applies regardless of whether the toxicity is caused by a single substance or the interactive effect of multiple substances.
10. **Biostimulatory Substances:** Biostimulatory substances which promote aquatic growths in concentrations that cause nuisance or adversely affect beneficial uses.

11. Floating Material: Floating material in amounts that cause nuisance or adversely affect beneficial uses.
12. Sediment: Suspended sediment load and suspended sediment discharge rate altered in such a manner to cause nuisance or adversely affect beneficial uses.
13. Suspended Sediment: Suspended sediment concentrations that cause nuisance or adversely affect beneficial uses.
14. Taste and Order: Taste- or odor-producing substances in concentrations that cause nuisance, adversely affect beneficial uses, or impart undesirable tastes or odors to fish flesh or other edible products of aquatic origin or to domestic or municipal water supplies.
15. Turbidity: Changes in turbidity that cause nuisance or adversely affect beneficial uses. Turbidity attributable to controllable water quality factors to exceed the following:
 - a. More than 1 Nephelometric Turbidity Units (NTUs) where natural turbidity is between 0 and 5 NTUs.
 - b. More than 20 percent where natural turbidity is between 5 and 50 NTUs.
 - c. More than 10 NTUs where natural turbidity is between 50 and 100 NTUs.
 - d. More than 10 percent where natural turbidity is greater than 100 NTUs.
16. Pesticides:
 - a. Pesticides in individual or combined concentrations that adversely affect beneficial uses.
 - b. Pesticide concentrations in bottom sediments or aquatic life that adversely affect beneficial uses.
 - c. Total identifiable persistent chlorinated hydrocarbon pesticides in concentrations detectable within the accuracy of analytical methods approved by the Environmental Protection Agency or the Executive Officer.
 - d. Concentrations exceeding those allowable by applicable antidegradation policies (see State Water Resources Control Board Resolution No. 68-16 and 40 C.F.R. Section 131.12.)
 - e. Concentrations exceeding the lowest levels technically and economically achievable.

- f. Concentrations exceeding the Maximum Contaminant Levels set forth in California Code of Regulations, Title 22, Division 4, Chapter 15.
 - g. Concentrations of thiobencarb in excess of 1.0 mg/L.
17. Aquatic communities and populations, including vertebrate, invertebrate, and plant species, to be degraded.

B. Groundwater Limitations – Not Applicable

VI. PROVISIONS

A. Standard Provisions

1. **Federal Standard Provisions.** The Discharger shall comply with all Standard Provisions included in Attachment D of this Order.
2. **Regional Water Board Standard Provisions.** The Discharger shall comply with the following provisions:
 - a. If the Discharger’s wastewater treatment plant is publicly owned or subject to regulation by the California Public Utilities Commission, it shall be supervised and operated by persons possessing certificates of appropriate grade according to Title 23, California Code of Regulations (CCR), Division 3, Chapter 14.
 - b. After notice and opportunity for a hearing, this Order may be terminated or modified for cause, including, but not limited to:
 - i. Violation of any term or condition contained in this Order;
 - ii. Obtaining this Order by misrepresentation or by failing to disclose fully all relevant facts;
 - iii. A change in any condition that requires either a temporary or permanent reduction or elimination of the authorized discharge; and
 - iv. A material change in the character, location, or volume of discharge.

The causes for modification include:

- i. **New regulations.** New regulations have been promulgated under Section 405(d) of the Clean Water Act, or the standards or regulations on which the permit was based have been changed by promulgation of amended standards or regulations or by judicial decision after the permit was issued.
- ii. **Land application plans.** When required by a permit condition to incorporate a land application plan for beneficial reuse of sewage sludge,

to revise an existing land application plan, or to add a land application plan.

- iii. **Change in sludge use or disposal practice.** Under 40 Code of Federal Regulations (CFR) 122.62(a)(1), a change in the Discharger's sludge use or disposal practice is a cause for modification of the permit. It is cause for revocation and reissuance if the Discharger requests or agrees.

The Regional Water Board may review and revise this Order at any time upon application of any affected person or the Regional Water Board's own motion.

- c. If a toxic effluent standard or prohibition (including any scheduled compliance specified in such effluent standard or prohibition) is established under Section 307(a) of the CWA, or amendments thereto, for a toxic pollutant that is present in the discharge authorized herein, and such standard or prohibition is more stringent than any limitation upon such pollutant in this Order, the Regional Water Board will revise or modify this Order in accordance with such toxic effluent standard or prohibition.

The Discharger shall comply with effluent standards and prohibitions within the time provided in the regulations that establish those standards or prohibitions, even if this Order has not yet been modified.

- d. This Order shall be modified, or alternately revoked and reissued, to comply with any applicable effluent standard or limitation issued or approved under Sections 301(b)(2)(C) and (D), 04(b)(2), and 307(a)(2) of the CWA, if the effluent standard or limitation so issued or approved:
 - i. Contains different conditions or is otherwise more stringent than any effluent limitation in the Order; or
 - ii. Controls any pollutant limited in the Order.

The Order, as modified or reissued under this paragraph, shall also contain any other requirements of the CWA then applicable.

- e. The provisions of this Order are severable. If any provision of this Order is found invalid, the remainder of this Order shall not be affected.
- f. The Discharger shall take all reasonable steps to minimize any adverse effects to waters of the State or users of those waters resulting from any discharge or sludge use or disposal in violation of this Order. Reasonable steps shall include such accelerated or additional monitoring as necessary to determine the nature and impact of the non-complying discharge or sludge use or disposal.

- g. The Discharger shall ensure compliance with any existing or future pretreatment standard promulgated by USEPA under Section 307 of the CWA, or amendment thereto, for any discharge to the municipal system.
- h. The discharge of any radiological, chemical or biological warfare agent or high-level, radiological waste is prohibited.
- i. A copy of this Order shall be maintained at the discharge facility and be available at all times to operating personnel. Key operating personnel shall be familiar with its content.
- j. Safeguard to electric power failure:
 - i. The Discharger shall provide safeguards to assure that, should there be reduction, loss, failure of electric power, the discharge shall comply with the terms and conditions of this Order.
 - ii. Upon written request by the Regional Water Board the Discharger shall submit a written description of safeguards. Such safeguards may include alternate power sources, standby generators, retention capacity, operating procedures, or other means. A description of the safeguards provided shall include an analysis of the frequency, duration, and impact of power failures experienced over the past five years on effluent quality and on the capability of the Discharger to comply with the terms and conditions of the Order. The adequacy of the safeguards is subject to the approval of the Regional Water Board.
 - iii. Should the treatment works not include safeguards against reduction, loss, or failure of electric power, or should the Regional Water Board not approve the existing safeguards, the Discharger shall, within ninety days of having been advised in writing by the Regional Water Board that the existing safeguards are inadequate, provide to the Regional Water Board and USEPA a schedule of compliance for providing safeguards such that in the event of reduction, loss, or failure of electric power, the Discharger shall comply with the terms and conditions of this Order. The schedule of compliance shall, upon approval of the Regional Water Board, become a condition of this Order.
- k. The Discharger, upon written request of the Regional Water Board, shall file with the Regional Water Board a technical report on its preventive (failsafe) and contingency (cleanup) plans for controlling accidental discharges, and for minimizing the effect of such events.

The technical report shall:

- i. Identify the possible sources of spills, leaks, untreated waste by-pass, and contaminated drainage. Loading and storage areas, power outage, waste treatment unit outage, and failure of process equipment, tanks and pipes should be considered.
- ii. Evaluate the effectiveness of present facilities and procedures and state when they became operational.
- iii. Predict the effectiveness of the proposed facilities and procedures and provide an implementation schedule containing interim and final dates when they will be constructed, implemented, or operational.

The Regional Water Board, after review of the technical report, may establish conditions, which it deems necessary to control accidental discharges and to minimize the effects of such events. Such conditions shall be incorporated as part of this Order, upon notice to the Discharger.

- I. A publicly owned treatment works (POTW) whose waste flow has been increasing, or is projected to increase, shall estimate when flows will reach hydraulic and treatment capacities of its treatment and disposal facilities. The projections shall be made in January, based on the last three years' average dry weather flows, peak wet weather flows and total annual flows, as appropriate. When any projection shows that capacity of any part of the facilities may be exceeded in four years, the Discharger shall notify the Regional Water Board by **31 January**. A copy of the notification shall be sent to appropriate local elected officials, local permitting agencies and the press. Within 120 days of the notification, the Discharger shall submit a technical report showing how it will prevent flow volumes from exceeding capacity or how it will increase capacity to handle the larger flows. The Regional Water Board may extend the time for submitting the report.
- m. Chemical, bacteriological, and bioassay analyses shall be conducted at a laboratory certified for such analyses by the State Department of Health Services. In the event a certified laboratory is not available to the Discharger, analyses performed by a noncertified laboratory will be accepted provided a Quality Assurance-Quality Control Program is instituted by the laboratory. A manual containing the steps followed in this program must be kept in the laboratory and shall be available for inspection by Regional Water Board staff. The Quality Assurance-Quality Control Program must conform to USEPA guidelines or to procedures approved by the Regional Water Board.
 - i. Unless otherwise specified, all metals shall be reported as Total Metals.
 - ii. Acute bioassays shall be performed in accordance with guidelines approved by the Regional Water Board and the Department of Fish and Game or in accordance with methods described in USEPA's manual for

measuring acute toxicity of effluents (EPA-821-R-02-012 and subsequent amendments).

- iii. Short-term chronic bioassays shall be performed in accordance with USEPA guidelines (EPA-821-R-02-013 and subsequent amendments).
- n. Laboratories that perform sample analyses must be identified in all monitoring reports submitted to the Regional Water Board and USEPA.
- o. The Discharger shall conduct analysis on any sample provided by USEPA as part of the Discharge Monitoring Quality Assurance (DMQA) program. The results of any such analysis shall be submitted to USEPA's DMQA manager.
- p. The Discharger shall submit technical reports as directed by the Executive Officer. All technical reports required herein that involve planning, investigation, evaluation, or design, or other work requiring interpretation and proper application of engineering or geologic sciences, shall be prepared by or under the direction of persons registered to practice in California pursuant to California Business and Professions Code, Sections 6735, 7835, and 7835.1. To demonstrate compliance with Title 16, CCR, Sections 415 and 3065, all technical reports must contain a statement of the qualifications of the responsible registered professional(s). As required by these laws, completed technical reports must bear the signature(s) and seal(s) of the registered professional(s) in a manner such that all work can be clearly attributed to the professional responsible for the work.
- q. The Discharger shall take all reasonable steps to minimize any adverse effects to waters of the State or users of those waters resulting from any discharge or sludge use or disposal in violation of this Order. Reasonable steps shall include such accelerated or additional monitoring as necessary to determine the nature and impact of the non-complying discharge or sludge use or disposal.
- r. The Regional Water Board is authorized to enforce the terms of this permit under several provisions of the CWC, including, but not limited to, sections 13385, 13386, and 13387.

B. Monitoring and Reporting Program Requirements

The discharger shall comply with the Monitoring and Reporting Program, and future revisions thereto, in Attachment E of this Order.

C. Special Provisions

1. Reopener Provisions

- a. If more stringent applicable water quality standards are promulgated or approved pursuant to Section 303 of the Federal Water Pollution Control Act or amendments thereto, the Regional Water Board will revise and modify this Order in accordance with such more stringent standards.
- b. If after review of effluent monitoring results it is determined that the discharge has reasonable potential to cause or contribute to an exceedance of a water quality objective, or the discharge is causing groundwater degradation, this Order may be reopened and effluent limitations added for the subject constituents.
- c. The Discharger may request the Executive Officer to reopen the permit to request a reduction in monitoring, if appropriate.

2. Special Studies, Technical Reports and Additional Monitoring Requirements

- a. **Chronic Whole Effluent Toxicity Requirements.** For compliance with the Basin Plan's narrative toxicity objective, this Order requires the Discharger to conduct chronic whole effluent toxicity testing, as specified in the Monitoring and Reporting Program ([Attachment E](#)). Furthermore, this Provision requires the Discharger to investigate the causes of, and identify corrective actions to reduce or eliminate effluent toxicity. If the discharge exceeds numeric toxicity trigger levels established in this Provision, the Discharger is required to initiate a Toxicity Reduction Evaluation (TRE), in accordance with an approved TRE Work Plan, and take actions to mitigate the impact of the discharge and prevent recurrence of the toxicity. A TRE is a site-specific study conducted in a stepwise process to identify source(s) of toxicity and the effective control measures for effluent toxicity. TREs are designed to identify the causative agents of whole effluent toxicity, evaluate the effectiveness of the toxicity control options, and confirm the reduction in effluent toxicity. This Provision includes the requirements for the Discharger to develop and submit a TRE Work Plan and also the procedures for accelerated chronic toxicity monitoring and TRE initiation.
 - (i) **Toxicity Reduction Evaluation (TRE) Work Plan.** Within 90 days of the effective date of this Order, the Discharger shall submit to the Regional Water Board a TRE Work Plan for approval by the Executive Officer. The TRE Work Plan shall outline the procedures for identifying the source(s) of, and reducing or eliminating effluent toxicity. The TRE Work Plan shall be developed in accordance with EPA guidance and shall contain adequate detail to allow the Discharger to immediately implement a TRE as required in this Provision.

- (ii) **Numeric Toxicity Trigger.** The numeric toxicity trigger is 1 TUc^2 for any test species. The numeric toxicity trigger is not an effluent limitation, it is the toxicity threshold at which the Discharger is required to perform accelerated chronic toxicity monitoring to confirm effluent toxicity, as well as, the threshold to initiate a TRE. The accelerated monitoring specifications are described in subsection (iv), below.
- (iii) **Accelerated Monitoring and TRE Initiation.** When the numeric toxicity trigger is exceeded during regular chronic toxicity monitoring, and the testing meets all test acceptability criteria, the Discharger shall initiate accelerated monitoring to confirm the effluent toxicity as required in the Accelerated Monitoring Specifications outlined in subsection iv, below. Any exceedance of the TRE Trigger during accelerated monitoring requires the Discharger to initiate a TRE in accordance with an approved TRE Work Plan. Notwithstanding the accelerated monitoring results, if there is adequate evidence of effluent toxicity, the Executive Officer may require that the Discharger initiate a TRE.
- (a) In the event the numeric toxicity trigger is exceeded during accelerated monitoring, specific actions the Discharger will take to investigate and identify the cause(s) of toxicity;
- (b) In the event the numeric toxicity trigger is exceeded during accelerated monitoring, specific actions the Discharger will take to mitigate the impact of the discharge and prevent the recurrence of toxicity; and
- (c) A schedule for these actions.
- (iv) **Accelerated Monitoring Specifications.** If the TRE Trigger is exceeded during regular chronic toxicity testing, within 14-days of notification by the laboratory of the exceedance, the Discharger shall initiate accelerated monitoring to confirm effluent toxicity. Accelerated monitoring shall consist of three (3) monthly chronic toxicity tests using the species that exhibited toxicity. The following protocol shall be used for accelerated monitoring and TRE initiation:
- (a) If the results of three (3) consecutive accelerated monitoring tests do not exceed the TRE Trigger, the Discharger may cease accelerated monitoring and resume regular chronic toxicity monitoring. Notwithstanding the accelerated monitoring results, if there is adequate evidence of effluent toxicity, the Executive Officer may require that the Discharger initiate a TRE.

¹ See [Attachment F \(Fact Sheet\) Section VII.B.2.a.](#) for a list of EPA guidance documents that must be considered in development of the TRE Work Plan.

² TUc – Chronic toxicity unit. The reciprocal of the effluent concentration that causes no observable effect on the test organism in a chronic toxicity test (TUc=100/NOEC)

- (b) If the source(s) of the toxicity is easily identified (i.e. temporary plant upset), the Discharger shall make necessary corrections to the facility and shall continue accelerated monitoring until three (3) consecutive accelerated tests do not exceed the TRE Trigger. Upon confirmation that the effluent toxicity has been removed, the Discharger may cease accelerated monitoring and resume regular chronic toxicity monitoring.
 - (c) If the result of any accelerated toxicity test exceeds the TRE Trigger, the Discharger shall cease accelerated monitoring and begin a TRE to investigate the cause(s) of, and identify corrective actions to reduce or eliminate effluent toxicity. Within thirty (30) days of notification by the laboratory of the exceedance of the TRE Trigger during accelerated monitoring, the Discharger shall submit a TRE Action Plan to the Regional Water Board including, at minimum:
 - 1. Specific actions the Discharger will take to investigate and identify the cause(s) of toxicity, including TRE WET monitoring schedule;
 - 2. Specific actions the Discharger will take to mitigate the impact of the discharge and prevent the recurrence of toxicity; and
 - 3. A schedule for these actions.
- b. **Thermal Impacts Associated with Discharge to Outfall 008 or 009.** The Discharger is not permitted to discharge to Outfall 008 and/or 009 until an adequate thermal impact assessment is completed for Outfall 008 and/or 009 that demonstrates that the discharge will not cause an unacceptable thermal impact on the receiving water. The study must demonstrate that the discharge will meet the Water Quality Objectives for temperature found in the Basin Plan. Those objectives state “the natural receiving water temperature of intrastate waters shall not be altered unless it can be demonstrated to the satisfaction of the Regional Water Board that such alteration in temperature does not affect beneficial uses” and “at no time or place shall the temperature of COLD or WARM intrastate waters be increased more than 5°F above the natural receiving water temperature”.
- c. **Evaluation of Treatment Options for Discharge from AC-18 and AC-23.** As the discharges from these two water supply wells are not through the treatment plant, these low-threat, low-volume discharges from these two systems fall under Discharge Point 12 with an perchlorate effluent limitation of 12 µg/L. As the perchlorate concentration in the extracted groundwater has the potential to increase over time, when the effluent from the well is above 8 µg/L perchlorate for two consecutive months, the Discharger is required to submit a plan, within 90-days following the second month of exceedance, to assure the discharge from the well will be compliant with the perchlorate effluent limitation. The plan shall be executed upon approval by Regional Board staff.

3. Best Management Practices and Pollution Prevention – Not Applicable

4. Compliance Schedules

a. Final Effluent Limitations for Perchlorate at Discharge 001

- i. If the effluent from the GET D system is added to ARGET and the total influent perchlorate concentration into ARGET is greater than 6 µg/L, then by **1 December 2013** the Discharger shall provide treatment equipment at the ARGET facility to remove perchlorate to less than 4 µg/L, the AMEL found in IV(A)(1)(a).

5. Construction, Operation and Maintenance Specifications

a. Operations and Maintenance Plan:

Within 60-days of startup of a GET, the Discharger shall certify in writing to the Regional Water Board that it has developed an Operation and Maintenance Plan (O&M). O&M plans have already developed for GET E/F, ARGET, Interim GET H and GET J under previous versions of the permit. The Discharger shall develop and implement the O&M plan to prevent or minimize the generation and discharge of wastes and pollutants to the waters of the United States and waters of the State. The Discharger shall develop and implement an O&M plan consistent with the following objectives:

i. Operations and Maintenance

- 1) Maintain in-system production and wastewater treatment technologies to prevent the overflow of any floating matter or bypassing of treatment technologies.
- 2) Inspect the treatment systems on a routine basis in order to identify and promptly repair any damage.
- 3) Ensure storage and containment of chemicals or other materials to prevent spillage or release into waters of the United States, or waters of the State.
- 4) Implement procedures for properly containing, cleaning, and disposing of any spilled material.

ii. Recordkeeping

- 1) Keep records documenting the frequency of cleaning, inspections, maintenance and repairs.

v. Training

- 1) Adequately train all relevant facility personnel in spill prevention and how to respond in the event of a spill in order to ensure the proper clean-up and disposal of spilled material.
- 2) Train staff on the proper operation and cleaning of production and wastewater treatment systems, including training in feeding procedures and proper use of equipment.

The Discharger shall ensure that its operations staff are familiar with the O&M Plan and have been adequately trained in the specific procedures it requires.

b. Solids disposal specifications:

- i. Collected screenings, sludges, and other solids, shall be disposed of in a manner approved by the Executive Officer and consistent *with Consolidated Regulations for Treatment, Storage, Processing, or Disposal of Solid Waste*, as set forth in Title 27, CCR, Division 2, Subdivision 1, Section 20005, et seq.
- ii. Any proposed change in solids disposal from a previously approved practice (as described in this Order) shall be reported to this office at least 90 days in advance of the change.

6. Special Provisions for Municipal Facilities (POTWs Only) – Not Applicable

7. Other Special Provisions

- a. Prior to making any change in the discharge point, place of use, or purpose of use of the wastewater, the Discharger shall obtain approval of, or clearance from the State Water Resources Control Board (Division of Water Rights).
- b. In the event of any change in control or ownership of land or waste discharge facilities presently owned or controlled by the Discharger, the Discharger shall notify the succeeding owner or operator of the existence of this Order by letter, a copy of which shall be immediately forwarded to this office.

To assume operation under this Order, the succeeding owner or operator must apply in writing to the Executive Officer requesting transfer of the Order. The request must contain the requesting entity's full legal name, the State of incorporation if a corporation, address and telephone number of the persons responsible for contact with the Regional Water Board and a statement. The statement shall comply with the signatory paragraph of Standard Provision V.B, Attachment D, and state that the new owner or operator assumes full responsibility for compliance with this Order. Failure to submit the request shall be considered a discharge without requirements, a violation of the California

Water Code. Transfer shall be approved or disapproved in writing by the Executive Officer.

- c. In the event the Discharger does not comply or will be unable to comply for any reason, with any prohibition or limitation contained in this Order, the Discharger shall notify the Regional Water Board by telephone (916) 464-3291 within 24 hours of having knowledge of such noncompliance, and shall confirm this notification in writing within five days, unless the Regional Water Board waives confirmation. The written notification shall include the information required by [Federal Standard Provision V.E.1](#) [40 CFR §122.41(l)(6)(i)].

VII. COMPLIANCE DETERMINATION

Compliance with the effluent limitations contained in Section IV of this Order will be determined as specified below:

A. Average Monthly Effluent Limitation (AMEL).

If the average of daily discharges over a calendar month exceeds the AMEL for a given parameter, an alleged violation will be flagged and the discharger will be considered out of compliance for each day of that month for that parameter (e.g., resulting in 31 days of non-compliance in a 31-day month). The average of daily discharges over the calendar month that exceeds the AMEL for a parameter will be considered out of compliance for that month only. If only a single sample is taken during the calendar month and the analytical result for that sample exceeds the AMEL, the discharger will be considered out of compliance for that calendar month. For any one calendar month during which no sample (daily discharge) is taken, no compliance determination can be made for that calendar month. For NDMA and 1,4-dioxane, if the approved Practical Quantitation Level (PQL) is greater than the AMEL, then compliance is met if the monthly average is less than the PQL.

B. Maximum Daily Effluent Limitation (MDEL).

If a daily discharge exceeds the MDEL for a given parameter, an alleged violation will be flagged and the discharger will be considered out of compliance for that parameter for that 1 day only within the reporting period. For any 1 day during which no sample is taken, no compliance determination can be made for that day. For NDMA and 1,4-dioxane, if the approved Practical Quantitation Level (PQL) is greater than the MDEL, then compliance is met if the daily value is less than the PQL.

C. Instantaneous Minimum Effluent Limitation.

If the analytical result of a single grab sample is lower than the instantaneous minimum effluent limitation for a parameter, a violation will be flagged and the discharger will be considered out of compliance for that parameter for that single sample. Non-compliance for each sample will be considered separately (e.g., the results of two grab samples taken within a calendar day that both are lower than the instantaneous minimum effluent limitation would result in two instances of non-compliance with the instantaneous minimum effluent limitation).

D. Instantaneous Maximum Effluent Limitation.

If the analytical result of a single grab sample is higher than the instantaneous maximum effluent limitation for a parameter, a violation will be flagged and the discharger will be considered out of compliance for that parameter for that single sample. Non-compliance for each sample will be considered separately (e.g., the results of two grab samples taken within a calendar day that both exceed the instantaneous maximum effluent limitation would result in two instances of non-compliance with the instantaneous maximum effluent limitation).

E. Maximum 1-Hour Average.

If the analytical result of a samples collected within 1-hour are higher than the maximum 1-hour average effluent limitation for a parameter, a violation will be flagged and the discharger will be considered out of compliance for that parameter.

ATTACHMENT A – DEFINITIONS

Average Monthly Effluent Limitation (AMEL): the highest allowable average of daily discharges over a calendar month, calculated as the sum of all daily discharges measured during a calendar month divided by the number of daily discharges measured during that month.

Average Weekly Effluent Limitation (AWEL): the highest allowable average of daily discharges over a calendar week (Sunday through Saturday), calculated as the sum of all daily discharges measured during a calendar week divided by the number of daily discharges measured during that week.

Daily Discharge: Daily Discharge is defined as either: (1) the total mass of the constituent discharged over the calendar day (12:00 am through 11:59 pm) or any 24-hour period that reasonably represents a calendar day for purposes of sampling (as specified in the permit), for a constituent with limitations expressed in units of mass or; (2) the unweighted arithmetic mean measurement of the constituent over the day for a constituent with limitations expressed in other units of measurement (e.g., concentration).

The daily discharge may be determined by the analytical results of a composite sample taken over the course of one day (a calendar day or other 24-hour period defined as a day) or by the arithmetic mean of analytical results from one or more grab samples taken over the course of the day.


For composite sampling, if 1 day is defined as a 24-hour period other than a calendar day, the analytical result for the 24-hour period will be considered as the result for the calendar day in which the 24-hour period ends.

Instantaneous Maximum Effluent Limitation: the highest allowable value for any single grab sample or aliquot (i.e., each grab sample or aliquot is independently compared to the instantaneous maximum limitation).


Instantaneous Minimum Effluent Limitation: the lowest allowable value for any single grab sample or aliquot (i.e., each grab sample or aliquot is independently compared to the instantaneous minimum limitation).


Maximum Daily Effluent Limitation (MDEL): the highest allowable daily discharge of a pollutant.

Attachment B-1 - Discharge and GET Locations




Attachment B-2 - Receiving Water Sample Locations






Attachment C-1 ARGFT Treatment System




Attachment C-2 GET E/F Treatment System

Attachment C-4


GBT H Treatment System



SEQUENCE OF OPERATION	
PLANT PROCESS	DIRECTION OF FLOW
MODE 1	INFLUENT → UV REACTORS → BOOSTER PUMP → 0M VESSELS → OMC VESSELS → OMC FILTERS → EFFLUENT
MODE 2	INFLUENT → BOOSTER PUMP → 0M VESSELS → UV REACTORS → OMC VESSELS → EFFLUENT





Attachment C-5 GFT J Treatment System



Attachment C-7

GET K-A Treatment System



Attachment C-9

GFT I-B Treatment System

ATTACHMENT D – FEDERAL STANDARD PROVISIONS

I. STANDARD PROVISIONS – PERMIT COMPLIANCE

A. Duty to Comply

1. The Discharger must comply with all of the conditions of this Order. Any noncompliance constitutes a violation of the Clean Water Act (CWA) and the California Water Code (CWC) and is grounds for enforcement action, for permit termination, revocation and reissuance, or denial of a permit renewal application [40 CFR §122.41(a)].
2. The Discharger shall comply with effluent standards or prohibitions established under Section 307(a) of the Clean Water Act for toxic pollutants and with standards for sewage sludge use or disposal established under Section 405(d) of the CWA within the time provided in the regulations that establish these standards or prohibitions, even if this Order has not been modified to incorporate the requirement [40 CFR §122.41(a)(1)].

B. Need to Halt or Reduce Activity Not a Defense

It shall not be a defense for a Discharger in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this Order [40 CFR §122.41(c)].

C. Duty to Mitigate

The Discharger shall take all reasonable steps to minimize or prevent any discharge or sludge use or disposal in violation of this Order that has a reasonable likelihood of adversely affecting human health or the environment [40 CFR §122.41(d)].

D. Proper Operation and Maintenance

The Discharger shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the Discharger to achieve compliance with the conditions of this Order. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of backup or auxiliary facilities or similar systems that are installed by a Discharger only when necessary to achieve compliance with the conditions of this Order [40 CFR §122.41(e)].

E. Property Rights

1. This Order does not convey any property rights of any sort or any exclusive privileges [40 CFR §122.41(g)].
2. The issuance of this Order does not authorize any injury to persons or property or invasion of other private rights, or any infringement of State or local law or regulations [40 CFR §122.5(c)].

F. Inspection and Entry

The Discharger shall allow the Regional Water Quality Control Board (RWQCB), State Water Resources Control Board (SWRCB), United States Environmental Protection Agency (USEPA), and/or their authorized representatives (including an authorized contractor acting as their representative), upon the presentation of credentials and other documents, as may be required by law, to [40 CFR §122.41(i)] [CWC 13383(c)]:

1. Enter upon the Discharger's premises where a regulated facility or activity is located or conducted, or where records are kept under the conditions of this Order [40 CFR §122.41(i)(1)];
2. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this Order [40 CFR §122.41(i)(2)];
3. Inspect and photograph, at reasonable times, any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this Order [40 CFR §122.41(i)(3)];
4. Sample or monitor, at reasonable times, for the purposes of assuring Order compliance or as otherwise authorized by the CWA or the CWC, any substances or parameters at any location [40 CFR §122.41(i)(4)].

G. Bypass

1. Definitions
 - a. "Bypass" means the intentional diversion of waste streams from any portion of a treatment facility [40 CFR §122.41(m)(1)(i)].
 - b. "Severe property damage" means substantial physical damage to property, damage to the treatment facilities, which causes them to become inoperable, or substantial and permanent loss of natural resources that can reasonably be expected to occur in the absence of a bypass. Severe property damage does

not mean economic loss caused by delays in production [40 CFR §122.41(m)(1)(ii)].

2. Bypass not exceeding limitations – The Discharger may allow any bypass to occur which does not cause exceedances of effluent limitations, but only if it is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions listed in Standard Provisions – Permit Compliance I.G.3 and I.G.5 below [40 CFR §122.41(m)(2)].
3. Prohibition of bypass – Bypass is prohibited, and the Regional Water Board may take enforcement action against a Discharger for bypass, unless [40 CFR §122.41(m)(4)(i)]:
 - a. Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage [40 CFR §122.41(m)(4)(A)];
 - b. There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass that occurred during normal periods of equipment downtime or preventive maintenance [40 CFR §122.41(m)(4)(B)]; and
 - c. The Discharger submitted notice to the Regional Water Board as required under Standard Provision – Permit Compliance I.G.5 below [40 CFR §122.41(m)(4)(C)].
4. The Regional Water Board may approve an anticipated bypass, after considering its adverse effects, if the Regional Water Board determines that it will meet the three conditions listed in Standard Provisions – Permit Compliance I.G.3 above [40 CFR §122.41(m)(4)(ii)].
5. Notice
 - a. Anticipated bypass. If the Discharger knows in advance of the need for a bypass, it shall submit a notice, if possible at least 10 days before the date of the bypass [40 CFR §122.41(m)(3)(i)].
 - b. Unanticipated bypass. The Discharger shall submit notice of an unanticipated bypass as required in Standard Provisions - Reporting V.E below [40 CFR §122.41(m)(3)(ii)].

H. Upset

Upset means an exceptional incident in which there is unintentional and temporary noncompliance with technology based permit effluent limitations because of factors beyond the reasonable control of the permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation [40 CFR §122.41(n)(1)].

1. Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with such technology based permit effluent limitations if the requirements of paragraph H.2 of this section are met. No determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review [40 CFR §122.41(n)(2)].
2. Conditions necessary for a demonstration of upset. A Discharger who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs or other relevant evidence that [40 CFR §122.41(n)(3)]:
 - a. An upset occurred and that the Discharger can identify the cause(s) of the upset [40 CFR §122.41(n)(3)(i)];
 - b. The permitted facility was, at the time, being properly operated [40 CFR §122.41(n)(3)(i)];
 - c. The Discharger submitted notice of the upset as required in Standard Provisions – Reporting V.E.2.b [40 CFR §122.41(n)(3)(iii)]; and
 - d. The Discharger complied with any remedial measures required under Standard Provisions – Permit Compliance I.C above [40 CFR §122.41(n)(3)(iv)].
3. Burden of proof. In any enforcement proceeding, the Discharger seeking to establish the occurrence of an upset has the burden of proof [40 CFR §122.41(n)(4)].

II. STANDARD PROVISIONS – PERMIT ACTION

A. General

This Order may be modified, revoked and reissued, or terminated for cause. The filing of a request by the Discharger for modification, revocation and reissuance, or

termination, or a notification of planned changes or anticipated noncompliance does not stay any Order condition [40 CFR §122.41(f)].

B. Duty to Reapply

If the Discharger wishes to continue an activity regulated by this Order after the expiration date of this Order, the Discharger must apply for and obtain a new permit [40 CFR §122.41(b)].

C. Transfers

This Order is not transferable to any person except after notice to the Regional Water Board. The Regional Water Board may require modification or revocation and reissuance of the Order to change the name of the Discharger and incorporate such other requirements as may be necessary under the CWA and the CWC [40 CFR §122.41(l)(3)] [40 CFR §122.61].

III. STANDARD PROVISIONS – MONITORING

- A.** Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity [40 CFR §122.41(j)(1)].
- B.** Monitoring results must be conducted according to test procedures under 40 CFR Part 136 or, in the case of sludge use or disposal, approved under 40 CFR Part 136 unless otherwise specified in 40 CFR Part 503 unless other test procedures have been specified in this Order [40 CFR §122.41(j)(4)] [40 CFR §122.44(i)(1)(iv)].

IV. STANDARD PROVISIONS – RECORDS

- A.** Except for records of monitoring information required by this Order related to the Discharger's sewage sludge use and disposal activities, which shall be retained for a period of at least five years (or longer as required by 40 CFR Part 503), the Discharger shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this Order, and records of all data used to complete the application for this Order, for a period of at least three (3) years from the date of the sample, measurement, report or application. This period may be extended by request of the Regional Water Board Executive Officer at any time [40 CFR §122.41(j)(2)].

B. Records of monitoring information shall include:

1. The date, exact place, and time of sampling or measurements [40 CFR §122.41(j)(3)(i)];

2. The individual(s) who performed the sampling or measurements [40 CFR §122.41(j)(3)(ii)];
3. The date(s) analyses were performed [40 CFR §122.41(j)(3)(iii)];
4. The individual(s) who performed the analyses [40 CFR §122.41(j)(3)(iv)];
5. The analytical techniques or methods used [40 CFR §122.41(j)(3)(v)]; and
6. The results of such analyses [40 CFR §122.41(j)(3)(vi)].

C. Claims of confidentiality for the following information will be denied [40 CFR §122.7(b)]:

1. The name and address of any permit applicant or Discharger [40 CFR §122.7(b)(1)]; and
2. Permit applications and attachments, permits and effluent data [40 CFR §122.7(b)(2)].

V. STANDARD PROVISIONS – REPORTING

A. Duty to Provide Information

The Discharger shall furnish to the Regional Water Board, SWRCB, or USEPA within a reasonable time, any information which the Regional Water Board, SWRCB, or USEPA may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this Order or to determine compliance with this Order. Upon request, the Discharger shall also furnish to the Regional Water Board, SWRCB, or USEPA copies of records required to be kept by this Order [40 CFR §122.41(h)] [CWC 13267].

B. Signatory and Certification Requirements

1. All applications, reports, or information submitted to the Regional Water Board, SWRCB, and/or USEPA shall be signed and certified in accordance with paragraph (2.) and (3.) of this provision [40 CFR §122.41(k)].
2. All permit applications shall be signed as follows:
 - a. For a corporation: By a responsible corporate officer. For the purpose of this section, a responsible corporate officer means: (i) A president, secretary, treasurer, or vice-president of the corporation in charge of a principal business function, or any other person who performs similar policy- or decision-making functions for the corporation, or (ii) the manager of one or more manufacturing,

- production, or operating facilities, provided, the manager is authorized to make management decisions which govern the operation of the regulated facility including having the explicit or implicit duty of making major capital investment recommendations, and initiating and directing other comprehensive measures to assure long term environmental compliance with environmental laws and regulations; the manager can ensure that the necessary systems are established or actions taken to gather complete and accurate information for permit application requirements; and where authority to sign documents has been assigned or delegated to the manager in accordance with corporate procedures [40 CFR §122.22(a)(1)];
- b. For a partnership or sole proprietorship: by a general partner or the proprietor, respectively [40 CFR §122.22(a)(2)]; or
 - c. For a municipality, State, federal, or other public agency: by either a principal executive officer or ranking elected official. For purposes of this provision, a principal executive officer of a federal agency includes: (i) the chief executive officer of the agency, or (ii) a senior executive officer having responsibility for the overall operations of a principal geographic unit of the agency (e.g., Regional Administrators of USEPA) [40 CFR §122.22(a)(3)].
3. All reports required by this Order and other information requested by the Regional Water Board, SWRCB, or USEPA shall be signed by a person described in paragraph (b) of this provision, or by a duly authorized representative of that person. A person is a duly authorized representative only if:
- a. The authorization is made in writing by a person described in paragraph (2.) of this provision [40 CFR §122.22(b)(1)];
 - b. The authorization specified either an individual or a position having responsibility for the overall operation of the regulated facility or activity such as the position of plant manager, operator of a well or a well field, superintendent, position of equivalent responsibility, or an individual or position having overall responsibility for environmental matters for the company (a duly authorized representative may thus be either a named individual or any individual occupying a named position) [40 CFR §122.22(b)(2)]; and
 - c. The written authorization is submitted to the Regional Water Board, SWRCB, or USEPA [40 CFR §122.22(b)(3)].
4. If an authorization under paragraph (3.) of this provision is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization satisfying the requirements of paragraph (3.) of this provision must be submitted to the Regional Water Board, SWRCB or USEPA

prior to or together with any reports, information, or applications, to be signed by an authorized representative [40 CFR §122.22(c)].

5. Any person signing a document under paragraph (2.) or (3.) of this provision shall make the following certification:

“I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations” [40 CFR §122.22(d)].

C. Monitoring Reports

1. Monitoring results shall be reported at the intervals specified in the Monitoring and Reporting Program in this Order [40 CFR §122.41(l)(4)].
2. Monitoring results must be reported on a Discharge Monitoring Report (DMR) form or forms provided or specified by the Regional Water Board or SWRCB for reporting results of monitoring of sludge use or disposal practices [40 CFR §122.41(l)(4)(i)].
3. If the Discharger monitors any pollutant more frequently than required by this Order using test procedures approved under 40 CFR Part 136 or, in the case of sludge use or disposal, approved under 40 CFR Part 136 unless otherwise specified in 40 CFR Part 503, or as specified in this Order, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the DMR or sludge reporting form specified by the Regional Water Board [40 CFR §122.41(l)(4)(ii)].
4. Calculations for all limitations, which require averaging of measurements, shall utilize an arithmetic mean unless otherwise specified in this Order [40 CFR §122.41(l)(4)(iii)].

D. Compliance Schedules

Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this Order, shall be submitted no later than 14 days following each schedule date [40 CFR §122.41(l)(5)].

E. Twenty-Four Hour Reporting

1. The Discharger shall report any noncompliance that may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the Discharger becomes aware of the circumstances. A written submission shall also be provided within five (5) days of the time the Discharger becomes aware of the circumstances. The written submission shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance [40 CFR §122.41(l)(6)(i)].
2. The following shall be included as information that must be reported within 24 hours under this paragraph [40 CFR §122.41(l)(6)(ii)]:
 - a. Any unanticipated bypass that exceeds any effluent limitation in this Order [40 CFR §122.41(l)(6)(ii)(A)].
 - b. Any upset that exceeds any effluent limitation in this Order [40 CFR §122.41(l)(6)(ii)(B)].
 - c. Violation of a maximum daily discharge limitation for any of the pollutants listed in this Order to be reported within 24 hours [40 CFR §122.41(l)(6)(ii)(C)].
3. The Regional Water Board may waive the above-required written report under this provision on a case-by-case basis if an oral report has been received within 24 hours [40 CFR §122.41(l)(6)(iii)].

F. Planned Changes

The Discharger shall give notice to the Regional Water Board as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is required under this provision only when [40 CFR §122.41(l)(1)]:

1. The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source in 40 CFR §122.29(b) [40 CFR §122.41(l)(1)(i)]; or
2. The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants which are subject neither to effluent limitations in this Order nor to notification requirements under 40 CFR Part 122.42(a)(1) (see Additional Provisions—Notification Levels VII.A.1) [40 CFR §122.41(l)(1)(ii)].

3. The alteration or addition results in a significant change in the Discharger's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use or disposal sites not reported during the permit application process or not reported pursuant to an approved land application plan [40 CFR §122.41(l)(1)(iii)].

G. Anticipated Noncompliance

The Discharger shall give advance notice to the Regional Water Board or SWRCB of any planned changes in the permitted facility or activity that may result in noncompliance with General Order requirements [40 CFR §122.41(l)(2)].

H. Other Noncompliance

The Discharger shall report all instances of noncompliance not reported under Standard Provisions – Reporting E.3, E.4, and E.5 at the time monitoring reports are submitted. The reports shall contain the information listed in Standard Provision – Reporting V.E [40 CFR §122.41(l)(7)].

I. Other Information

When the Discharger becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the Regional Water Board, SWRCB, or USEPA, the Discharger shall promptly submit such facts or information [40 CFR §122.41(l)(8)].

VI. STANDARD PROVISIONS – ENFORCEMENT

- A. The CWA provides that any person who violates section 301, 302, 306, 307, 308, 318 or 405 of the Act, or any permit condition or limitation implementing any such sections in a permit issued under section 402, or any requirement imposed in a pretreatment program approved under sections 402(a)(3) or 402(b)(8) of the Act, is subject to a civil penalty not to exceed \$25,000 per day for each violation. The CWA provides that any person who negligently violates sections 301, 302, 306, 307, 308, 318, or 405 of the Act, or any condition or limitation implementing any of such sections in a permit issued under section 402 of the Act, or any requirement imposed in a pretreatment program approved under section 402(a)(3) or 402(b)(8) of the Act, is subject to criminal penalties of \$2,500 to \$25,000 per day of violation, or imprisonment of not more than one (1) year, or both. In the case of a second or subsequent conviction for a negligent violation, a person shall be subject to criminal penalties of not more than \$50,000 per day of violation, or by imprisonment of not more than two (2) years, or both. Any person who knowingly violates such sections, or such conditions or limitations is subject to criminal penalties of \$5,000 to \$50,000 per day of violation, or imprisonment for not more than three (3) years, or both. In the case of a second or subsequent

conviction for a knowing violation, a person shall be subject to criminal penalties of not more than \$100,000 per day of violation, or imprisonment of not more than six (6) years, or both. Any person who knowingly violates section 301, 302, 303, 306, 307, 308, 318 or 405 of the Act, or any permit condition or limitation implementing any of such sections in a permit issued under section 402 of the Act, and who knows at that time that he thereby places another person in imminent danger of death or serious bodily injury, shall, upon conviction, be subject to a fine of not more than \$250,000 or imprisonment of not more than 15 years, or both. In the case of a second or subsequent conviction for a knowing endangerment violation, a person shall be subject to a fine of not more than \$500,000 or by imprisonment of not more than 30 years, or both. An organization, as defined in section 309(c)(3)(B)(iii) of the Clean Water Act, shall, upon conviction of violating the imminent danger provision, be subject to a fine of not more than \$1,000,000 and can be fined up to \$2,000,000 for second or subsequent convictions [40 CFR §122.41(a)(2)] [CWC 13385 and 13387].

- B.** Any person may be assessed an administrative penalty by the Regional Water Board for violating section 301, 302, 306, 307, 308, 318 or 405 of this Act, or any permit condition or limitation implementing any of such sections in a permit issued under section 402 of this Act. Administrative penalties for Class I violations are not to exceed \$10,000 per violation, with the maximum amount of any Class I penalty assessed not to exceed \$25,000. Penalties for Class II violations are not to exceed \$10,000 per day for each day during which the violation continues, with the maximum amount of any Class II penalty not to exceed \$125,000 [40 CFR §122.41(a)(3)].
- C.** The CWA provides that any person who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required to be maintained under this permit shall, upon conviction, be punished by a fine of not more than \$10,000, or by imprisonment for not more than 2 years, or both. If a conviction of a person is for a violation committed after a first conviction of such person under this paragraph, punishment is a fine of not more than \$20,000 per day of violation, or by imprisonment of not more than 4 years, or both [40 CFR §122.41(j)(5)].
- D.** The CWA provides that any person who knowingly makes any false statement, representation, or certification in any record or other document submitted or required to be maintained under this Order, including monitoring reports or reports of compliance or noncompliance shall, upon conviction, be punished by a fine of not more than \$10,000 per violation, or by imprisonment for not more than six months per violation, or by both [40 CFR §122.41(k)(2)].

VII. ADDITIONAL PROVISIONS – NOTIFICATION LEVELS

A. Non-Municipal Facilities

Existing manufacturing, commercial, mining, and silvicultural dischargers shall notify the Regional Water Board as soon as they know or have reason to believe [40 CFR §122.42(a)]:

1. That any activity has occurred or will occur that would result in the discharge, on a routine or frequent basis, of any toxic pollutant that is not limited in this Order, if that discharge will exceed the highest of the following "notification levels" [40 CFR §122.42(a)(1)]:
 - a. 100 micrograms per liter ($\mu\text{g/L}$) [40 CFR §122.42(a)(1)(i)];
 - b. 200 $\mu\text{g/L}$ for acrolein and acrylonitrile; 500 $\mu\text{g/L}$ for 2,4-dinitrophenol and 2-methyl-4,6-dinitrophenol; and 1 milligram per liter (mg/L) for antimony [40 CFR §122.42(a)(1)(ii)];
 - c. Five (5) times the maximum concentration value reported for that pollutant in the Report of Waste Discharge [40 CFR §122.42(a)(1)(iii)]; or
 - d. The level established by the Regional Water Board in accordance with 40 CFR §122.44(f) [40 CFR §122.42(a)(1)(iv)].
2. That any activity has occurred or will occur that would result in the discharge, on a non-routine or infrequent basis, of any toxic pollutant that is not limited in this Order, if that discharge will exceed the highest of the following "notification levels" [40 CFR §122.42(a)(2)]:
 - a. 500 micrograms per liter ($\mu\text{g/L}$) [40 CFR §122.42(a)(2)(i)];
 - b. 1 milligram per liter (mg/L) for antimony [40 CFR §122.42(a)(2)(ii)];
 - c. Ten (10) times the maximum concentration value reported for that pollutant in the Report of Waste Discharge [40 CFR §122.42(a)(2)(iii)]; or
 - d. The level established by the Regional Water Board in accordance with 40 CFR §122.44(f) [40 CFR §122.42(a)(2)(iv)].

B. Publicly-Owned Treatment Works (POTWs)

All POTWs shall provide adequate notice to the Regional Water Board of the following [40 CFR §122.42(b)]:

1. Any new introduction of pollutants into the POTW from an indirect discharger that would be subject to Sections 301 or 306 of the CWA if it were directly discharging those pollutants [*40 CFR §122.42(b)(1)*]; and
2. Any substantial change in the volume or character of pollutants being introduced into that POTW by a source introducing pollutants into the POTW at the time of adoption of the Order [*40 CFR §122.42(b)(2)*].

Adequate notice shall include information on the quality and quantity of effluent introduced into the POTW as well as any anticipated impact of the change on the quantity or quality of effluent to be discharged from the POTW [*40 CFR §122.42(b)(3)*].

Attachment E – Monitoring and Reporting Program – Table of Contents

Attachment E – Monitoring and Reporting Program (MRP) 2

I. General Monitoring Provisions..... 2

II. Monitoring Locations 3

III. Influent Monitoring Requirements – Not applicable 4

IV. Effluent Monitoring Requirements 6

 A. Monitoring Location M-001 6

V. Whole Effluent Toxicity Testing Requirements – Not Applicable 13

VI. Land Discharge Monitoring Requirements – Not Applicable 15

VII. Reclamation Monitoring Requirements – Not Applicable 15

VIII. Receiving Water Monitoring Requirements 15

 A. Surface Water Monitoring 16

 B. Groundwater Monitoring – Not Applicable 16

 B. Groundwater Reporting Requirements – Not Applicable 16

IX. Other Monitoring Requirements..... 17

 A. Priority Pollutant Metals Monitoring..... 18

X. Reporting Requirements..... 18

 A. General Monitoring and Reporting Requirements – Not Applicable..... 18

 B. Self Monitoring Reports (SMRs) 18

 C. Discharge Monitoring Reports (DMRs) 20

 D. Other Reports 20

ATTACHMENT E – MONITORING AND REPORTING PROGRAM (MRP)

The Code of Federal Regulations (CFR) at 40 CFR Section 122.48 requires that all NPDES permits specify monitoring and reporting requirements. CWC sections 13267 and 13383 also authorize the Regional Water Quality Control Board (Regional Water Board) to require technical and monitoring reports. This MRP establishes monitoring and reporting requirements that implement the federal and California regulations.

I. GENERAL MONITORING PROVISIONS

- A. Samples and measurements taken as required herein shall be representative of the volume and nature of the monitored discharge. All samples shall be taken at the monitoring locations specified below and, unless otherwise specified, before the monitored flow joins or is diluted by any other waste stream, body of water, or substance. Monitoring locations shall not be changed without notification to and the approval of this Regional Water Board.
- B. Chemical, bacteriological, and bioassay analyses shall be conducted at a laboratory certified for such analyses by the State Department of Public Health Environmental Lab Accreditation Program (ELAP). In the event a certified laboratory is not available to the Discharger, analyses performed by a noncertified laboratory will be accepted provided the laboratory institutes a Quality Assurance-Quality Control Program. A manual containing the steps followed in this program must be kept in the laboratory and shall be available for inspection by Regional Water Board staff. The Quality Assurance-Quality Control Program must conform to USEPA guidelines or to procedures approved by the Regional Water Board.
- C. All analyses shall be conducted at a laboratory certified for such analyses by the State of California ELAP. Laboratories that perform sample analyses shall be identified in all monitoring reports.
- D. Appropriate flow measurement devices and methods consistent with accepted scientific practices shall be selected and used to ensure the accuracy and reliability of measurements of the volume of monitored discharges. All monitoring instruments and devices used by the Discharger to fulfill the prescribed monitoring program shall be properly maintained and calibrated as necessary to ensure their continued accuracy.
- E. Monitoring results, including noncompliance, shall be reported at intervals and in a manner specified in this Monitoring and Reporting Program.
- F. If the facility is not in operation, or there is no discharge during a required reporting period, the Discharger shall forward a letter to the Regional Water Board indicating that there has been no activity during the required reporting period.

II. MONITORING LOCATIONS

The Discharger shall establish the following monitoring locations to demonstrate compliance with the effluent limitations, discharge specifications, and other requirements in this Order:

Discharge Point Name	Monitoring Location Name	Monitoring Location Description (include Latitude and Longitude when available)
001	M-001	Effluent from ARGET.
002	M-002	Effluent from GET E/F.
003	M-003	No Longer Used
004	M-004	Effluent from GET H-A
005	M-005	Effluent from GET J.
006	M-006	No Longer Used
007	M-007	Effluent from GET K-A
008	M-008	Effluent from GET L-A.
009	M-009	Effluent from GET L-B
010	M-010	Effluent from Sailor Bar Park Well System.
011	M-011	Effluent from Chettenham Well System.
012	M-012	Effluent from Low-threat System.
013	M-013	Effluent from AC-6 Well System
014	M-014	Effluent form AC-18 Well System
015	M-015	Effluent from AC-23 Well System
	MINFA	Influent to ARGET
	MINFB	Influent to GET E/F
	MINFC	No Longer Used
	MINFD	Influent to GET H-A
	MINFE	Influent to GET J
	MINFF	No Longer Used
	MINFG	Influent to GET K-A
	MINFH	Influent to GET L-A
	MINFI	Influent to GET L-B
	MINFJ	Influent to Sailor Bar Park Well System
	MINFK	Influent to Chettenham Well System
	MINFL	Influent to AC-6 Well System
	MINFM	Influent to AC-18 Well System
	MINFN	Influent to AC-23 Well System
	R-001 and R-002	R-001 (upstream) and R-002 (downstream) on American River from discharge of Buffalo Creek into American River at Latitude 38°, 38', 00" N, Longitude 121°, 16', 07" W. Outfall 001 is representative of ARGET, GET E/F and GET J discharges (Discharges 001, 002, and 005, respectively).
	R-003 and R-004	R-003 (upstream) and R-004 (downstream) on American River from discharge water from GET L-B (Discharge 009) into American River at Latitude 38°, 37', 31" N, Longitude 121°, 18', 13" W.

Discharge Point Name	Monitoring Location Name	Monitoring Location Description (include Latitude and Longitude when available)
	R-005 and R-008	R-005 (upstream) and R-008 (downstream) on American River from discharge water from GET L-A (Discharge 008) into American River at Latitude 38°, 36', 29" N, Longitude 121°, 18', 33" W.
	R-006 and R-007	R-006 (upstream) and R-007 (downstream) on American River from discharge water from long term GET K-A (Discharge 007) and AC-6 (Discharge 013) into American River at Latitude 38°, 36', 07" N, Longitude 121°, 19', 02" W
	R-008 and R-009	No longer used.
	R-010 and R-011	R-010 (upstream) and R-011 (downstream) on American River from discharge from Chettenham Well (Discharge 011) and AC-23 (Discharge 015) into American River via the Boyd Station Channel at Latitude 38°, 34', 46" N, Longitude 121°, 19', 32" W. May receive water from long term GET H-A (Discharge 004) in the future.
	R-012 and R-013	R-012 (upstream) and R-013 (downstream) on Morrison Creek from discharge of drainage ditch to Morrison Creek at Latitude 38°, 31', 53" N, Longitude 121°, 19', 36" W. Outfall 006 represents discharge from GET H-A (Discharge 004) and AC-18 (Discharge 014).
	R-014 and R-015	R-014 (upstream) and R-015 (downstream) on American River from a potential discharge from various GETs into American River via pipeline at 38°, 38', 06" N, Longitude 121°, 13', 13" W.
	R-016 and R-017	R-016 (upstream) and R-017 (downstream) on Alder Creek from a potential discharge water from various GETs via pipeline into Alder Creek at American River at Latitude 38°, 38', 12" N, Longitude 121°, 12', 11" W.

III. INFLUENT MONITORING REQUIREMENTS

A. The Discharger shall monitor **MINFA and MINFB** as follows:

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method
VOCs	µg/L	Grab	Monthly	[1]
N-nitrosodimethylamine	µg/L	Grab	Monthly	[2]
Perchlorate	µg/L	Grab	Monthly	[3]
Semi-Volatile Organics	µg/L	Grab	Monthly	[4]
1,4-Dioxane	µg/L	Grab	Monthly	[5]
Total Copper	µg/L	Grab	Monthly	[6]
PROWL [8]	µg/L	Grab	2xYear	[7]

1. Test Method to be EPA Methods 601 and 602 or 8010 and 8020 or 8260, or 500 Series, or an equivalent method approved by the Regional Board with a practical quantitation level no greater than 0.5 µg/L. All concentrations between the detection level and practical quantitation level shall be reported as trace.
2. A test method with a practical quantitation level no greater than 0.002 µg/L. All concentrations between the detection limit and practical quantitation level shall be reported as trace.

3. Test Method to be EPA Methods 314.0 or 314.1, or an equivalent method approved by the Regional Board. with a practical quantitation level no greater than 4.0 µg/L. All concentrations between the detection level and practical quantization level shall be reported as trace.
4. Test Method to be EPA Methods 8270 or 500 Series Method, or an equivalent method approved by the Regional Board with a Practical Quantitation Level no greater than 0.5 µg/L. All concentrations between the detection limit and practical quantitation level shall be reported as trace.
5. A test method with a practical quantitation level no greater than 3 µg/L. All concentrations between the detection limit and practical quantitation level shall be reported as trace.
6. Test Method to be EPA Method 1638/200.8 or an equivalent method approved by the Regional Board with a practical quantitation level no greater than 3 µg/L. All concentrations between the detection limit and practical quantitation level shall be reported as trace.
7. PROWL analysis with a practical quantitation level no greater than 10 µg/L. All concentrations between the detection level and practical quantitation level shall be reported as trace.
8. MINFB only for PROWL analysis.

B. The Discharger shall monitor MINFD, MINFJ, MINFM and MINFN as follows:

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method
VOCs	µg/L	Grab	Monthly	[1]
Perchlorate	µg/L	Grab	Monthly	[2]
Semi-Volatile Organics[4]	µg/L	Grab	Quarterly	[3]

1. Test Method to be EPA Methods 601 and 602 or 8010 and 8020 or 8260, or 500 Series, or an equivalent method approved by the Regional Board with a practical quantitation level no greater than 0.5 µg/L. All concentrations between the detection level and practical quantitation level shall be reported as trace.
2. Test Method to be EPA Methods 314.0 or 314.1, or an equivalent method approved by the Regional Board. with a practical quantitation level no greater than 4.0 µg/L. All concentrations between the detection level and practical quantization level shall be reported as trace.
3. Test Method to be EPA Methods 8270 or 500 Series Method, or an equivalent method approved by the Regional Board with a Practical Quantitation Level no greater than 0.5 µg/L. All concentrations between the detection limit and practical quantitation level shall be reported as trace.
4. Not for MINFM and MINFN.

C. The Discharger shall monitor MINFE, MINFG, MINFH, MINFI AND MINFL as follows:

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method
VOCs	µg/L	Grab	Monthly	[1]
N-nitrosodimethylamine	µg/L	Grab	Monthly	[2]
Perchlorate	µg/L	Grab	Monthly	[3]
Semi-Volatile Organics[5]	µg/L	Grab	Quarterly	[4]

1. Test Method to be EPA Methods 601 and 602 or 8010 and 8020 or 8260, or 500 Series, or an equivalent method approved by the Regional Board with a practical quantitation level no greater than 0.5 µg/L. All concentrations between the detection level and practical quantitation level shall be reported as trace.
2. A test method with a practical quantitation level no greater than 0.002 µg/L. All concentrations between the detection limit and practical quantitation level shall be reported as trace.
3. Test Method to be EPA Methods 314.0 or 314.1, or an equivalent method approved by the Regional Board with a practical quantitation level no greater than 4.0 µg/L. All concentrations between the detection level and practical quantization level shall be reported as trace.
4. Test Method to be EPA Methods 8270 or 500 Series Method, or an equivalent method approved by the Regional Board with a Practical Quantitation Level no greater than 0.5 µg/L. All concentrations between the detection limit and practical quantitation level shall be reported as trace.
5. Not for MINFL.

D. The Discharger shall monitor MINFK as follows:

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method
Perchlorate	µg/L	Grab	Monthly	[1]
Total Copper	µg/L	Grab	Monthly	[2]

1. Test Method to be EPA Methods 314.0 or 314.1, or an equivalent method approved by the Regional Board with a practical quantitation level no greater than 4.0 µg/L. All concentrations between the detection level and practical quantization level shall be reported as trace.
2. Test Method to be EPA Methods 8270 or 500 Series Method, or an equivalent method approved by the Regional Board with a Practical Quantitation Level no greater than 0.5 µg/L. All concentrations between the detection limit and practical quantitation level shall be reported as trace.

IV. EFFLUENT MONITORING REQUIREMENTS

A. Monitoring Locations M-001, M-002, M-004, M-005, M-007, M-008, M-009, M-010, M-011, M-012, M-013, M-014 and M-015

1. The Discharger shall monitor wastewater discharged at **M-001** as follows:

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method[9]
Volatile Organics	µg/L	Grab	Monthly	[1]
N-nitrosodimethylamine	µg/L	Grab	Monthly	[2]
Perchlorate	µg/L	Grab	Monthly	[3]
Semi-Volatile Organics	µg/L	Grab	Monthly	[4]
1,4-Dioxane	µg/L	Grab	Monthly	[5]
Total Copper	µg/L	Grab	Monthly	[6]
Flow[7]	mgd	Measure	Continuous	--
Temperature[7]	°F(°C)	Grab	Monthly	--
Dissolved Oxygen[7]	mg/L	Grab	Monthly	--
Turbidity[7]	NTU	Grab	Monthly	--
Electrical Conductivity[7]	µmhos/cm	Grab	Monthly	--
pH[7]	Standard	Grab	Monthly	--
Hardness as CaCO ₃	mg/L	Grab	Quarterly	--
Total Dissolved Solids	mg/L	Grab	Monthly	--
Acute Toxicity	% Survival	Grab	Quarterly	[8]

1. Test Method to be EPA Methods 601 and 602 or 8010 and 8020 or 8260, or 500 Series, or an equivalent method approved by the Regional Board with a Practical Quantitation Level no greater than 0.5 µg/L. All concentrations between the detection level and practical quantitation level shall be reported as trace.
2. A test method with a practical quantitation level no greater than 0.002 µg/L. All concentrations between the detection limit and practical quantitation level shall be reported as trace.
3. Test Method to be EPA Methods 314.0 or 314.1, or an equivalent method approved by the Regional Board with a Practical Quantitation Level no greater than 4.0 µg/L. All concentrations between the detection limit and practical quantitation level shall be reported as trace.
4. Test Method to be EPA Methods 8270 or 500 Series Method, or an equivalent method approved by the Regional Board with a Practical Quantitation Level no greater than 0.5 µg/L. All concentrations between the detection limit and Practical quantitation level shall be reported as trace.
5. A test method with a practical quantitation level no greater than 3 µg/L. All concentrations between the detection limit and practical quantitation level shall be reported as trace.
6. Test Method to be EPA Method 1638/200.8 or an equivalent method approved by the Regional Board with a practical quantitation limit no greater than 3 µg/L. All concentrations between the detection limit and practical quantitation

level shall be reported as trace.

7. Field Measurements.
8. Acute toxicity testing shall be performed as described in [Whole Effluent Toxicity Testing Requirements V.A.](#), below.
9. Parameters shall be analyzed using the analytical methods described in 40 CFR sections 136.

2. The Discharger shall monitor wastewater discharged at **M-002** as follows:

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method[13]
Volatile Organics	µg/L	Grab	Monthly	[1]
N-nitrosodimethylamine	µg/L	Grab	Monthly	[2]
Perchlorate	µg/L	Grab	Monthly	[3]
Semi-Volatile Organics	µg/L	Grab	Monthly	[4]
1,4-Dioxane	µg/L	Grab	Monthly	[5]
Total Copper	µg/L	Grab	Monthly	[6]
Flow[7]	mgd	Measure	Continuous	--
Temperature[7]	°F(°C)	Grab	Monthly	--
Dissolved Oxygen	mg/L	Grab	Monthly	--
Turbidity	NTU	Grab	Monthly	--
Electrical Conductivity[7]	µmhos/cm	Grab	Monthly	--
pH[7]	Standard	Grab	Monthly	--
Hardness as CaCO ₃	mg/L	Grab	Quarterly	--
Total Dissolved Solids	mg/L	Grab	Monthly	--
PROWL	µg/L	Grab	2xYear	[8]
Formaldehyde	µg/L	Grab	Monthly	[9]
Glyoxal	µg/L	Grab	Monthly	[10]
Acetaldehyde	µg/L	Grab	Monthly	[11]
Acute Toxicity	% Survival	Grab	Quarterly	[12]

1. Test Method to be EPA Methods 601 and 602 or 8010 and 8020 or 8260, or 500 Series, or an equivalent method approved by the Regional Board with a Practical Quantitation Level no greater than 0.5 µg/L. All concentrations between the detection level and practical quantitation level shall be reported as trace.
2. A test method with a practical quantitation level no greater than 0.002 µg/L. All concentrations between the detection limit and practical quantitation level shall be reported as trace.
3. Test Method to be EPA Methods 314.0 or 314.1, or an equivalent method approved by the Regional Board with a Practical Quantitation Level no greater than 4.0 µg/L. All concentrations between the detection limit and practical quantitation level shall be reported as trace.
4. Test Method to be EPA Methods 8270 or 500 Series Method, or an equivalent method approved by the Regional Board with a practical quantitation level no greater than 0.5 µg/L. All concentrations between the detection limit and practical quantitation level shall be reported as trace.
5. A test method with a practical quantitation level no greater than 3 µg/L. All concentrations between the detection limit and practical quantitation level shall be reported as trace.
6. Test Method to be EPA Method 1638/200.8 or an equivalent method approved by the Regional Board with a practical quantitation limit no greater than 3 µg/L. All concentrations between the detection limit and practical quantitation level shall be reported as trace.
7. Field Measurements.
8. PROWL analysis with a practical quantitation level no greater than 10 µg/L. All concentrations between the detection level and practical quantitation level shall be reported as trace.
9. Formaldehyde analysis with a practical quantitation level no greater than 5 µg/L. All concentrations between the detection level and practical quantitation level shall be reported as trace.
10. Glyoxal analysis with a practical quantitation level no greater than 5 µg/L. All concentrations between the detection level and practical quantitation level shall be reported as trace.
11. Acetaldehyde analysis with a practical quantitation level no greater than 1 µg/L. All concentrations between the detection level and practical quantitation level shall be reported as trace.
12. Acute toxicity testing shall be performed as described in [Whole Effluent Toxicity Testing Requirements V.A.](#), below.

13. Parameters shall be analyzed using the analytical methods described in 40 CFR sections 136.

3. The Discharger shall monitor wastewater discharged at **M-004** as follows:

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method[6]
Volatile Organics	µg/L	Grab	Monthly	[1]
Perchlorate	µg/L	Grab	Monthly	[2]
Semi-Volatile Organics	µg/L	Grab	Quarterly	[3]
Flow[4]	mgd	Measure	Continuous	--
Temperature[4]	°F(°C)	Grab	Monthly	--
Dissolved Oxygen[4]	mg/L	Grab	Monthly	--
Turbidity[4]	NTU	Grab	Monthly	--
Electrical Conductivity[4]	µmhos/cm	Grab	Monthly	--
pH[4]	Standard	Grab	Monthly	--
Hardness as CaCO ₃	mg/L	Grab	Quarterly	--
Total Dissolved Solids	mg/L	Grab	Monthly	--
Acute Toxicity	% Survival	Grab	Quarterly	[5]

1. Test Method to be EPA Methods 601 and 602 or 8010 and 8020 or 8260, or 500 Series, or an equivalent method approved by the Regional Board with a Practical Quantitation Level no greater than 0.5 µg/L. All concentrations between the detection level and practical quantitation level shall be reported as trace.
2. Test Method to be EPA Methods 314.0 or 314.1, or an equivalent method approved by the Regional Board, with a Practical Quantitation Level no greater than 4.0 µg/L. All concentrations between the detection limit and practical quantitation level shall be reported as trace.
3. Test Method to be EPA Methods 8270 or 500 Series Method, or an equivalent method approved by the Regional Board with a Practical Quantitation Level no greater than 0.5 µg/L. All concentrations between the detection limit and practical quantitation level shall be reported as trace.
4. Field Measurements.
5. Acute toxicity testing shall be performed as described in [Whole Effluent Toxicity Testing Requirements V.A.](#), below.
6. Parameters shall be analyzed using the analytical methods described in 40 CFR sections 136.

4. The Discharger shall monitor wastewater discharged at **M-005** as follows:

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method[7]
Volatile Organics	µg/L	Grab	Monthly	[1]
N-nitrosodimethylamine	µg/L	Grab	Monthly	[2]
Perchlorate	µg/L	Grab	Monthly	[3]
Semi-Volatile Organics	µg/L	Grab	Quarterly	[4]
Flow[5]	mgd	Measure	Continuous	--
Temperature[5]	°F(°C)	Grab	Monthly	--
Dissolved Oxygen[5]	mg/L	Grab	Monthly	--
Turbidity[5]	NTU	Grab	Monthly	--
Electrical Conductivity[5]	µmhos/cm	Grab	Monthly	--
pH[5]	Standard	Grab	Monthly	--
Hardness as CaCO ₃	mg/L	Grab	Quarterly	--
Total Dissolved Solids	mg/L	Grab	Monthly	--
Acute Toxicity	% Survival	Grab	Quarterly	[6]

1. Test Method to be EPA Methods 601 and 602 or 8010 and 8020 or 8260, or 500 Series, or an equivalent method approved by the Regional Board with a Practical Quantitation Level no greater than 0.5 µg/L. All concentrations between the detection level and practical quantitation level shall be reported as trace.
2. A test method with a practical quantitation level no greater than 0.002 µg/L. All concentrations between the detection limit and practical quantitation level shall be reported as trace.
3. Test Method to be EPA Methods 314.0 or 314.1, or an equivalent method approved by the Regional Board with a Practical Quantitation Level no greater than 4.0 µg/L. All concentrations between the detection limit and practical quantitation level shall be reported as trace.
4. Test Method to be EPA Methods 8270 or 500 Series Method, or an equivalent method approved by the Regional Board with a Practical Quantitation Level no greater than 0.5 µg/L. All concentrations between the detection limit and practical quantitation level shall be reported as trace.
5. Field Measurements.
6. Acute toxicity testing shall performed as described in [Whole Effluent Toxicity Testing Requirements V.A.](#), below.
7. Parameters shall be analyzed using the analytical methods described in 40 CFR sections 136.

5. The Discharger shall monitor wastewater discharged at **M-007** as follows:

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method[6]
Volatile Organics	µg/L	Grab	Monthly	[1]
N-nitrosodimethylamine	µg/L	Grab	Monthly	[2]
Perchlorate	µg/L	Grab	Monthly	[3]
Flow[4]	mgd	Measure	Continuous	--
Temperature[4]	°F(°C)	Grab	Monthly	--
Dissolved Oxygen[4]	mg/L	Grab	Monthly	--
Turbidity[4]	NTU	Grab	Monthly	--
Electrical Conductivity[4]	µmhos/cm	Grab	Monthly	--
pH[4]	Standard	Grab	Monthly	--
Hardness as CaCO ₃	mg/L	Grab	Quarterly	--
Total Dissolved Solids	mg/L	Grab	Monthly	--
Acute Toxicity	% Survival	Grab	Quarterly	[5]

1. Test Method to be EPA Methods 601 and 602 or 8010 and 8020 or 8260, or 500 Series, or an equivalent method approved by the Regional Board with a Practical Quantitation Level no greater than 0.5 µg/L. All concentrations between the detection level and practical quantitation level shall be reported as trace.
2. A test method with a practical quantitation level no greater than 0.002 µg/L. All concentrations between the detection limit and practical quantitation level shall be reported as trace.
3. Test Method to be EPA Methods 314.0 or 314.1, or an equivalent method approved by the Regional Board with a Practical Quantitation Level no greater than 4.0 µg/L. All concentrations between the detection limit and practical quantitation level shall be reported as trace. Sampling commences once perchlorate has been detected in the influent.
4. Field Measurements.
5. Acute toxicity testing shall performed as described in [Whole Effluent Toxicity Testing Requirements V.A.](#), below.
6. Parameters shall be analyzed using the analytical methods described in 40 CFR sections 136.

6. The Discharger shall monitor wastewater discharged at **M-008 and M-009** as follows:

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method[6]
Volatile Organics	µg/L	Grab	Monthly [1]	[1]
N-nitrosodimethylamine	µg/L	Grab	Monthly	[2]
Perchlorate	µg/L	Grab	Monthly[3]	[3]
Flow[4]	mgd	Measure	Continuous	--

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method[6]
Temperature[4]	°F(°C)	Grab	Monthly	--
Dissolved Oxygen[4]	mg/L	Grab	Monthly	--
Turbidity[4]	NTU	Grab	Monthly	--
Electrical Conductivity[4]	µmhos/cm	Grab	Monthly	--
pH[4]	Standard	Grab	Monthly	--
Hardness as CaCO ₃	mg/L	Grab	Quarterly	--
Total Dissolved Solids	mg/L	Grab	Monthly	--
Acute Toxicity	% Survival	Grab	Quarterly	[5]

1. Test Method to be EPA Methods 601 and 602 or 8010 and 8020 or 8260, or 500 Series, or an equivalent method approved by the Regional Board. with a Practical Quantitation Level no greater than 0.5 µg/L. All concentrations between the detection level and practical quantitation level shall be reported as trace. Sampling commences once a VOC constituent is detected in the influent.
2. A test method with a practical quantitation level no greater than 0.002 µg/L. All concentrations between the detection limit and practical quantitation level shall be reported as trace.
3. Test Method to be EPA Methods 314.0 or 314.1, or an equivalent method approved by the Regional Board with a Practical Quantitation Level no greater than 4.0 µg/L. All concentrations between the detection limit and practical quantitation level shall be reported as trace. Sampling commences once perchlorate is detected in the influent.
4. Field Measurements.
5. Acute toxicity testing shall performed as described in [Whole Effluent Toxicity Testing Requirements V.A.](#), below.
6. Parameters shall be analyzed using the analytical methods described in 40 CFR sections 136.

7. The Discharger shall monitor wastewater discharged at **M-010** as follows:

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method[5]
Volatile Organics	µg/L	Grab	Monthly	[1]
Perchlorate	µg/L	Grab	Monthly[2]	[2]
1,4-Dioxane	µg/L	Grab	Monthly	[3]
Flow[4]	mgd	Measure	Continuous	--
Temperature[4]	°F(°C)	Grab	Monthly	--
Dissolved Oxygen[4]	mg/L	Grab	Monthly	--
Electrical Conductivity[4]	µmhos/cm	Grab	Monthly	--
pH[4]	Standard	Grab	Monthly	--

1. Test Method to be EPA Methods 601 and 602 or 8010 and 8020 or 8260, or 500 Series, or an equivalent method approved by the Regional Board with a Practical Quantitation Level no greater than 0.5 µg/L. All concentrations between the detection level and practical quantitation level shall be reported as trace.
2. Test Method to be EPA Methods 314.0 or 314.1, or an equivalent method approved by the Regional Board with a Practical Quantitation Level no greater than 4.0 µg/L. All concentrations between the detection limit and practical quantitation level shall be reported as trace. Sampling for perchlorate commences when perchlorate is detected in the influent.
3. A test method with a practical quantitation level no greater than 3 µg/L. All concentrations between the detection limit and practical quantitation level shall be reported as trace.
4. Field Measurements.
5. Parameters shall be analyzed using the analytical methods described in 40 CFR sections 136.

8. The Discharger shall monitor wastewater discharged at **M-011** as follows:

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method[3]
Perchlorate	µg/L	Grab	Weekly	[1]
Flow[2]	mgd	Measure	Continuous	--

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method[3]
Temperature[2]	°F(°C)	Grab	Monthly	--
Dissolved Oxygen	mg/L	Grab	Monthly	--
Electrical Conductivity[2]	µmhos/cm	Grab	Monthly	--
pH[3]	Standard	Grab	Monthly	--

1. Test Method to be EPA Methods 314.0 or 314.1, or an equivalent method approved by the Regional Board with a Practical Quantitation Level no greater than 4.0 µg/L. All concentrations between the detection limit and practical quantitation level shall be reported as trace.
2. Field Measurements.
3. Parameters shall be analyzed using the analytical methods described in 40 CFR sections 136.

9. The Discharger shall monitor wastewater discharged at **M-012** as follows:

Parameter	Units	Sample Type	Minimum Sampling Frequency[5]	Required Analytical Test Method[4]
Volatile Organics	µg/L	Grab	Once per 10,000 gallons purge water for Well Purge Beginning, middle and end of Aquifer Test	[1]
N-nitrosodimethylamine[6]	µg/L	Grab	Once per well purge Beginning, middle and end of Aquifer Test	[2]
Perchlorate	µg/L	Grab	Once per well purge Beginning, middle and end of Aquifer Test	[3]
1,4-Dioxane [6]	µg/L	Grab	Once per well purge Beginning, middle and end of Aquifer Test	[3]
Flow[4] [6]	gallons	Measure	Continuous	--
Temperature[4]	°F(°C)	Grab	Once per well purge Beginning, middle and end of Aquifer Test	--
pH[4]	Standard	Grab	Once per well purge Beginning, middle and end of Aquifer Test	--

1. Test Method to be EPA Methods 601 and 602 or 8010 and 8020 or 8260, or 500 Series, or an equivalent method approved by the Regional Board with a Practical Quantitation Level no greater than 0.5 µg/L. All concentrations between the detection level and practical quantitation level shall be reported as trace.
2. A test method with a practical quantitation level no greater than 0.002 µg/L. All concentrations between the detection limit and practical quantitation level shall be reported as trace.
3. Test Method to be EPA Methods 314.0 or 314.1, or an equivalent method approved by the Regional Board with a Practical Quantitation Level no greater than 4.0 µg/L. All concentrations between the detection limit and practical quantitation level shall be reported as trace.
4. Field Measurements.
5. Monitoring at M-012 when it is used for well purging or well rehabilitation at AC-6, AC-18 and AC-23 shall occur monthly for each of the wells.
6. Not required for AC-6, AC-18 and AC-23.

10. The Discharger shall monitor wastewater discharged at **M-013** as follows:

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method[4]
Volatile Organics	µg/L	Grab	Monthly	[1]
Perchlorate	µg/L	Grab	Monthly	[2]
N-nitrosodimethylamine	µg/L	Grab	Monthly	[6]
Flow[3]	mgd	Measure	Continuous	--
Temperature[3]	°F(°C)	Grab	Monthly[5]	--
Dissolved Oxygen[3]	mg/L	Grab	Monthly[5]	--
Electrical Conductivity[3]	µmhos/cm	Grab	Monthly[5]	--
pH[3]	Standard	Grab	Monthly[5]	--
Turbidity[3]	NTU	Grab	Monthly[5]	--

1. Test Method to be EPA Methods 601 and 602 or 8010 and 8020 or 8260, or 500 Series, or an equivalent method approved by the Regional Board with a Practical Quantitation Level no greater than 0.5 µg/L. All concentrations between the detection level and practical quantitation level shall be reported as trace.
2. Test Method to be EPA Methods 314.0 or 314.1, or an equivalent method approved by the Regional Board with a Practical Quantitation Level no greater than 4.0 µg/L. All concentrations between the detection limit and practical quantitation level shall be reported as trace.
3. Field Measurements.
4. Parameters shall be analyzed using the analytical methods described in 40 CFR sections 136.
5. Samples only collected during discharge to receiving water not during times of discharge to potable system.
6. A test method with a practical quantitation level no greater than 0.002 µg/L. All concentrations between the detection limit and practical quantitation level shall be reported as trace. Sampling commences once NDMA is detected in the influent.

11. The Discharger shall monitor wastewater discharged at **M-014 and M-015** as follows:

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method[4]
Volatile Organics	µg/L	Grab	Monthly	[1]
Perchlorate	µg/L	Grab	Monthly	[2]
Flow[3]	mgd	Measure	Continuous	--
Temperature[3]	°F(°C)	Grab	Monthly[5]	--
Dissolved Oxygen[3]	mg/L	Grab	Monthly[5]	--
Electrical Conductivity[3]	µmhos/cm	Grab	Monthly[5]	--
pH[3]	Standard	Grab	Monthly[5]	--
Turbidity[3]	NTU	Grab	Monthly[5]	--

1. Test Method to be EPA Methods 601 and 602 or 8010 and 8020 or 8260, or 500 Series, or an equivalent method approved by the Regional Board with a Practical Quantitation Level no greater than 0.5 µg/L. All concentrations between the detection level and practical quantitation level shall be reported as trace. Sampling commences once VOCs are detected in the influent.
2. Test Method to be EPA Methods 314.0 or 314.1, or an equivalent method approved by the Regional Board with a Practical Quantitation Level no greater than 4.0 µg/L. All concentrations between the detection limit and practical quantitation level shall be reported as trace.
3. Field Measurements.
4. Parameters shall be analyzed using the analytical methods described in 40 CFR sections 136.
5. Samples only collected during discharge to receiving water not during times of discharge to potable system.

12. If the discharge is intermittent rather than continuous, then on the first day of each such discharge, the Discharger shall monitor and record data for all of the

constituents listed above, after which the frequency of analysis given in the schedule shall apply for the duration of each such intermittent discharge. In no event shall the Discharger be required to monitor and record data more often than twice the frequencies listed in the schedule.

13. If no discharge occurs at a particular discharge point during the monitoring period, then samples need not be collected for that particular discharge. It must be reported under the reporting program that no sampling was conducted at a particular monitoring point due to no discharge.

V. WHOLE EFFLUENT TOXICITY TESTING REQUIREMENTS

A. **Acute Toxicity Testing.** The Discharger shall conduct acute toxicity testing to determine whether the effluent is contributing acute toxicity to the receiving water. The Discharger shall meet the following acute toxicity testing requirements:

1. Monitoring Frequency – the Discharger shall perform quarterly acute toxicity testing, concurrent with effluent sampling for volatile organics and copper.
2. Sample Types – Effluent samples shall be grab samples taken at M-001, M-002, M-004, M-005, M-007, M-008 and M-009.
3. Test Species – Test species shall be larval stage (0 to 14 days old) fathead minnows (*Pimephales promelas*).
4. Methods – The acute bioassay tests samples shall be conducted in accordance with EPA-821-R-02-012, Fifth Edition, or later amendment with Executive Officer approval. Temperature and pH shall be recorded at the time of bioassay sample collection. No pH adjustment may be made unless approved by the Executive Officer.
5. Test Failure – If an acute toxicity test does not meet all test acceptability criteria, as specified in the test method, the Discharger must re-sample and re-test as soon as possible, not to exceed 3 business days following notification of test failure.

B. **Chronic Toxicity Testing.** The Discharger shall conduct three species chronic toxicity testing to determine whether the effluent is contributing chronic toxicity to the receiving water. The Discharger shall meet the following chronic toxicity testing requirements:

1. Monitoring Frequency – the Discharger shall perform annual chronic toxicity testing for the first 4 quarters and annually thereafter.
2. Sample Types – Effluent samples shall be grab samples and shall be representative of the volume and quality of the discharge. The effluent samples

shall be taken at effluent monitoring locations M-001 and M-002. The receiving water control shall be a grab sample obtained from the R-001 sampling location.

3. Sample Volumes – Adequate sample volumes shall be collected to provide renewal water to complete the test in the event that the discharge is intermittent.
 4. Test Species – Chronic toxicity testing measures either lethal or sublethal (e.g. reduced growth, reproduction) effects to experimental test organisms exposed to an effluent compared to that of the control organisms. The Discharger shall conduct chronic toxicity tests with:
 - The cladoceran, water flea, *Ceriodaphnia dubia* (survival and reproduction test);
 - The fathead minnow, *Pimephales promelas* (larval survival and growth test); and
 - The green alga, *Selenastrum capricornutum* (growth test).
 5. Methods – The presence of chronic toxicity shall be estimated as specified in *Short-term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms, Fourth Edition, EPA/821-R-02-013, October 2002*, or later amendment with Executive Officer approval.
 6. Reference Toxicant – As required by the SIP, all chronic toxicity tests shall be conducted with concurrent testing with a reference toxicant and shall be reported with the chronic toxicity test results.
 7. Dilutions – The chronic toxicity testing shall be performed using the 100% effluent, 25% effluent/75% R-001, 10% effluent/90% R-001 and 5%effluent/95% R-001.
 8. Test Failure – If either the reference toxicant test or the effluent test does not meet all test acceptability criteria as specified in the *Short-term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms, Fourth Edition, EPA/821-R-02-013, October 2002*, and its subsequent amendments or revisions, the Discharger must re-sample and re-test as soon as possible, but no later than fourteen (14) days after receiving notification of test failure.
- C. **WET Testing Notification Requirements.** The Discharger shall notify the Regional Board within 24-hrs after the receipt of the results of an exceedance of a toxicity trigger during regular or accelerated monitoring.
- D. **WET Testing Reporting Requirements.** All toxicity test reports shall include the contracting laboratory's complete report provided to the Discharger and shall be in accordance with the appropriate "Report Preparation and Test Review" sections of the

method manuals. At a minimum, whole effluent toxicity monitoring shall be reported as follows:

1. **Chronic WET Reporting.** Regular chronic toxicity monitoring results shall be reported to the Regional Water Board within 30 days following completion of the test, and shall contain, at minimum:
 - a. The results expressed in TUC, measured as 100/NOEC, and also measured as 100/LC50 100/EC₂₅, 100/IC₂₅, and 100/IC₅₀, as appropriate.
 - b. The statistical methods used to calculate endpoints;
 - c. The statistical output page, which includes the calculation of the percent minimum significant difference (PMSD);
 - d. The dates of sample collection and initiation of each toxicity test; and
 - e. The results compared to the numeric toxicity trigger.

Additionally, the monthly discharger self-monitoring reports shall contain an updated chronology of chronic toxicity test results expressed in TUC, and organized by test species, type of test (survival, growth or reproduction), and monitoring frequency, i.e., either quarterly, monthly, accelerated, or TRE.

2. **Acute WET Reporting.** Acute toxicity test results shall be submitted with the monthly discharger self-monitoring reports, reported as percent survival.
3. **TRE Reporting.** Reports for Toxicity Reduction Evaluations shall be submitted in accordance with the schedule contained in the Discharger's approved TRE Workplan.
4. **Quality Assurance (QA).** The Discharger must provide the following information for QA purposes:
 - a. Results of the applicable reference toxicant data with the statistical output page giving the species, NOEC, LOEC, type of toxicant, dilution water used, concentrations used, PMSD, and dates tested.
 - b. The reference toxicant control charts for each endpoint, which include summaries of reference toxicant tests performed by the contracting laboratory.
 - c. Any information on deviations or problems encountered and how they were dealt with.

VI. LAND DISCHARGE MONITORING REQUIREMENTS – NOT APPLICABLE

VII. RECLAMATION MONITORING REQUIREMENTS – NOT APPLICABLE

VIII. RECEIVING WATER MONITORING REQUIREMENTS

A. Surface Water Monitoring – American River, Morrison Creek and Alder Creek

1. The Discharger shall monitor the American River at R-001, R-002, R-003, R-004, R-005, R-008, R-009, R-010, R-011, R-014 and R-015, and Alder Creek at R-016 and R-017 as follows:

Parameter	Units	Sample Type	Minimum Sampling Frequency[7]	Required Analytical Test Method[6]
Volatile Organics	µg/L	Grab	Monthly	[1]
N-nitrosodimethylamine	µg/L	Grab	Monthly	[2]
Perchlorate	µg/L	Grab	Monthly	[3]
Total Copper	µg/L	Grab	Monthly	[4]
Temperature[5]	°F(°C)	Grab	Monthly	--
Dissolved Oxygen[5]	mg/L	Grab	Monthly	--
Turbidity	NTU	Grab	Monthly	--
Electrical Conductivity[5]	µmhos/cm	Grab	Monthly	--
pH[5]	Standard	Grab	Monthly	--
Hardness as CaCO ₃	mg/L	Grab	Quarterly	--
Total Dissolved Solids	mg/L	Grab	Monthly	--

1. Test Method to be EPA Methods 601 and 602 or 8010 and 8020 or 8260, or 500 Series, or an equivalent method approved by the Regional Board. with a Practical Quantitation Level no greater than 0.5 µg/L. All concentrations between the detection level and practical quantitation level shall be reported as trace.
2. A test method with a practical quantitation level no greater than 0.002 µg/L. All concentrations between the detection limit and practical quantitation level shall be reported as trace. NOT REQUIRED AT R-012 AND R-013.
3. A test method with a practical quantitation level no greater than 3 µg/L. All concentrations between the detection limit and practical quantitation level shall be reported as trace.
4. Test Method to be EPA Method 1638/200.8 or an equivalent method approved by the Regional Board with a practical quantitation limit no greater than 3 µg/L. All concentrations between the detection limit and practical quantitation level shall be reported as trace.
5. Field Measurements.
6. Parameters shall be analyzed using the analytical methods described in 40 CFR sections 136.
7. For R-010 and R-011, monitor only when a continuous discharge is occurring from M-011 and/or M-015.

In conducting the receiving water sampling, a log shall be kept of the receiving water conditions throughout the reaches bounded by Stations R-001 and R-015. Attention shall be given to the presence or absence of:

- | | |
|---------------------------------|--|
| a. Floating or suspended matter | e. Visible films, sheens or coatings |
| b. Discoloration | f. Fungi, slimes, or objectionable growths |
| c. Bottom deposits | g. Potential nuisance conditions |
| d. Aquatic life | |

Notes on receiving water conditions shall be summarized in the monitoring report.

2. The Discharger shall monitor Morrison Creek R-012 and R-013 as follows:

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method[5]
Volatile Organics	µg/L	Grab	Monthly	[1]
Perchlorate	µg/L	Grab	Monthly	[2]
Total Copper	µg/L	Grab	Monthly	[3]
Temperature[4]	°F(°C)	Grab	Monthly	--
Dissolved Oxygen[4]	mg/L	Grab	Monthly	--
Turbidity	NTU	Grab	Monthly	--
Electrical Conductivity[4]	µmhos/cm	Grab	Monthly	--
pH[4]	Standard	Grab	Monthly	--
Hardness as CaCO ₃	mg/L	Grab	Quarterly	--
Total Dissolved Solids	mg/L	Grab	Monthly	--

1. Test Method to be EPA Methods 601 and 602 or 8010 and 8020 or 8260, or 500 Series, or an equivalent method approved by the Regional Board. with a Practical Quantitation Level no greater than 0.5 µg/L. All concentrations between the detection level and practical quantitation level shall be reported as trace.
2. Test Method to be EPA Methods 314.0 or 314.1, or an equivalent method approved by the Regional Board with a Practical Quantitation Level no greater than 4.0 µg/L. All concentrations between the detection limit and practical quantitation level shall be reported as trace.
3. Test Method to be EPA Method 1638/200.8 or an equivalent method approved by the Regional Board with a practical quantitation limit no greater than 3 µg/L. All concentrations between the detection limit and practical quantitation level shall be reported as trace.
4. Field Measurements.
5. Parameters shall be analyzed using the analytical methods described in 40 CFR sections 136.

In conducting the receiving water sampling, a log shall be kept of the receiving water conditions throughout the reach bounded by Stations R-012 and R-013. Attention shall be given to the presence or absence of:

- | | |
|---------------------------------|--|
| a. Floating or suspended matter | e. Visible films, sheens or coatings |
| b. Discoloration | f. Fungi, slimes, or objectionable growths |
| c. Bottom deposits | g. Potential nuisance conditions |
| d. Aquatic life | |

Notes on receiving water conditions shall be summarized in the monitoring report.

3. If no discharge occurs at a particular discharge point during the monitoring period, then receiving water samples associated with that discharge need not be collected for that monitoring period. It must be reported under the reporting program that no sampling was conducted at a particular monitoring point due to no discharge.

B. Groundwater Monitoring – Not Applicable

IX. OTHER MONITORING REQUIREMENTS

A. State Implementation Plan Monitoring

The State Water Resources Control Board (SWRCB) adopted the *Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California* (known as the State Implementation Policy or SIP). The SIP states that the Regional Water Boards will require periodic monitoring (at least once prior to issuance and reissuance of a permit) for pollutants for which criteria or objectives apply and for which no effluent limitations have been established.

Accordingly, the Regional Water Board is requiring, as part of this Monitoring and Reporting Program, that the Discharger monitor effluent and analyze the sample for all SIP constituents **one time at least 180 days but no more than 365 days prior to expiration of this Order**. The Discharger must analyze pH and hardness of the effluent at the same time as priority pollutant metals.

X. REPORTING REQUIREMENTS

A. General Monitoring and Reporting Requirements

1. The Discharger shall comply with all Standard Provisions (Attachment D) related to monitoring, reporting, and recordkeeping.
2. **Compliance Time Schedules.** For compliance time schedules included in the Order, the Discharger shall submit to the Regional Water Board, on or before each compliance due date, the specified document or a written report detailing compliance or noncompliance with the specific date and task. If noncompliance is reported, the Discharger shall state the reasons for noncompliance and include an estimate of the date when the Discharger will be in compliance. The Discharger shall notify the Regional Water Board by letter when it returns to compliance with the compliance time schedule.
3. The Discharger shall report to the Regional Board any toxic chemical release data it reports to the State Emergency Response Commission within 15 days of reporting the data to the Commission pursuant to section 313 of the "Emergency Planning and Community Right to Know Act of 1986.
4. **Within 24-hours** after the Discharger has received information that its discharge exceeds effluent limitations, or if operational monitoring of the treatment facilities indicates that there is a potential for effluent limitations to be exceeded, the Discharger shall notify the Board, City of Sacramento Department of Utilities, the Freeport Regional Water Authority and Carmichael Water District. Arden-Cordova Water Service and the Bureau of Reclamation shall be notified if the discharge that is in violation is to Alder Creek, tributary to Lake Natoma.

B. Self Monitoring Reports (SMRs)

1. At any time during the term of this permit, the State or Regional Water Board may notify the Discharger to electronically submit self-monitoring reports. Until such notification is given, the Discharger shall submit self-monitoring reports in accordance with the requirements described below.
2. The Discharger shall submit monthly Self Monitoring Reports including the results of all required monitoring using USEPA-approved test methods or other test methods specified in this Order. Monthly reports shall be due on the 15th day of the second month following the end of each calendar month.
3. Monitoring periods and reporting for all required monitoring shall be completed according to the following schedule:

Sampling Frequency	Monitoring Period Begins On...	Monitoring Period	SMR Due Date
Continuous	Day after permit effective date	All	Fifteenth day of second calendar month following month of sampling
1 / week	Sunday following permit effective date or on permit effective date if on a Sunday	Sunday through Saturday	Fifteenth day of second calendar month following month of sampling
1 / month	First day of calendar month following permit effective date or on permit effective date if that date is first day of the month	1 st day of calendar month through last day of calendar month	Fifteenth day of second calendar month following month of sampling
1 / quarter	Closest of January 1, April 1, July 1, or October 1 following (or on) permit effective date	January 1 through March 31 April 1 through June 30 July 1 through September 30 October 1 through December 31	May 15 August 15 November 15 February 15
1/year	January 1 following (or on) permit effective date	January 1 through December 31	February 15

4. The Discharger shall report with each sample result the applicable Minimum Level (ML) and the current Method Detection Limit (MDL), as determined by the procedure in 40 CFR Part 136.
5. The Discharger shall arrange all reported data in a tabular format. The data shall be summarized to clearly illustrate whether the facility is operating in compliance with interim and/or final effluent limitations.
6. The Discharger shall attach a cover letter to the SMR. The information contained in the cover letter shall clearly identify violations of the WDRs; discuss corrective actions taken or planned; and the proposed time schedule for corrective actions.

Identified violations must include a description of the requirement that was violated and a description of the violation.

8. SMRs must be submitted to the Regional Water Board, signed and certified as required by the standard provisions (Attachment D), to the address listed below:

Submit monitoring reports to: Central Valley Regional Water Quality Control Board 11020 Sun Center Drive #200 Rancho Cordova, CA 95670-6114
--

C. Discharge Monitoring Reports (DMRs)

1. When requested by U.S. EPA, the Discharger shall complete and submit Discharge Monitoring Reports. The submittal date shall be no later than the submittal date specified in the Monitoring and Reporting Program for Discharger Self Monitoring Reports.
2. DMRs must be signed and certified as required by the standard provisions (Attachment D). The Discharge shall submit the original DMR and one copy to the address listed below:

State Water Resources Control Board
Discharge Monitoring Report Processing Center
Post Office Box 671
Sacramento, CA 95812

3. All discharge monitoring results must be reported on the official USEPA pre-printed DMR forms (EPA Form 3320-1). Forms that are self generated or modified cannot be accepted.

D. Other Reports

1. **Annual Solids Disposal Report.** An annual solids disposal report shall be submitted with annual self-monitoring reports. The report shall describe the annual volume of solids, including spent ion exchange resin and granular activated carbon, generated by the Facility and specify the disposal practices.

Attachment F – Fact Sheet – Table of Contents

Attachment F – Fact Sheet 3

I. Permit Information 3

II. Facility Description 5

 A. Description of Wastewater and Biosolids Treatment or Controls 6

 B. Discharge Points and Receiving Waters 9

 C. Summary of Existing Requirements and Self-Monitoring Report (SMR) Data 9

 D. Compliance Summary – Not Applicable 13

 E. Planned Changes 13

III. Applicable Plans, Policies, and Regulations 13

 A. Legal Authorities 14

 B. California Environmental Quality Act (CEQA) 14

 C. State and Federal Regulations, Policies, and Plans 14

 D. Impaired Water Bodies on CWA 303(d) List 18

 E. Other Plans, Policies and Regulations – Not Applicable 18

IV. Rationale For Effluent Limitations and Discharge Specifications 18

 A. Discharge Prohibitions 20

 B. Technology-Based Effluent Limitations 20

 1. Scope and Authority 20

 2. Applicable Technology-Based Effluent Limitations 20

 3. Final Technology-Based Effluent Limitations 21

 C. Water Quality-Based Effluent Limitations (WQBELs) 22

 1. Scope and Authority 22

 2. Applicable Beneficial Uses and Water Quality Criteria and Objectives 23

 3. Determining the Need for WQBELs 24

 4. WQBEL Calculations 26

 5. Whole Effluent Toxicity (WET) 28

 D. Final Effluent Limitations 29

 E. Interim Effluent Limitations – Not Applicable 30

 F. Land Discharge Specifications – Not Applicable 31

 G. Reclamation Specifications – Not Applicable 31

V. Rationale for Receiving Water Limitations 31

 A. Surface Water 31

 B. Groundwater 33

VI. RationaleE for Monitoring and Reporting Requirements 33

 A. Influent Monitoring 33

 B. Effluent Monitoring 33

 C. Whole Effluent Toxicity Testing Requirements – Not Applicable 33

 D. Receiving Water Monitoring 33

 1. Surface Water – Not Applicable 33

 2. Groundwater 33

 E. Other Monitoring Requirements 34

 1. Solids Disposal Monitoring 34

VII. Rationale for Provisions 34

 A. Standard Provisions 34

B.	Special Provisions.....	34
1.	Reopener Provisions	34
2.	Special Studies and Additional Monitoring Requirements	32
3.	Best Management Practices and Pollution Prevention	38
4.	Compliance Schedules – Not Applicable	38
5.	Construction, Operation, and Maintenance Specifications	38
6.	Special Provisions for Municipal Facilities (POTWs Only) – Not Applicable	38
7.	Other Special Provisions	38
VIII.	Public Participation	38
A.	Notification of Interested Parties	38
B.	Written Comments	39
C.	Public Hearing	39
D.	Waste Discharge Requirements Petitions.....	39
E.	Information and Copying.....	40
F.	Register of Interested Persons	40
G.	Additional Information	40

ATTACHMENT F – FACT SHEET

As described in Section II of this Order, this Fact Sheet includes the legal requirements and technical rationale that serve as the basis for the requirements of this Order.

I. PERMIT INFORMATION

The following table summarizes administrative information related to the facility.

WDID	5A342000006
Discharger	Aerojet-General Corporation
Name of Facilities	ARGET, GET E/F, GET H, GET J, GET K-A, GET L-A, GET L-B, Sailor Bar Park Well, Chettenham Well, Golden State Wells – AC-6, AC-18 and AC-23
Facility Address	Aerojet Road
	Sacramento, CA 95813-6000
	Sacramento County
Facility Contact, Title and Phone	Chris Fennessy, Project Manager, (916) 355-3341
Authorized Person to Sign and Submit Reports	Scott Goulart, Director Environmental Operations, (916) 355-3558
Mailing Address	P.O. Box 13222, Sacramento, CA 95813-6000
Billing Address	P.O. Box 13222, Sacramento, CA 95813-6000
Type of Facility	Groundwater Extraction and Treatment Facilities
Major or Minor Facility	Minor
Threat to Water Quality	2
Complexity	B
Pretreatment Program	Not Applicable
Reclamation Requirements	Not Applicable
Facilities Permitted Flow	39.09 million gallons per day (mgd)
Facilities Design Flow	Not Applicable
Watershed	American and Sacramento Rivers
Receiving Water	Buffalo Creek, Morrison Creek, American River, Alder Creek, Sailor Bar Park Pond
Receiving Water Type	Stream and Pond

- A. Aerojet-General Corporation (Aerojet) operates a rocket testing and chemical manufacturing facility on 8500 acres in eastern Sacramento County. In order to address groundwater pollution beneath and beyond the Aerojet property, Aerojet has constructed many groundwater extraction and treatment facilities (GETs). The GET facilities covered under this permit are on both Aerojet-owned property and property leased by Aerojet. Aerojet is responsible for maintaining compliance with this Order and is responsible for the Facilities' operations and discharge to surface waters
- B. The Facilities discharge to Buffalo Creek, drainage canals, Alder Creek (potential discharge conditioned on completion of acceptable studies) and Sailor Bar Park Pond,

all tributary to the American River, and to Morrison Creek, tributary to the Sacramento River, waters of the United States. The Facilities are existing facilities regulated by a Regional Water Board Order.

- C. The Discharger submitted a Report of Waste Discharge (RWD), dated 11 April 2005, and applied for a National Pollutant Discharge Elimination System (NPDES) permit authorization to discharge up to 32.57 mgd of treated groundwater from the Aerojet GET facilities. Supplemental Information was received on 28 April, 12 May and 15 May 2005. In addition, on 9 July 2007, the Discharger submitted a request to revise the effluent limitation for NDMA for GETs J, K-A, L-A, and L-B. The previous version of the permit had an interim limit for NDMA for GET J, and GETs K, L-A and L-B had not been completed at the time of issuance of the permit. The interim effluent had an expiration date of 1 January 2008. The Discharger performed an evaluation of the technical and economic ramifications of treating NDMA to concentrations less than 0.010 µg/L. The permit was revised with the adoption of Order No. R5-2007-0165 based on that evaluation supplied by the Discharger and reviewed by staff from the Regional Board, United States Environmental Protection Agency, and Department of Toxic Substances Control.

In 2008, the Discharger requested a revision to the effluent limitation for trichloroethylene (TCE) for the GET E/F discharge (Discharge 002). The combination of treatment technologies at the GET E/F system, utilizing the best available technologies for removal of volatile organics (which includes TCE), NDMA and perchlorate was demonstrated to not consistently meet the effluent limitation for TCE due to low concentrations of biosolids carryover from the perchlorate treatment system. The original effluent limitations for TCE were 0.5 µg/L for the monthly average and 0.7 µg/L for the daily maximum. The Primary Maximum Contaminant Level for TCE is 5.0 µg/L and the California Public Health Goal (one-in-a-million excess cancer risk) has been established by the California Office of Health Hazard Assessment at 1.7 µg/L. Resolution No. R5-2009-0016 revised the Effluent Limitation for TCE for GET E/F to 1.5 µg/L. None of the other discharges covered by the Order were modified.

On 21 May 2009, the Discharger submitted a revised RWD requesting the addition of three new discharges. The discharges are from treatment systems added to three of Golden State Water Company's water supply wells. The treatment systems are designed to remove perchlorate from the water prior to it being placed in the water supply distribution system. For the initial two to four months of operation the discharge from the treatment systems will be to the storm drainage system. Following the initial operating period, two (AC-18 and AC-23) of the three wells will be operated on an on-demand basis with the only discharges occurring for 2-4 minutes during well startup and shutdown to avoid unacceptable pressure issues within the distribution system. The third well (AC-6) will be operated on a continuous basis and will discharge to the storm drain during periods when the water is not need for municipal purposes. This permit has been modified to include those three new treatment systems. In addition, several minor modifications were made regarding nomenclature of the treatment facilities, moving the GET L-A discharge 1,900 feet west of the original proposed location, and

moving the discharge from GET K-A from Outfall 003 to Outfall 004 in response to a request from the City of Rancho Cordova.

Since adoption of the previous version of the permit, Order No. R5-2010-0039, the Discharger has constructed the three treatment systems on the three municipal supply wells, AC-6, AC-18 and AC-23 and commenced operation of the AC-6 well system. The construction and potential operation of the three systems has changed from what was anticipated in the 2010 revision to this permit. During initial testing of the treatment systems for AC-18 and AC-23 it was noted that fine particles entered the system during the first 10 minutes of startup of the water supply well. In order to prevent clogging of the ion exchange resin, the two systems will be plumbed to allow the fines to dissipate prior to sending the water through the resin. Those first few minutes of flow will be discharged to the storm drain.

As these discharges are not through the treatment system, the discharges during startup and shutdown of the wells are considered well purging and covered under Discharge Point 12 of this permit. Generally during well startup and shutdown, the discharge occurs for 1 to 3 minutes, but may be up to 15 -20 minutes at AC-18 and AC-23 to minimize the concentration of fines. Subsequent discharges that are not during well startup and shutdown are covered under Discharge Point 13 for AC-6, Discharge Point 14 for AC-18 and Discharge Point 15 for AC-23.

In addition to the discharges during operation of the wells, there will be discharges of water during resin exchange. This discharge occurs during draining of the vessel, rinsing the vessel and adding the new resin. These discharges are generally of low volume (1000-8000 gallons) and occur infrequently. Thus, these discharges are low threat and are covered under Discharge Point 12. There could be instances when the flow occurs for 24-48 hours the event that bacteria are detected following resin change-out. This is within the limitations specified in Discharge Point 12.

II. FACILITIES DESCRIPTIONS

The Facilities are found both on and off Aerojet's 8500 acres in eastern Sacramento County, approximately 17 miles east of downtown Sacramento, in and around the City of Rancho Cordova, Sacramento County, as shown in Attachment B.

According to the Discharger's RWD, the Facilities treat extracted groundwater primarily containing volatile organics (VOCs) and/or perchlorate and/or N-nitrosodimethylamine (NDMA) and or 1,4-dioxane. The identified VOCs primarily include trichloroethylene (TCE), chloroform, vinyl chloride (VC), 1,2-dichloroethylene (1,2-DCE), 1,1-dichloroethylene (1,1-DCE), and tetrachloroethylene (PCE). These pollutants originated, for the most part, from historical rocket-testing and chemical manufacturing operations on the Aerojet site. Various treatment methods are used to reduce the pollutants down to acceptable levels prior to discharge

A. Description of Wastewater and Biosolids Treatment or Controls

1. VOCs can be easily removed from the extracted groundwater using a variety of treatment processes. Aerojet uses air-stripping, carbon adsorption (GAC) and ultraviolet or ozone oxidation in different combinations to remove the VOCs. At GET facilities that have high concentrations of VOCs Aerojet uses ultraviolet oxidation/hydrogen peroxide or oxidation using ozone, to destroy a majority of the VOCs, utilizing air stripping or GAC to remove residual VOCs. For lower concentrations of VOCs, GAC alone is utilized. Spent GAC is trucked to a permitted destruction facility.
2. Perchlorate is removed from the extracted groundwater using either biological reduction or ion-exchange. Biological reduction is performed by growing bacteria on carbon or sand in a fluidized bed reactor. Ethanol is injected into the influent to provide food for the bacteria. The bacteria will remove oxygen and nitrate prior to destroying the perchlorate. Biosolids are generated as bacteria material is removed from the system. The biosolids are collected on continuously cleaning sand filters. The backwash water proceeds through a clarifier to remove the solids prior to discharge. The solids collected in the clarifier are trucked to the sanitary sewer and the supernatant off of the clarifier is returned to the treatment process. The ion-exchange process uses a perchlorate-specific ion exchange resin that is disposed of when the resin's capacity for taking up perchlorate is exhausted. The resin is then replaced with fresh resin and the spent resin taken to a permitted disposal facility.
3. Removal of NDMA is accomplished using ultraviolet light oxidation in combination with hydrogen peroxide. This process is highly energy and concentration dependent. Hydrogen peroxide can be added to this process to oxidize VOCs. The Discharger has demonstrated that 0.007 µg/L is the technical and cost effective effluent level (Best Available/Cost Effective Technology (BACT)) for GETs J, K-A, L-A and L-B.
4. ARGET Facility. The American River Study Area (ARSA) treatment system is on the Aerojet site. The facility was constructed in 1997 and originally consisted of ultraviolet/hydrogen peroxide treatment to reduce concentrations of volatile organic compounds (VOCs) and 1,4-dioxane, and air-stripping to remove any remaining VOCs. This facility has been shown to remove VOCs to below detection levels (0.5 µg/L) and 1,4-dioxane to below its detection level (2-10 µg/L). This facility is designed to treat up to 3500 gallons per minute (gpm). Aerojet modified the VOC-removal portion of the facility to utilize ozone/hydrogen peroxide to remove the chlorinated ethenes VOCs and 1,4-dioxane at a lower cost than the ultraviolet light system. Treatment for removal of low concentrations of perchlorate may be required in the future as additional flow from new extraction wells are brought to the facility and the influent concentrations of perchlorate potentially increase.
5. GET E/F Facility. The GET E/F facility is also on Aerojet property. GET E and GET F were originally constructed in the mid-1980's and were subsequently combined

into one facility in 2000. The combined facility uses biological reduction to remove perchlorate, ultraviolet light/hydrogen peroxide to destroy NDMA and most of the VOCS, and air stripping to remove the remainder of VOCs from up to 6000 gpm of influent. There is also a sand filter and clarifier for solids control. The solids from the clarifier are discharged to the sanitary sewer under a wastewater discharge permit with the Sacramento Regional County Sanitation District (SRCSD). The treatment process has been shown to be effective in removing VOCs to below detection levels (0.5 µg/L), perchlorate to below 4 µg/L, and NDMA to below detection (0.002 –0.0075 µg/L). Testing of the influent and effluent of the treatment facility for full-scan analysis, including tentatively identified compound analysis, did not indicate additional contaminants of concern.

6. GET H-A Facility. The interim GET H facilities are no longer active and have been dismantled. The water from the GET H extraction wells is now treated at the GET H-A facility on Mather Field. The GET H-A system utilizes ion-exchange resin adsorption to remove perchlorate to less than 4 µg/L, and granular activated carbon (GAC) to remove VOCs to less than 0.5 µg/L, treating a flow of approximately 2000 gpm of extracted groundwater. The GET H-A system came on-line in summer 2006 and is in the north-central section of Mather Field. The GET H-A facility has been able to consistently meet effluent limitations.
7. GET J Facility. The GET J facility is similar to GET H, but with the addition of ultraviolet treatment for the designed destruction of NDMA to less than 0.002 µg/L and particulate filtration to help the ultraviolet system. The system is designed to treat 4150 gpm and is found on Pyrites Way in Gold River. The GET J facility has been shown to be capable of consistently meeting effluent limitations, though it has had difficulty meeting the NDMA effluent limitation utilizing only ultraviolet light and has incurred a large expense in meeting the limit. As discussed above, and in more detail below, Aerojet performed an evaluation of the ability to technically and effectively remove NDMA down to 0.002 µg/L. The evaluation has led to a revision to the effluent limitation to 0.007 µg/L. This revised effluent limitation is also being applied to the GET K-A, GET L-A and GET L-B treatment systems.
8. GET K-A Facility. The interim GET K facility is no longer being used. The water from the GET K extraction wells is being treated at the GET K-A facility on Coloma Road. The GET K-A system commenced operation in June 2009 and utilizes GAC to remove VOCs, ion exchange to remove perchlorate and ultraviolet light radiation, hydrogen peroxide addition, and particulate removal for treatment of NDMA and trace VOCs from approximately 2880 gpm of extracted groundwater. The facility has sufficient space and existing plumbing connections to quickly add on perchlorate treatment should influent perchlorate concentrations increase over time.
9. GET L-A Facility. GET L-A is currently being constructed and will be in Carmichael, at Ancil Hoffman Park. The facility will initially treat for NDMA using ultraviolet light. If, in the future, VOCs and/or perchlorate are determined to be approaching the extraction wells in the groundwater, VOC and/or perchlorate treatment will be added

utilizing the same processes described above for GET J. Flow to the plant, anticipated to commence operation in 2010, is 2000 gpm. The discharge from the treatment facility will be to the golf course at Ancil Hoffman Park whenever possible. During times when the water is not needed at the golf course the water will be discharged to the American River.

10. GET L-B Facility. GET L-B has been constructed in order to reduce pipeline lengths from extraction wells to the GET L-A facility. A portion of the extracted flow in the Carmichael area (estimated to be 900 gpm) is sent to the GET L-B facility for processing using the same type of treatment as GET L-A.
11. Sailor Bar Park Facility. The Sailor Bar Park system provides for removal of VOCs by GAC on a water supply well that is used to maintain the water elevation in the pond on Sailor Bar Park. The flow through the treatment plant is intermittent and is a maximum of 250 gpm. The park is on the north side of the American River, approximately ½ mile west of Hazel Avenue.
12. Chettenham Facility. Aerojet negotiated with California American Water Company (CalAm), owner of the Chettenham Well, to use the well on an interim basis to evaluate plume control by the extraction field with the well pumping and to evaluate the well as an extraction point to control the movement of a portion of the groundwater pollution. Wellhead treatment consisting of ion exchange for perchlorate removal was installed on the well and the discharge is to the Boyd Station Drainage Channel. Concentrations of perchlorate have dropped from an initial concentration of over 90 µg/L to less than 4 µg/L, the effluent limitation for the discharge. Aerojet will continue to operate the well to verify declining concentrations and effect on the extraction well field. If concentrations are near or above 6 µg/l, the current MCL, Aerojet will operate the treatment system with an effluent limitation of 4 µg/L. If concentrations remain low, then the treatment system will not be operated and the effluent limitation will be 6 µg/L.
13. Golden State Water Supply Well Treatment Facilities. Three water supply wells operated by the Golden State Water Company, AC-6, AC-18 and AC-23 are being equipped by Aerojet with ion exchange systems to remove perchlorate. In the regular operation mode, AC-6 will be generally operated on an on-demand basis, but could also be operated on a continuous basis. Treated water not needed at the time for municipal purposes during continuous operation will be discharged to the storm drain. For regular operations the other two wells will be operated on an on-demand basis. The only time that the discharge would occur is for 2-4 minutes during well startup and shutdown to minimize pressure issues within the water distribution system. Discharges from AC-6 will also occur during startup and shutdown of the wells and these short-term discharges are done under the well purge operations described below in A.14.
14. Groundwater Extraction Well Aquifer Test Water and Well purge and development water. After construction of an extraction well Aerojet will perform an aquifer test on

the well for up to 4 days. The purpose of the test is to provide information that will allow design of a GET system for treatment of water generated by an extraction field. The aquifer test water is passed through a portable treatment system designed using the type of treatment systems described above to remove the suspected pollutants. Under the previous permit, Aerojet was able to meet consistently meet effluent limitations with the portable system. Aerojet also develops and purges monitor wells prior to sampling. Treatment is applied as needed to remove the pollutants. Discharges also covered under these low-threat discharges include discharges from the startup and shutdown of water supply wells AC-6, AC-18 and AC-23, and discharges from the treatment systems for those wells related to changing the ion exchange resin.

B. Discharge Points and Receiving Waters

1. Treated groundwater is discharged from Discharges 001, 002 and 005 (respectively, ARGET, GET E/F, GET J) to Buffalo Creek (tributary to the American River). Discharges 004 and 014 (GET H-A and AC-18, respectively) are to Morrison Creek (tributary to the Sacramento River). Discharges 007 (GET K-A), 008 (GET L-A), 009 (GET L-B), 011 (Chettentham Well), 013 (AC-6) and 015 (AC-23) are to drainage channels to the American River between the Sunrise Boulevard and Watt Avenue over crossings. Discharge 010 (Sailor Bar Park) is to a pond in Sailor Bar Park, with a potential for overflow to the American River. Sacramento County requested during development of the previous permit to allow for the potential discharge from some or all of the GETs covered in this permit to Alder Creek and/or the Natomas Stilling Basin, to assist in their reuse of treated groundwater. The previous permit and this permit included a provision allowing for the discharge to Alder Creek/Natomas Stilling Basin pending completion of an acceptable study of the potential thermal impacts on Alder Creek/American River, including a mixing zone study, and potential impacts on the Nimbus Fish Hatchery. In addition, in the future the effluent from the GET H-A discharge (004) may be piped to the Boyd Station Channel in order to better accommodate reuse projects for the water.

C. Summary of Existing Requirements and Self-Monitoring Report (SMR) Data

1. Effluent limitations/Discharge Specifications contained in the existing Order for discharges from Discharge Points 001 through 011 and representative monitoring data since July 1998 through November 2009 are as follows:

Parameter (units)	Average Monthly	Maximum Daily	Highest Average Monthly Discharge	Highest Daily Discharge
1,4-dioxane (µg/L)	3	10	<3	<3
Perchlorate (µg/L)	4	8	<4	7
Copper (µg/L)	11	17	29	29

Parameter (units)	Average Monthly	Maximum Daily	Highest Average Monthly Discharge	Highest Daily Discharge
N-nitrosodimethylamine (µg/L)	0.002	0.005	0.001	0.0023
Trichloroethylene (µg/L)	--	0.5	0.7	1.4
1,2-Dichloroethane (µg/L)	0.38	0.5	0.25	0.45
Acetaldehyde (µg/L)	--	5	5.0	7.0
Formaldehyde (µg/L)	--	50	30	36

2. The RWD and Aerojet Monitoring describe the discharges as follows:

ARGET

<u>Constituent</u>	<u>Units</u>	<u>Maximum Daily</u>
Flow	mgd	4.96
pH	Standard Units	7.8-8.3
COD	mg/L	<3
Total Suspended Solids	mg/L	<6
Chlorides	mg/L	15
Sulfate	mg/L	12
Manganese	mg/L	0.02
Aluminum	mg/L	<0.030
Iron	mg/L	<0.040
Zinc	mg/L	0.020
Arsenic	mg/L	<0.002
Lead	mg/L	<0.005
Hardness (as CaCO ₃)	mg/L	130
Barium	mg/L	0.07
Copper	mg/L	0.027
Chromium	mg/L	<0.002
Nickel	mg/L	<0.005
All VOCs	mg/L	<0.0005
Perchlorate	mg/L	0.007

GET E/F

<u>Constituent</u>	<u>Units</u>	<u>Maximum Daily</u>
Flow	mgd	8.64
pH	Standard Units	7.2-8.2
COD	mg/L	<3
Total Suspended Solids	mg/L	<6
Chlorides	mg/L	6.6
Sulfate	mg/L	15
Manganese	mg/L	0.07
Aluminum	mg/L	<0.050
Iron	mg/L	0.050
Arsenic	mg/L	<0.002

<u>Constituent</u>	<u>Units</u>	<u>Maximum Daily</u>
Lead	mg/L	<0.002
Hardness (as CaCO ₃)	mg/L	110
Barium	mg/L	0.1
Copper	mg/L	<0.003
Chromium	mg/L	<0.002
Nickel	mg/L	<0.005
All VOCs	mg/L	<0.0005
Perchlorate	mg/L	<0.004
Zinc	mg/L	<0.050

GET H-A/CHETTENHAM WELL

<u>Constituent</u>	<u>Units</u>	<u>Maximum Daily</u>
Flow	mgd	3.96
pH	Standard Units	7.6-7.8
COD	mg/L	<3
Total Suspended Solids	mg/L	<6
Chlorides	mg/L	4.4
Sulfate	mg/L	3.3
Manganese	mg/L	0.07
Aluminum	mg/L	<0.050
Iron	mg/L	<0.050
Zinc	mg/L	<0.050
Arsenic	mg/L	<0.002
Lead	mg/L	<0.002
Hardness (as CaCO ₃)	mg/L	53
Barium	mg/L	0.046
Copper	mg/L	<0.003
Chromium	mg/L	<0.002
Nickel	mg/L	<0.005
All VOCs	mg/L	<0.0005
Perchlorate	mg/L	<0.004

GET J

<u>Constituent</u>	<u>Units</u>	<u>Maximum Daily</u>
Flow	mgd	5.98
pH	Standard Units	6.8-7.6
COD	mg/L	<3
Total Suspended Solids	mg/L	<6
Chlorides	mg/L	6.6
Sulfate	mg/L	15
Manganese	mg/L	0.07
Aluminum	mg/L	<0.050
Iron	mg/L	0.050
Zinc	mg/L	<0.050

<u>Constituent</u>	<u>Units</u>	<u>Maximum Daily</u>
Arsenic	mg/L	<0.002
Lead	mg/L	<0.002
Hardness (as CaCO ₃)	mg/L	160
Barium	mg/L	0.18
Copper	mg/L	<0.003
Chromium	mg/L	<0.002
Nickel	mg/L	<0.005
All VOCs	mg/L	<0.0005
Perchlorate	mg/L	<0.004

GET K-A

<u>Constituent</u>	<u>Units</u>	<u>Maximum Daily</u>
Flow	mgd	4.03
pH	Standard Units	7.7-7.8
COD	mg/L	<3
Total Suspended Solids	mg/L	<6
Chlorides	mg/L	4.4
Sulfate	mg/L	3.3
Manganese	mg/L	0.07
Aluminum	mg/L	<0.050
Iron	mg/L	0.050
Zinc	mg/L	<0.050
Arsenic	mg/L	<0.002
Lead	mg/L	<0.002
Hardness (as CaCO ₃)	mg/L	110
Barium	mg/L	0.110
Copper	mg/L	<0.003
Chromium	mg/L	<0.002
Nickel	mg/L	<0.005
All VOCs	mg/L	<0.0005
Perchlorate	mg/L	<0.004

GET L-A/L-B

<u>Constituent</u>	<u>Units</u>	<u>Maximum Daily</u>
Flow	mgd	4.32
pH	Standard Units	6.4-9.0
Chlorides	mg/L	6.4
Sulfate	mg/L	7.1
Manganese	mg/L	0.07
Aluminum	mg/L	<0.005
Iron	mg/L	0.050
Zinc	mg/L	<0.050
Arsenic	mg/L	<0.002

<u>Constituent</u>	<u>Units</u>	<u>Maximum Daily</u>
Lead	mg/L	<0.002
Hardness (as CaCO ₃)	mg/L	110
Barium	mg/L	0.18
Copper	mg/L	<0.003
Chromium	mg/L	<0.002
Nickel	mg/L	<0.005
All VOCs	mg/L	<0.0005
Perchlorate	mg/L	<0.004

D. Compliance Summary

ARGET, GET E/F, GET H-A, GET J and Sailor Bar Park Well discharges have been in substantial compliance with effluent limitations since the inception of the discharges from those facilities. There have been six detections of TCE in the GET E/F effluent at slightly above the effluent limitation of 0.50 µg/L (maximum 0.8 µg/L). These excursions were not verified by follow-up sampling by Aerojet or Regional Board staff. Other effluent limitation excursions were for exceedance of the daily maximum effluent limit for copper for the ARGET effluent. Four times since 2001 copper has been detected at up to 29 µg/L (limit of 17 µg/L). The effluent limitation does not allow for dilution in the receiving water. It was later determined that the sampling taps were made of brass. Since replacing the taps with ones made of stainless steel, there have been no excursions of copper above the effluent limitation. The effluent limitation for perchlorate was exceeded twice at the GET E/F facility due to failure of metering system feeding ethanol to the bioreactors. The system was fixed and additional fail-safe measurements were taken to reduce the potential for recurrence. There have been no violations of receiving water limitations for any of the discharges.

E. Planned Changes

As stated above in Sections II(A) and II(B), in order to more easily reuse the treated groundwater, Discharge 004 may be redirected to the Boyd Station Channel for ultimate discharge to the American River. Revision of the permit will be necessary prior to taking Discharge 004 to the Boyd Station Channel. The discharges from ARGET and/or GET E/F may also be redirected to the Natomas Stilling Basin or Alder Creek. Prior to doing so, a thermal impact study, including a mixing zone study and an assessment of the potential impacts to the Nimbus fish hatchery will need to be completed that demonstrates that there are no adverse impacts with discharging to the new location(s). The permit would then be reopened and the modified to specify the changes.

III. APPLICABLE PLANS, POLICIES, AND REGULATIONS

The requirements contained in the proposed Order are based on the requirements and authorities described in this section.

A. Legal Authorities

This Order is issued pursuant to section 402 of the Federal Clean Water Act (CWA) and implementing regulations adopted by the U.S. Environmental Protection Agency (USEPA) and Chapter 5.5, Division 7 of the California Water Code (CWC). It shall serve as a NPDES permit for point source discharges from these facilities to surface waters. This Order also serves as Waste Discharge Requirements (WDRs) pursuant to Article 4, Chapter 4 of the CWC for discharges that are not subject to regulation under CWA section 402.

B. California Environmental Quality Act (CEQA)

This action to adopt an NPDES permit is exempt from the provisions of the California Environmental Quality Act (Public Resources Code Section 21100, et seq.) in accordance with Section 13389 of the CWC. The Department of Toxic Substances Control certified a final Negative Declaration and Initial Study for the American River Study Area project in accordance with CEQA and State CEQA Guidelines. The Board has reviewed the negative declaration and these waste discharge requirements will mitigate or avoid any significant impacts on water quality due to the discharges from the ARGET facility.

C. State and Federal Regulations, Policies, and Plans

- 1. Water Quality Control Plans.** The Regional Water Board adopted a *Water Quality Control Plan for the Sacramento River and San Joaquin River Basins, Fourth Edition* (hereinafter Basin Plan) that designates beneficial uses, establishes water quality objectives, and contains implementation programs and policies to achieve those objectives for all waters addressed through the plan.

The Basin Plan at page II-2.00 states that the beneficial uses of any specifically identified water body generally applies to its tributary streams. The Basin Plan does not specifically identify beneficial uses for Buffalo Creek, Alder Creek or Sailor Bar Park Pond, but does identify present and potential uses for the American River, to which Buffalo Creek, Alder Creek and potentially Sailor Bar Park Pond are tributary. In addition the Basin Plan does not specifically identify beneficial uses for Morrison Creek, but does identify present and potential uses for the Sacramento River, to which Morrison Creek is tributary. These beneficial uses of the American and Sacramento Rivers are municipal and domestic supply (MUN); agricultural supply, irrigation and stock watering (AGR); water contact recreation (REC-1); non-contact water recreation (REC-2); warm freshwater habitat (WARM); cold freshwater habitat (COLD); warm and cold migration of aquatic organisms (MIGR); warm and cold spawning (SPWN); wildlife habitat (WILD). The Sacramento River has an additional designated beneficial use of navigation (NAV). In addition, State Water Resources Control Board (State Water Board) Resolution No. 88-63 requires that, with certain exceptions, the Regional Water Board assign the municipal and domestic supply use to water bodies that do not have beneficial uses listed in the Basin Plan. Thus, as

discussed in detail in this Fact Sheet, beneficial uses applicable to the American River, Buffalo Creek, Alder Creek, Morrison Creek and the Sailor Bar Park Pond are as follows:

Discharge Point	Receiving Water Name	Beneficial Use(s)
001, 002 and 005	Buffalo Creek and Alder Creek, Tributaries of the American River	<u>Existing:</u> MUN, AGR, IND, REC-1, REC-2, WARM, COLD, MIGR, SPWN, WILD.
004 and 014	Morrison Creek, Tributary of the Sacramento River	<u>Existing:</u> MUN, AGR, IND, REC-1, REC-2, WARM, COLD, MIGR, SPWN, WILD.
004, 007, 008, 009, 011, 013 and 015	American River	<u>Existing:</u> MUN, AGR, IND, REC-1, REC-2, WARM, COLD, MIGR, SPWN, WILD.
010	Sailor Bar Pond, Potentially tributary to American River	<u>Existing:</u> MUN, AGR, IND, REC-1, REC-2, WARM, COLD, WILD.

The Basin Plan on page II-1.00 states: “*Protection and enhancement of existing and potential beneficial uses are primary goals of water quality planning...*” and with respect to disposal of wastewaters states that “...disposal of wastewaters is [not] a prohibited use of waters of the State; it is merely a use which cannot be satisfied to the detriment of beneficial uses.”

The federal Clean Water Act, Section 101(a)(2), states: “it is the national goal that wherever attainable, an interim goal of water quality which provides for the protection and propagation of fish, shellfish, and wildlife, and for recreation in and on the water be achieved by July 1, 1983.” Federal Regulations, developed to implement the requirements of the Clean Water Act, create a rebuttable presumption that all waters be designated as fishable and swimmable. Federal Regulations, 40 CFR Sections 131.2 and 131.10, require that all waters of the State regulated to protect the beneficial uses of public water supply, protection and propagation of fish, shell fish and wildlife, recreation in and on the water, agricultural, industrial and other purposes including navigation. Section 131.3(e), 40 CFR, defines existing beneficial uses as those uses actually attained after November 28, 1975, whether or not they are included in the water quality standards. Federal Regulation, 40 CFR Section 131.10 requires that uses be obtained by implementing effluent limitations, requires that all downstream uses be protected and states that in no case shall a state adopt waste transport or waste assimilation as a beneficial use for any waters of the United States.

In reviewing whether the existing and/or potential uses of the American and Sacramento River apply to Buffalo Creek, Alder Creek, and Sailor Bar Park Pond, and Morrison Creek, respectively, the Regional Water Board has considered the following facts:

a. Domestic Supply and Agricultural Supply

The Regional Water Board is required to apply the beneficial uses of municipal and domestic supply to Buffalo Creek, Alder Creek, Morrison Creek and Sailor Bar Park Pond based on State Water Board Resolution No. 88-63 which was incorporated in the Basin Plan pursuant to Regional Water Board Resolution No. 89-056.

b. Water Contact and Noncontact Recreation and Esthetic Enjoyment

The Regional Water Board finds that the discharges flow through residential areas, there is ready public access to the receiving waters, exclusion of the public is unrealistic and contact recreational activities currently exist along Buffalo Creek, Alder Creek, Morrison Creek and Sailor Bar Park Pond and downstream waters. Prior to flowing into the American River, Buffalo Creek, Alder Creek and Morrison Creek flow through areas of general public access, meadows, and residential and commercial areas. Sailor Bar Park Pond is accessible to the public and is used for fishing. The American and Sacramento Rivers offer considerable recreational opportunities. Additionally, the Lower American River was designated a Wild and Scenic River in 1981 and is considered the most heavily used recreation river in California.

c. Preservation and Enhancement of Fish, Wildlife, and Other Aquatic Resources

Buffalo Creek, Alder Creek and the Sailor Bar Park pond flow to the American River. It is highly unlikely that the overflow from Sailor Bar Park would ever directly reach the American River due to the dredger tailings through which the overflow must traverse. However, there is a potential for the pond to indirectly discharge to the American River via a subsurface pathway. The Basin Plan (Table II-1) designates the American River as being both a cold and warm freshwater habitat; wildlife habitat; warm and cold migration of aquatic organisms; and warm and cold spawning, reproduction, and/or early development of freshwater organisms. The American River supports significant aquatic life, and therefore these beneficial uses apply to its tributaries. Morrison Creek flows to the Sacramento River. The Basin Plan (Table II-1) designates the Sacramento River below the American the confluence with American River as being both a cold and warm freshwater habitat; wildlife habitat; warm and cold migration of aquatic organisms; and warm spawning, reproduction, and/or early development of freshwater organisms. The Sacramento River supports significant aquatic life, and therefore these beneficial uses apply to its tributaries

Upon review of the flow conditions, habitat values, and beneficial uses of Buffalo Creek and Alder Creek, and Morrison Creek, and the facts described above, the Regional Water Board finds that the beneficial uses identified in the Basin Plan for the American River and Sacramento River are applicable to Buffalo Creek and Alder

Creek, and Morrison Creek, respectively, in the vicinity of the discharges. Given the location of the Sailor Bar Park Pond, the beneficial uses of SPWN and MIGR are not applicable.

2. **Thermal Plan.** The State Water Board adopted a *Water Quality Control Plan for Control of Temperature in Coastal and Interstate Waters and Enclosed Bays and Estuaries of California* (Thermal Plan) on May 18, 1972, and amended this plan on September 18, 1975. This plan contains temperature objectives for inland surface waters.
3. **National Toxics Rule (NTR) and California Toxics Rule (CTR).** USEPA adopted the NTR on December 22, 1992, which was amended on May 4, 1995 and November 9, 1999, and the CTR on May 18, 2000, which was amended on February 13, 2001. These rules include water quality criteria for priority pollutants and are applicable to this discharge.
4. **State Implementation Policy.** On March 2, 2000, State Water Board adopted the *Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California* (State Implementation Policy or SIP). The SIP became effective on April 28, 2000, with respect to the priority pollutant criteria promulgated for California by the USEPA through the NTR and to the priority pollutant objectives established by the Regional Water Boards in their basin plans, with the exception of the provision on alternate test procedures for individual discharges that have been approved by USEPA Regional Administrator. The alternate test procedures provision was effective on May 22, 2000. The SIP became effective on May 18, 2000. The SIP includes procedures for determining the need for and calculating water quality-based effluent limitations (WQBELs), and requires Dischargers to submit data sufficient to do so.
5. **Compliance Schedules and Interim Requirements.** In accordance with Section 2.1 of the SIP, compliance schedules and interim requirements may only be granted to existing discharges. One of the existing discharges, ARGET (Discharge 001), has a compliance schedule and associated interim requirements.

The ARGET facility currently has 4 to 6 µg/L perchlorate in the influent to the facility. Concentrations of perchlorate have historically been as high as 8 µg/L in the effluent. The previous effluent limit was 12 µg/L perchlorate as it was determined not to be cost effective to reduce the concentrations from 8 µg/L to 4 µg/L and there was significant dilution available in the American River. The Discharger has proposed adding additional groundwater extraction wells in the future, with treatment at the ARGET facility. Those additional extraction wells currently are treated at the GET D facility, with discharge to land. The influent at the GET D facility contains approximately 200 µg/L perchlorate. Prior to adding those extraction wells the Discharger will add facilities to remove perchlorate at ARGET if the influent is projected to exceed 6 µg/L. Once the treatment facilities are added, the Discharger will be able to meet the same effluent limits established for the other GET facilities.

Therefore, interim effluent limits (until December 2012) for perchlorate are established at 8 µg/L for daily maximum and monthly averages. In the interim, mixing of the ARGET effluent with the effluent from GETE/F in Buffalo Creek (<4 µg/L perchlorate) will keep the perchlorate concentration below the WQO for perchlorate of 6 µg/L.

6. **Antidegradation Policy.** The permitted discharge is consistent with the antidegradation provisions of 40 CFR 131.12 and State Water Resources Control Board Resolution 68-16. Compliance with these requirements will result in the use of best practicable treatment or control of the discharge. The impact on existing water quality will be insignificant.
7. **Anti-Backsliding Requirements.** Sections 402(o)(2) and 303(d)(4) of the CWA and 40 CFR Section 122.44(l) prohibit backsliding in NPDES permits. These anti-backsliding provisions require that effluent limitations in a reissued permit must be as stringent as those in the previous permit, with some exceptions in which limitations may be relaxed. The effluent limits are at least as stringent as those in contained in the previous order. There are new facilities added in this permit, therefore anti-backsliding provisions do not apply to those new facilities.

D. Impaired Water Bodies on CWA 303(d) List

1. The Basin Plan includes a list of Water Quality Limited Segments (WQLSs), which are defined as “...*those sections of lakes, streams, rivers or other fresh water bodies where water quality does not meet (or is not expected to meet) water quality standards even after the application of appropriate limitations for point sources (40 CFR 130, et seq.)*.” The Basin Plan also states, “*Additional treatment beyond minimum federal standards will be imposed on dischargers to WQLSs. Dischargers will be assigned or allocated a maximum allowable load of critical pollutants so that water quality objectives can be met in the segment.*” The listing for the western portion Sacramento-San Joaquin Delta waterways includes: diazinon and chlorpyrifos, organo-chlorine Group A pesticides, mercury, and unknown toxicity. The listing for the American River includes mercury and unknown toxicity. There have been no detections of mercury, diazinon, chlorpyrifos, or organo-chlorine Group A pesticides in the effluent from the GETs nor in the plumes of groundwater pollution captured by the GETs. Buffalo Creek, Alder Creek and Morrison Creek are not listed on the 303(d) list.

E. Other Plans, Policies and Regulations – Not Applicable

IV. RATIONALE FOR EFFLUENT LIMITATIONS AND DISCHARGE SPECIFICATIONS

Effluent limitations and toxic and pretreatment effluent standards established pursuant to Sections 301 (Effluent Limitations), 302 (Water Quality Related Effluent Limitations), 304 (Information and Guidelines), and 307 (Toxic and Pretreatment Effluent Standards) of the Clean Water Act (CWA) and amendments thereto are applicable to the discharge.

The federal Clean Water Act (CWA) mandates the implementation of effluent limitations that are as stringent as necessary to meet water quality standards established pursuant to state or federal law. (33 U.S.C., Section 1311(b)(1)(C); 40 C.F.R., Section 122.44(d)(1)) NPDES permits must incorporate discharge limits necessary to ensure that water quality standards are met. This requirement applies to narrative criteria as well as to criteria specifying maximum amounts of particular pollutants. Pursuant to Federal Regulations, 40 C.F.R. section 122.44(d)(1)(i), NPDES permits must contain limits that control all pollutants that “*are or may be discharged at a level which will cause, have the reasonable potential to cause, or contribute to an excursion above any state water quality standard, including state narrative criteria for water quality.*” Federal Regulations, 40 CFR, Section 122.44(d)(1)(vi), further provide that “[w]here a state has not established a water quality criterion for a specific chemical pollutant that is present in an effluent at a concentration that causes, has the reasonable potential to cause, or contributes to an excursion above a narrative criterion within an applicable State water quality standard, the permitting authority must establish effluent limits.”

The Regional Water Board’s Basin Plan, page IV-17.00 contains an implementation policy (“Policy for Application of Water Quality Objectives”) that specifies that the Regional Water Board “*will, on a case-by-case basis, adopt numerical limitations in orders which will implement the narrative objectives.*” This Policy complies with 40 CFR 122.44(d)(1). With respect to narrative objectives, the Regional Water Board must establish effluent limitations using one or more of three specified sources, including EPA’s published water quality criteria, a proposed state criterion (*i.e.*, water quality objective), or an explicit state policy interpreting its narrative water quality criteria (*i.e.*, the Regional Water Board’s “Policy for Application of Water Quality Objectives”)(40 C.F.R. 122.44(d)(1) (vi) (A), (B) or (C)). The Basin Plan contains a narrative objective requiring that: “*All waters shall be maintained free of toxic substances in concentrations that produce detrimental physiological responses in human, plant, animal, or aquatic life*”. The Basin Plan requires the application of the most stringent objective necessary to ensure that surface water and groundwater do not contain chemical constituents, toxic substances, radionuclides, or taste and odor producing substances that adversely affect beneficial uses. The beneficial uses include MUN, AGR, REC-1, REC-2, WARM, COLD, MIGR, SPWN, and WILD. The Basin Plan states that material and relevant information, including numeric criteria, and recommendations from other agencies and scientific literature will be utilized in evaluating compliance with the narrative toxicity objective. The Basin Plan also limits chemical constituents in concentrations that adversely affect surface water beneficial uses. For waters designated as municipal, the Basin Plan specifies that, at a minimum, waters shall not contain concentrations of constituents that exceed Maximum Contaminant Levels (MCL) of CCR Title 22. The Basin Plan further states that, to protect all beneficial uses, the Regional Water Board may apply limits more stringent than MCLs. When a reasonable potential exists for exceeding a narrative objective, Federal Regulations mandate numerical effluent limitations and the Basin Plan clearly establishes a procedure for translating the narrative objectives into numerical effluent limitations.

A. Discharge Prohibitions

1. As stated in Section I.G of Attachment D, Federal Standard Provisions, this Order prohibits bypass from any portion of the treatment Facility. Federal Regulations, 40 CFR 122.41 (m), define “bypass” as the intentional diversion of waste streams from any portion of a treatment facility. This section of the Federal Regulations, 40 CFR 122.41 (m)(4), prohibits bypass unless it is unavoidable to prevent loss of life, personal injury, or severe property damage. In considering the Regional Water Board’s prohibition of bypasses, the State Water Resources Control Board adopted a presidential decision, Order No. WQO 2002-0015, which cites the Federal Regulations, 40 CFR 122.41(m), as allowing bypass only for essential maintenance to assure efficient operation. In the case of United States v. City of Toledo, Ohio (63 F. Supp 2d 834, N.D. Ohio 1999) the Federal Court ruled that “any bypass which occurs because of inadequate plant capacity is unauthorized...to the extent that there are ‘feasible alternatives’, including the construction or installation of additional treatment capacity”.

B. Technology-Based Effluent Limitations

1. Scope and Authority

- a. As specified in 40 CFR Section 122.44(a)(1), permits are required to include technology based effluent limitations

2. Applicable Technology-Based Effluent Limitations

- a. **Volatile Organic Compounds (VOCs).** The effluent limits for VOCs are based on Best Available Technology utilizing either air stripping or carbon adsorption which have been demonstrated to readily reduce VOCs to below 0.5 µg/L. The 0.5 µg/L effluent limitation is below the Water Quality Based Effluent Limits (WQBEL) calculated below for VOCs of concern, with the exception of 1,2-Dichloroethane. The WQBEL will be used for 1,2-Dichloroethane. Carbon adsorption and ultraviolet light are not entirely effective on the removal of chloroform at low concentrations. GET J has low concentrations of chloroform (1 µg/L) and relying on removal to 0.5 µg/L by carbon, increases the cost of operating GET J by over \$500,000 per year. The effluent limit for chloroform for GET J is set at 3 µg/L which will meet the WQBEL for chloroform of 1.1 µg/L in Buffalo Creek as it mixes with the effluents from GETs E/F and ARGET. The effluent limitation for TCE for GET E/F was modified in Order No. R5-2009-0016 to 1.5 µg/L based on the treatment systems in use at that facility. Utilizing the best available technologies for perchlorate, NDMA and VOCs at the GET E/F facility hinders the ability to consistently remove the TCE to 0.5 µg/L due to the presence of very low concentrations of suspended solids from the perchlorate removal system. The concentration within the receiving water and discharge remain below the Water Quality Objective for TCE of 1.7 µg/L. The proposed effluent limitations are consistent with those found in the existing Order.

- b. **Perchlorate.** The monthly average effluent limitation for perchlorate is established at 4 µg/L, a value that the Discharger, utilizing commercially available technology at GET E/F, GET H-A, GET J and Interim GET K-A, has shown to be capable of technically and economically meeting on a consistent basis. As discussed below in Section IV.C.3, the water quality based effluent limitation is 6 µg/L. Therefore, systems for perchlorate removal are not added until the perchlorate concentration in the influent is 6 µg/L or greater. Once the treatment system is added, the effluent limitation is 4 µg/L. This possibility is only applicable to ARGET, the Chettenham Well and the Golden State wells AC-18 and AC-23 at this time.
- c. **Flow.** This Order contains a maximum daily and long term average effluent limitations of 5.4 mgd for ARGET, 8.64 mgd for GET E/F, 6.39 mgd for GET H-A, 0.86 mgd for Chettenham, 7.17 mgd for GET J, 5.76 mgd for interim GET K-A, 2.88 mgd, 1.56 for GET L-A, 1.73 mgd for GET L-B, 0.36 mgd for Sailor Bar Park Well, 1.08 mgd for AC-6, 2.49 mgd for AC-18 and 3.17 mgd for AC- 23 based on the maximum daily effluent flows reported in Aerojet's RWD. In accordance with 40 CFR Section 122.45, this Order includes mass effluent limitations based on the long term average effluent flows listed above and reported in the Discharger's RWD.
- d. **NDMA.** Under a pervious permit, the Discharger performed a study on the technical and economic implications of treating NDMA at GET J to 0.002 µg/L, the effluent limitation found in the previous version of the permit. An interim effluent limit of 0.01 µg/L was established and the studies undertaken. The studies showed that there is a significant reduction in treatment efficiency below a concentration of 0.01 µg/L, and even less efficiency below 0.007 µg/L. It was estimated that there would be approximately \$50 million in increased costs (30-year net present worth) to reduce the effluent from 0.010 µg/l to 0.002 µg/L, assuming power cost per kilowatt/hour remained constant. The Discharger's study concluded that treating to 0.007 µg/L was both technically achievable and cost-effective for GET J and future GETs using the low-watt UV technology to remove NDMA from groundwater. Using an effluent limitation of 0.007 µg/L for GET J and the available dilution in Buffalo Creek provided by flows from GET E/F and ARGET, the WQBEL of 0.003 µg/L will be met in Buffalo Creek. Future discharges at Discharge Points 007, 008, and 009 will discharge directly to the American River with a minimum dilution of 50:1. A technology-based effluent limitation of 0.007 µg/l will meet the WQO in the American River.

3. Final Technology-Based Effluent Limitations

Table F-1 summarizes the final technology-based effluent limitations established in this Order.

**Table F-1
Summary of Technology-based Effluent Limitations
Discharge Points 001, 002, 004, 005, 007, 008, 009, 010, 011, 013, 014, 015**

Parameter	Units	Effluent Limitations				
		Average Monthly	Average Weekly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
ARGET Flow	mgd	5.0	--	5.0	--	--
GET E/F Flow	mgd	8.64		8.64		
GET H/Chettenham Flow	mgd	3.96		3.96		
GET J Flow	mgd	5.98		5.98		
GET K-A Flow	mgd	4.03		4.03		
GET L-A/L-B Flow	mgd	4.32		4.32		
Sailor Bar Park Well Flow	mgd	0.36		0.36		
Golden State AC-6 Flow	mgd	1.08		1.08		
Golden State AC-18 Flow	mgd	2.49		2.49		
Golden State AC-23 Flow	mgd	3.17		3.17		
VOCs ¹	µg/L	0.5		0.75		
Perchlorate ²	µg/L	4.0		6.0		
N-nitrosodimethylamine	µg/L	0.002		0.005		
N-nitrosodimethylamine –Discharges 005, 007, 008, and 009	µg/L	0.007		0.010		
chloroform – GET J	µg/L	3.0		5.0		

1 1,2-dichloroethane has a WQBEL, listed below, that is more stringent than the 0.5 µg/L listed on this table. GET E/F has an effluent limit of 1.5 for TCE.

2 In the existing permit ARGET has an effluent limitation of 8 µg/L for a monthly average and 8 µg/L for a daily maximum. The current ARGET influent is between 4 and 6 µg/L. As planned new extraction wells are added and their extracted groundwater sent to the ARGET facility, treatment for removal of perchlorate will be added and the effluent limitations will be the same as those for the other treatment facilities.

C. Water Quality-Based Effluent Limitations (WQBELs)

1. Scope and Authority

As specified in 40 CFR Section 122.44(d)(1)(i), permits are required to include WQBELs for pollutants (including toxicity) that are or may be discharged at levels that cause, have reasonable potential to cause, or contribute to an excursion above any state water quality standard. The process for determining reasonable potential and calculating WQBELs when necessary is intended to protect the designated uses of the receiving water as specified in the Basin Plan, and achieve applicable water

quality objectives and criteria that are contained in other state plans and policies, or water quality criteria contained in the CTR and NTR.

2. Applicable Beneficial Uses and Water Quality Criteria and Objectives

- a. **Beneficial Uses.** The Basin Plan at page II-2.00 states that the beneficial uses of any specifically identified water body generally applies to its tributary streams. The Basin Plan does not specifically identify beneficial uses for Buffalo Creek and Alder Creek, or Morrison Creek, tributary to the American River and Sacramento River, respectively, but does identify present and potential uses for the American and Sacramento Rivers. These beneficial uses are municipal and domestic supply (MUN); agricultural supply, irrigation and stock watering (AGR); water contact recreation (REC-1); non-contact water recreation (REC-2); warm freshwater habitat (WARM); cold freshwater habitat (COLD); warm and cold migration of aquatic organisms (MIGR); warm and cold spawning (SPWN); wildlife habitat (WILD). In addition, State Water Resources Control Board (State Water Board) Resolution No. 88-63 requires that, with certain exceptions, the Regional Water Board assign the municipal and domestic supply use to water bodies that do not have beneficial uses listed in the Basin Plan. Thus, as discussed in detail in this Fact Sheet, beneficial uses applicable to the American River, Sacramento River, Buffalo Creek, Alder Creek, Morrison Creek and Sailor Bar Park Pond are as follows:

Discharge Point	Receiving Water Name	Beneficial Use(s)
001, 002 and 005	Buffalo Creek and Alder Creek, Tributary of the American River	<u>Existing:</u> MUN, AGR, REC-1, REC-2, WARM, COLD, MIGR, SPWN, WILD.
003	Morrison Creek, Tributary of the Sacramento River	<u>Existing:</u> MUN, AGR, REC-1, REC-2, WARM, COLD, MIGR, SPWN, WILD.
004, 006, 007, 008, 009, 011 and 012	American River	<u>Existing:</u> MUN, AGR, REC-1, REC-2, WARM, COLD, MIGR, SPWN, WILD.
010	Sailor Bar Pond, Potentially tributary to American River	<u>Existing:</u> MUN, AGR, REC-1, REC-2, WARM, COLD, MIGR, SPWN, WILD.

- b. **Dilution Credits/Mixing Zones.** The Regional Board finds that based on the available information that three of the receiving waters, Buffalo Creek, Morrison Creek and Alder Creek, and on the Discharger’s application, that these three creeks, absent the discharges, are ephemeral streams, or at times the flow upstream of the discharges is significantly less than that of the discharge. The ephemeral an/or low flow nature of the creeks means that the designated beneficial uses must be protected, but that no credit for receiving water dilution is available. However, there is dilution available on Buffalo Creek at Discharge Point 005 due to the flow from upstream Discharges 001 and 002. As the discharge, at times, maintains the aquatic habitat, constituents may not be

discharged that may cause harm to aquatic life. At other times, natural flows within the creeks help support the aquatic life. Dry conditions occur primarily in the summer months, but dry conditions may also occur throughout the year, particularly in low rainfall years. The lack of dilution results in more stringent effluent limitations to protect contact recreational uses, drinking water standards, agricultural water quality goals and aquatic life. Therefore, the Regional Water Board has evaluated the need for water quality-based effluent limitations for pollutants without benefit of dilution in this Order. These water quality-based effluent limitations are based on the application of water quality criteria or objectives at the points of discharge.

- c. **Hardness.** The minimum effluent hardness, maximum receiving water pH limitation, and measured effluent temperature were used to develop hardness, pH, and/or temperature dependent WQBELs. These worst-case values have been chosen to protect the beneficial uses of the receiving water and are summarized below:

Hardness:	130 mg/L
pH:	8.5 standard units
Temperature:	21 °C

3. Determining the Need for WQBELs

- a. Reasonable potential (RP) was determined by calculating the projected maximum effluent concentration (MEC) for each constituent and comparing it to applicable water quality criteria; if a criterion was exceeded, the discharge was determined to have reasonable potential to exceed a water quality objective for that constituent. The projected MEC is determined by multiplying the observed MEC by a factor that accounts for statistical variation. The multiplying factor is determined (for 99% confidence level and 99% probability basis) using the number of results available and the coefficient of variation (standard deviation divided by the mean) of the sample results. In accordance with the SIP, non-detect results were counted as one-half the detection level when calculating the mean. For all constituents for which the source of the applicable water quality standard is the CTR or NTR, the multiplying factor is 1. Reasonable potential evaluation was based on the methods used in the SIP and the U.S. EPA Technical Support Document for Water Quality-Based Toxics Control [EPA/505/2-90-001].
- b. Federal regulations require effluent limitations for all pollutants that are or may be discharged at a level that will cause or have the reasonable potential to cause, or contribute to an in-stream excursion above a narrative or numerical water quality standard. Based on information submitted as part of the application, in studies, and as directed by monitoring and reporting programs the Regional Water Board finds that the discharge does have a reasonable potential to cause or contribute

to an in-stream excursion above a water quality standard for copper. Effluent limitations for copper are included in this Order.

- c. The reasonable potential analysis for detected constituents is summarized below in Table F-2.

**Table F-2.
RPA Summary for Detected Constituents
Discharges 001-015**

Parameter	Units	MEC ¹	99 th MEC ¹	WQO/ WQC ²	Source	RP ³
Perchlorate	µg/L	4	4	6	California Primary MCL	Y
NDMA	µg/L	0.005	0.005	0.003	CTR HH	Y
Copper	µg/L	27	27	12/18	CTR CCC/CMC	Y
Mercury	µg/L	0.001	0.001	0.05	CTR HH	N
Nickel	µg/L	13	13	65/590	CTR CCC/CMC	N
Zinc	µg/L	42	42	150	CTR CCC/CMC	N
Barium	µg/L	90	124	1000	California Primary MCL	N
Iron	µg/L	55	75	300	California Secondary MCL	N
Manganese	µg/L	<5	23	50	California Secondary MCL	N
Chloride	mg/L	13	39	106	Water Quality for Agriculture	N
Nitrate	mg/L	0.8	4	10	California Primary MCL	N
Sulfate	mg/L	12	60	250	California Secondary MCL	N
Electrical Conductivity	µmhos/cm	210	230	700	Water Quality for Agriculture	N
Total Dissolved Solids	mg/L	220	260	450	Water Quality for Agriculture	N

1. MEC: maximum effluent concentration. 99th MEC: maximum predicted effluent concentration using 99th percentile multiplier, note that multiplier is equal to “1” when applying CTR criteria.
2. WQO: water quality objective. WQC: water quality criteria.
3. Reasonable potential.

- d. **Copper.** Copper is known to cause adverse impacts on aquatic species, particularly fish. The Basin Plan’s chemical constituents water quality objective has a copper limit for the American River of 0.01 mg/L. Furthermore, the same water quality objective prohibits chemical constituents in concentrations that adversely affect beneficial uses. Applying a hardness of 130 mg/L (worst case effluent hardness) the allowable continuous concentration is 0.011 mg/L and the allowable instantaneous concentration is 0.017 mg/L.
- e. **pH.** The Basin Plan includes numeric water quality objectives that the pH “...not be depressed below 6.5 nor raised above 8.5. Changes in normal ambient pH levels shall not exceed 0.5 in fresh waters with designated COLD or WARM beneficial uses.” The receiving water is designated as having both COLD and WARM beneficial uses. An effluent limitation for pH is included in this Order, and is based on the Basin Plan objectives for pH.

- f. **1,2-Dichloroethane.** 1,2-Dichloroethane has not been detected in the effluent of the GET facilities (PQL of 0.5 µg/L) but has been detected in the groundwater contaminant plumes. The estimated incremental 1×10^{-6} excess cancer risk value established by the Office of Environmental Health Hazard Assessment for the State of California for this volatile organic is 0.38 µg/L. As there is little to no dilution in Buffalo Creek and Morrison Creek, the monthly average effluent limitation is established at the risk value.
- g. **Perchlorate.** Perchlorate has been determined to have a potential adverse impact on the thyroid. The California Department of Public Health has adopted a Maximum Contaminant Level for perchlorate of 6 µg/L and the California Department of Health Hazard Assessment has adopted the same value as the Public Health Goal. Concentrations below 6 µg/L would pose a *de minimus* risk to human health.
- h. **NDMA.** NDMA is believed to be a human carcinogen at very low concentrations. The estimated incremental 1×10^{-6} excess cancer risk value (Public Health Goal) established by the Office of Environmental Health Hazard Assessment for the State of California for this pollutant is 0.003 µg/L. Barring any dilution within the receiving water, this value is used as the effluent limitation. However, when the previous version of the permit was adopted, the Public Health Goal was 0.002 µg/L and the effluent limits for the GETs were established at that value.

4. WQBEL Calculations

- a. The Discharger conducted monitoring for priority and non-priority pollutants. The analytical results of one comprehensive sampling event were submitted to the Regional Water Board. The results of this sampling event were used in developing the requirements of this Order. Effluent limitations are included in this Order to protect the beneficial uses of the receiving stream and to ensure that the discharge complies with the Basin Plan objective that toxic substances not be discharged in toxic amounts.
- b. **Calculations for Effluent Limitations.** In calculating maximum effluent limitations, the effluent concentration allowances were set equal to the criteria/standards/objectives.

$$ECA_{acute} = CMC \qquad ECA_{chronic} = CCC$$

$$ECA_{HH} = HH$$

where: ECA_{acute} = effluent concentration allowance for acute (one-hour average) toxicity criterion

ECA_{chronic} = effluent concentration allowance for chronic (four-day average) toxicity criterion
 ECA_{HH} = effluent concentration allowance for human health, agriculture, or other long-term criterion/objective
 CMC = criteria maximum concentration (one-hour average)
 CCC = criteria continuous concentration (four-day average, unless otherwise noted)
 HH = human health, agriculture, or other long-term criterion/objective

Acute and chronic toxicity ECAs were then converted to equivalent long-term averages (LTA) using statistical multipliers and the lowest is used. Additional statistical multipliers were then used to calculate the maximum daily effluent limitation (MDEL) and the average monthly effluent limitation (AMEL). The statistical multipliers were calculated using data shown in Table 1.

Human health ECAs are set equal to the AMEL and a statistical multiplier is used to calculate the MDEL.

$$MDEL = mult_{MDEL} \left[\min \left(\overbrace{M_A ECA_{acute}}^{LTA_{acute}}, \underbrace{M_C ECA_{chronic}}_{LTA_{chronic}} \right) \right]$$

$$MDEL_{HH} = \left(\frac{mult_{MDEL}}{mult_{AMEL}} \right) AMEL_{HH}$$

where: $mult_{AMEL}$ = statistical multiplier converting minimum LTA to AMEL
 $mult_{MDEL}$ = statistical multiplier converting minimum LTA to MDEL
 M_A = statistical multiplier converting CMC to LTA
 M_C = statistical multiplier converting CCC to LTA

- c. **Mass-based Effluent Limitations.** In accordance with 40 CFR 122.45(b)(2), mass-based limitations are calculated by multiplying the concentration limitation by the long-term average flow and the appropriate unit conversion factors. Mass based limits are found in Tables IV(A)(1) through IV(A)(12).

Mass-based effluent limitations, or mass emission rates (MERs), for WQBELs applicable to Discharge 001-011 are calculated as follows:

$$MER = 8.34 \left(\frac{lb - L}{mg - gal} \right) \times AMEL - or - MDEL \times flow(mgd)$$

- d. **Final WQBELs.** Table F-3 summarizes the final WQBELs contained in this Order.

**Table F-3
Discharge Points 001- 015**

Parameter	Units	Effluent Limitations				
		Average Monthly	Average Weekly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
perchlorate	µg/L	6				
NDMA – Discharge 002	µg/L	0.003		0.010		
Total Copper	µg/L	11	--	17	--	--
pH	standard units	--	--	--	6.5	8.5
1,2-DCA	µg/L	0.38	--	0.50	--	--

5. Whole Effluent Toxicity (WET)

The Basin Plan specifies a narrative objective for toxicity, requiring that “All waters shall be maintained free of toxic substances in concentrations that are toxic to, or that produce detrimental physiological responses in human, plant, animal, or aquatic life.” Compliance with this objective will be determined by use of indicator organisms, analyses of species diversity, population density, growth anomalies, bioassays of appropriate duration and/or other appropriate methods as specified by the Regional Water Board. The survival of aquatic life in surface waters subjected to a waste discharge, or other controllable water quality factors, shall not be less than that for the same water body in areas unaffected by the waste discharge, or when necessary, for other control water that is consistent with the requirements for “experimental water” as defined in Standard Methods for the Examination of Water and Wastewater (American Public Health Association, et al. 1992).

In addition to the Basin Plan requirements, Section 4 of the SIP states that a chronic toxicity effluent limitation is required in permits for all discharges that will cause, have the reasonable potential to cause, or contribute to chronic toxicity in receiving waters.

Numeric water quality criteria, or Basin Plan numeric objectives currently are not available for many of the aquaculture drugs and chemicals used by aquaculture facilities. Therefore, the Regional Water Board uses the narrative water quality objective for toxicity from the Basin Plan as a basis for determining “reasonable potential” for discharges of these drugs and chemicals. USEPA’s *Technical Support Document Water Quality-based Toxics Control (TSD)* specifies two toxicity measurement techniques that can be employed in effluent characterization; the first is WET testing, and the second is chemical-specific toxicity analyses. Whole effluent toxicity (WET) requirements protect the receiving water quality from the aggregate toxic effect of a mixture of pollutants in the effluent. WET tests measure the degree of response of exposed aquatic test organisms to an effluent. The WET approach allows for protection of the narrative “no toxics in toxic amounts” criterion

while implementing numeric criteria for toxicity. There are two types of WET tests: acute and chronic. An acute toxicity test is conducted over a short time period and generally measures mortality. A chronic toxicity test is conducted over a longer period of time and may measure mortality, reproduction, and growth. For fish hatcheries WET testing is used most appropriately when the toxic constituents in an effluent are not completely known; whereas chemical-specific analysis is more appropriately used when an effluent contains only one, or very few, well-known constituents.

D. Final Effluent Limitations

1. 40 CFR Section 122.45 states that:

“...All pollutants limited in permits shall have limitations...expressed in terms of mass except...[f]or pH, temperature, radiation, or other pollutants which cannot appropriately be expressed by mass...Pollutants limited in terms of mass additionally may be limited in terms of other units of measurement, and the permit shall require the permittee to comply with both limitations.”

2. Tables F-4 and F-5 summarizes the final technology-based and water quality-based effluent limits established in this Order.

**Table F-4
Summary of Final Effluent Limitations
Discharge Points 001 through 015**

Parameter	Units	Effluent Limitations			
		Average Monthly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
Flow – Discharge 001	mgd	5.0	5.0	--	--
Flow – Discharge 002	mgd	8.64	8.64		
Flow – Discharge 004	mgd	2.88	2.88		
Flow – Discharge 005	mgd	5.98	5.98		
Flow – Discharge 007	mgd	4.03	4.03		
Flow – Discharge 008	mgd	1.73	1.73		
Flow – Discharge 009	mgd	1.44	1.44		
Flow – Discharge 010	mgd	0.36	0.36		
Flow – Discharge 011	mgd	1.1	1.1		
Flow – Discharge 013	mgd	1.08	1.08		
Flow – Discharge 014	mgd	2.49	2.49		
Flow – Discharge 015	mgd	3.17	3.17		
Volatile Organic Contaminants	µg/L	0.5	0.7	--	--

Parameter	Units	Effluent Limitations			
		Average Monthly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
Trichloroethylene – Discharge 002	µg/L	--	1.5		
Chloroform – Discharge 005	µg/L	3.0	5.0		
1,2-Dichloroethane	µg/L	0.38	0.5	--	--
1,4-Dioxane	µg/L	3	6		
N-nitrosodimethylamine – Discharge 002	µg/L	0.002	0.010	--	--
N-nitrosodimethylamine - Discharges 005, 007, 008 and 009	µg/L	0.007	0.010		
Perchlorate	µg/L	4	6		
Total Copper	µg/L	11	17	--	--
Acetaldehyde	µg/L	5	--	--	--
Formaldehyde	µg/L	50	--		
pH	pH	--	--	6.5	8.5

**Table F-5
Summary of Final Effluent Limitations
Discharge Point 012**

Parameter	Units	Effluent Limitations			
		Total Maximum Discharge ¹	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
Flow – Per Well Purge/Development Water	mgd	0.01	0.01		
Flow – Per Aquifer Test	mgd	14.4	3.6		
Volatile Organic Contaminants	µg/L	--	5.0	--	--
1,4-Dioxane	µg/L		10		
N-nitrosodimethylamine	µg/L		0.020	--	--
Perchlorate	µg/L		12		
pH	pH	--	--	6.5	8.5

E. Interim Effluent Limitations

1. See Section IV(A)(2)(a) and IV(A)(6)(2).

**Table F-6
Summary of Interim Effluent Limitations
Discharge Point 001**

Parameter	Units	Effluent Limitations			
		Average Monthly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
Discharge 001 - Perchlorate	µg/L	8	8		

F. Land Discharge Specifications – Not Applicable

G. Reclamation Specifications – Not Applicable

V. RATIONALE FOR RECEIVING WATER LIMITATIONS

A. Surface Water

1. The Clean Water Act, Section 303(a-c), required states to adopt numeric criteria where they are necessary to protect designated uses. The Regional Water Board adopted numeric criteria in the Basin Plan. The Basin Plan is a regulatory reference for meeting the state and federal requirements for water quality control (40 CFR 131.20). State Water Board Resolution No. 68-16, the Antidegradation Policy, does not allow changes in water quality less than that prescribed in Water Quality Control Plans (Basin Plans). The Basin Plan states that; “The numerical and narrative water quality objectives define the least stringent standards that the Regional Water Board will apply to regional waters in order to protect the beneficial uses.” This Order contains Receiving Water Limitations based on the Basin Plan numerical and narrative water quality objectives for Biostimulatory Substances, Chemical Constituents, Color, Dissolved Oxygen, Floating Material, Oil and Grease, pH, Pesticides, Radioactivity, Salinity, Sediment, Settleable Material, Suspended Material, Tastes and Odors, Temperature, Toxicity and Turbidity.

2. Numeric Basin Plan objectives for bacteria, dissolved oxygen, pH, temperature, and turbidity are applicable to this discharge and have been incorporated as Receiving Surface Water Limitations. Rational for these numeric receiving surface water limitations are as follows:
 - a. **Bacteria.** The Basin Plan includes a water quality objective that “[/]n water designated for contact recreation (REC-1), the fecal coliform concentration based on a minimum of not less than five samples for any 30-day period shall not exceed a geometric mean of 200/100 ml, nor shall more than ten percent of the total number of samples taken during any 30-day period exceed 400/100 ml.” Numeric Receiving Water Limitations for bacteria are included in this Order and are based on the Basin Plan objective.

- b. **Dissolved Oxygen.** The Basin Plan includes a water quality objective that “[F]or water bodies outside of the legal boundaries of the Delta, the monthly median of the mean daily dissolved oxygen (DO) concentrations shall not fall below 85 percent of saturation in the main water mass, and the 95 percentile concentration shall not fall below 75 percent of saturation. The dissolved oxygen concentrations shall not fall below the following minimum levels at any time – Waters designated WARM – 5.0 mg/L, Waters designated COLD – 7.0 mg/L, and Waters designated SPAWN – 7.0 mg/L. The American River is designated as having WARM, COLD, and SPAWN designated uses. Numeric Receiving Water Limitations for dissolved oxygen are included in this Order and are based on the Basin Plan objective.
- c. **pH.** The Basin Plan includes water quality objectives that the pH “...not be depressed below 6.5 nor raised above 8.5. Changes in normal ambient pH levels shall not exceed 0.5 in fresh waters with designated COLD or WARM beneficial uses.” The American River is designated as having both COLD and WARM beneficial uses. The change in pH of 0.5 (standard pH units) is not included as necessary to protect aquatic life in U.S. EPA’s Ambient Criteria for the Protection of Freshwater Aquatic Life as long as pH does not fall below 6.5 or exceed 8.5 units. Therefore, an averaging period of 30 days has been applied to the Basin Plan receiving water objective for changes in pH. Numeric Receiving Water Limitations for pH are included in this Order and are based on the Basin Plan objectives for pH.
- d. **Temperature.** The Basin Plan includes water quality objectives that prohibit the temperature “. . . of COLD or WARM intrastate waters be increased more than 5°F above natural receiving water.” The American River is designated having both COLD and WARM beneficial uses. Receiving Water Limitations for temperatures are included in this Order and are based on the Basin Plan objectives for temperature.
- e. **Turbidity.** The Basin Plan includes a water quality objective that “[I]ncreases in turbidity attributable to controllable water quality factors shall not exceed the following limits:
- *Where natural turbidity is between 0 and 5 Nephelometric Turbidity Units (NTUs), increases shall not exceed 1 NTU.*
 - *Where natural turbidity is between 5 and 50 NTUs, increases shall not exceed 20 percent.*
 - *Where natural turbidity is between 50 and 100 NTUs, increases shall not exceed 10 NTUs.*
 - *Where natural turbidity is greater than 100 NTUs, increases shall not exceed 10 percent.”*

A numeric Receiving Surface Water Limitation for turbidity is included in this Order and is based on the Basin Plan objective for turbidity.

B. Groundwater – Not Applicable

VI. RATIONALE FOR MONITORING AND REPORTING REQUIREMENTS

Section 122.48 of 40 CFR requires all NPDES permits to specify recording and reporting of monitoring results. Sections 13267 and 13383 of the CWC authorize the Water Boards to require technical and monitoring reports. The Monitoring and Reporting Program, [Attachment E](#) of this Order, establishes monitoring and reporting requirements to implement federal and state requirements. The following provides the rationale for the monitoring and reporting requirements contained in the Monitoring and Reporting Program for this facility

A. Influent Monitoring

The Order establishes influent monitoring requirements to allow the Discharger to monitor the treatment efficiency of the treatment systems and make sure that influent concentrations are within the design parameters of the treatment systems. As such, monitoring is required for volatile organics, semi-volatile organics, perchlorate, 1,4-Dioxane, n-nitrosodimethylamine, and copper.

B. Effluent Monitoring

Pursuant to the requirements of 40 CFR 122.44(i)(2) effluent monitoring is required for all constituents with effluent limitations. The Monitoring and Reporting Requirements include effluent monitoring requirements in [Attachment E, Section IV](#).

C. Whole Effluent Toxicity Testing

1. **Acute Toxicity.** Quarterly 96-hour bioassay testing is required to demonstrate compliance with the effluent limitation for acute toxicity ([Effluent Limitations IV.A.1.e](#)).
2. **Chronic Toxicity.** Quarterly chronic whole effluent toxicity testing is required in order to demonstrate compliance with the Basin Plan's narrative toxicity objective.

D. Receiving Water Monitoring

1. **Surface Water.** Receiving water monitoring is required to demonstrate compliance with the Receiving Water Limitations.
2. **Groundwater – Not Applicable**

Groundwater monitoring associated with the treatment facilities is not required. Extensive groundwater monitoring is conducted by the Discharger to meet compliance associated with groundwater cleanup requirements established by the Regional Water Board and USEPA under other programs.

F. Other Monitoring Requirements

1. Solids Disposal Monitoring

This Order requires an annual solids disposal report describing the annual volume of solids generated by the Facilities and specifying the disposal practices. Solids disposal reporting is required to evaluate compliance with Construction, Operation, and Maintenance Specifications, Section VI.C.5.a, of this Order.

VII. RATIONALE FOR PROVISIONS

A. Standard Provisions

1. **Federal Standard Provisions.** In accordance with 40 CFR section 122.41 and 122.42, the Federal Standard Provisions provided in [Attachment D](#) of this Order apply to this discharge.
2. **Regional Water Board Standard Provisions.** In addition to the Federal Standard Provisions (Attachment D), the Discharger must comply with the Regional Water Board Standard Provisions provided in [Standard Provisions VI.A.2.](#)

40 CFR Section 122.41(a)(1) and (b) through (n) establish conditions that apply to all state-issued NPDES permits. These conditions must be incorporated into the permits either expressly or by reference. If incorporated by reference, a specific citation to the regulations must be included in the Order. 40 CFR Section 123.25(a)(12) allows the State to omit or modify conditions to impose more stringent requirements. In accordance with Section 123.35, this Order omits federal conditions that address enforcement authority specified in 40 CFR Sections 122.41(j)(5) and (k)(2) because the enforcement authority under the CWC is more stringent. In lieu of these conditions, this Order incorporates by reference CWC Section 13387(e).

B. Special Provisions

1. Reopener Provisions

- a. **Special Provisions VI.C.1.a.** Conditions that necessitate a major modification of a permit are described in 40 CFR section 122.62, which include the following:
 - i. When standards or regulations on which the permit was based have been changed by promulgation of amended standards or regulations or by judicial

decision. Therefore, if more stringent applicable water quality standards are promulgated or approved pursuant to section 303 of the Federal Water Pollution Control Act or amendments thereto, the Regional Water Board will revise and modify this Order in accordance with such more stringent standards.

- ii. When new information, that was not available at the time of permit issuance, would have justified different permit conditions at the time of issuance.
- b. **Whole Effluent Toxicity.** As a result of a Toxicity Reduction Evaluation (TRE), this Order may be reopened to include a chronic toxicity limitation, a new acute toxicity limitation, and/or a limitation for a specific toxicant identified in the TRE. Additionally, if a chronic toxicity water quality objective is adopted by the State Water Board, this Order may be reopened to include a chronic toxicity limitation based on that objective.

2. Special Studies, Technical Reports and Additional Monitoring Requirements

- a. **Chronic Whole Effluent Toxicity Requirements ([Special Provisions VI.C.2.a.](#))**. The Basin Plan contains a narrative toxicity objective that states, “All waters shall be maintained free of toxic substances in concentrations that produce detrimental physiological responses in human, plant, animal, or aquatic life.” (Basin Plan at III-8.00.) Based on quarterly whole effluent chronic toxicity testing performed by the Discharger from March 2, 2001 through October 15, 2004, the discharge has reasonable potential to cause or contribute to an in-stream excursion above of the Basin Plan’s narrative toxicity objective.

[Special Provisions VI.C.2.a.](#) requires the Discharger to develop a Toxicity Reduction Evaluation (TRE) work plan in accordance with EPA guidance. In addition, the provision establishes a numeric toxicity trigger, requirements for accelerated monitoring to confirm effluent toxicity, and a protocol for requiring the Discharger to initiate a TRE.


TRE Trigger. A numeric TRE Trigger of > 1 TUc (where TUc = 100/NOEC) is applied in the provision, because this Order does not allow any dilution for the chronic condition. Therefore, a TRE is triggered when the effluent exhibits toxicity at 100% effluent.

Accelerated Monitoring. The provision requires accelerated WET testing when a regular WET test result exceeds the TRE Trigger to confirm effluent toxicity prior to requiring implementation of a TRE.

TRE Guidance. The Discharger is required to prepare the TRE work plan in accordance with USEPA guidance. Numerous guidance documents are available, as identified below:

- Toxicity Reduction Evaluation Guidance for Municipal Wastewater Treatment Plants, (*EPA/833B-99/002*), August 1999.
- Generalized Methodology for Conducting Industrial TREs, (*EPA/600/2-88/070*), April 1989.
- Methods for Aquatic Toxicity Identification Evaluations: Phase I Toxicity Characterization Procedures, *Second Edition*, EPA 600/6-91/005F, February 1991.
- Toxicity Identification Evaluation: Characterization of Chronically Toxic Effluents, Phase I, *EPA 600/6-91/005F*, May 1992.
- Methods for Aquatic Toxicity Identification Evaluations: Phase II Toxicity Identification Procedures for Samples Exhibiting acute and Chronic Toxicity, *Second Edition*, EPA 600/R-92/080, September 1993.
- Methods for Aquatic Toxicity Identification Evaluations: Phase III Toxicity Confirmation Procedures for Samples Exhibiting Acute and Chronic Toxicity, *Second Edition*, EPA 600/R-92/081, September 1993.
- Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms, *Fifth Edition*, EPA-821-R-02-012, October 2002.
- Short-term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms, *Fourth Edition*, EPA-821-R-02-013, October 2002.
- Technical Support Document for Water Quality-based Toxics Control, EPA/505/2-90-001, March 1991

**Figure F-15
 WET Accelerated Monitoring Flow Chart**



3. Best Management Practices and Pollution Prevention – Not Applicable

4. Compliance Schedules

- a. **ARGET Perchlorate Effluent Limitation.** Effective immediately and ending on 1 January 2012, or until the treatment system to remove perchlorate at the ARGET facility is constructed, whichever is sooner, the discharge of treated effluent from the ARGET facility shall maintain compliance with 8.0 µg/l as the effluent limitation for perchlorate at Discharge Point 001. Mixing with the GET E/F effluent will keep the perchlorate concentration below the Water Quality Objective of 6 µg/L in Buffalo Creek. No additional extraction wells containing perchlorate will be added to the ARGET system until perchlorate treatment is added at ARGET.

5. Construction, Operation, and Maintenance Specifications

- a. **Provisions VI.C.5.a,b.** Solid waste disposal provisions in this Order are based on the requirements of CCR Title 27 and prevention of unauthorized discharge of solid wastes into waters of the United States or waters of the State. Other construction, operation, and maintenance specifications are to prevent other unauthorized discharges to waters of the United States or waters of the State.

6. Special Provisions for Municipal Facilities (POTWs Only) – Not Applicable

7. Other Special Provisions

VIII. PUBLIC PARTICIPATION

The California Regional Water Quality Control Board, Central Valley Region (Regional Water Board) is considering the issuance of waste discharge requirements (WDRs) that will serve as a National Pollutant Discharge Elimination System (NPDES) permit for the Aerojet-General Corporation Groundwater Extraction and Treatment Systems. As a step in the WDR adoption process, the Regional Water Board staff has developed tentative WDRs. The Regional Water Board encourages public participation in the WDR adoption process.

A. Notification of Interested Parties

The Regional Water Board has notified the Discharger and interested agencies and persons of its intent to prescribe waste discharge requirements for the discharge and has provided them with an opportunity to submit their written comments and recommendations.

B. Written Comments

The staff determinations are tentative. Interested persons are invited to submit written comments concerning these tentative WDRs. Comments should be submitted either in person or by mail to the Executive Office at the Regional Water Board at the address above on the cover page of this Order.

To be fully responded to by staff and considered by the Regional Water Board, written comments should be received at the Regional Water Board offices by 5:00 p.m. on November 2, 2007.

C. Public Hearing

The Regional Water Board will hold a public hearing on the tentative WDRs during its regular Board meeting on the following date and time and at the following location:

Date: **30 November/1 and 2 December 2011**
Time: 8:30 am
Location: Regional Water Quality Control Board
 11020 Sun Center Dr #200
 Rancho Cordova, CA

Interested persons are invited to attend. At the public hearing, the Regional Water Board will hear testimony, if any, pertinent to the discharge, WDRs, and permit. Oral testimony will be heard; however, for accuracy of the record, important testimony should be in writing.

Please be aware that dates and venues may change. Our web address is <http://www.waterboards.ca.gov/centralvalley/> where you can access the current agenda for changes in dates and locations.

D. Waste Discharge Requirements Petitions

Any aggrieved person may petition the State Water Resources Control Board to review the decision of the Regional Water Board regarding the final WDRs. The petition must be submitted within 30 days of the Regional Water Board's action to the following address:

State Water Resources Control Board
Office of Chief Counsel
P.O. Box 100, 1001 I Street
Sacramento, CA 95812-0100

E. Information and Copying

The RWD, related documents, tentative effluent limitations and special provisions, comments received, and other information are on file and may be inspected at the address above at any time between 8:30 a.m. and 4:45 p.m., Monday through Friday. Copying of documents may be arranged through the Regional Water Board by calling (916) 464-3291.

F. Register of Interested Persons

Any person interested in being placed on the mailing list for information regarding the WDRs and NPDES permit should contact the Regional Water Board, reference this facility, and provide a name, address, and phone number.

G. Additional Information

Requests for additional information or questions regarding this order should be directed to Alexander MacDonald at (916) 464-4625.