

INFORMATION SHEET

ORDER NO.
EL DORADO COUNTY
UNION MINE SEPTAGE/LEACHATE TREATMENT FACILITY
EL DOARDO COUNTY

Facilities and Discharge

El Dorado County owns, operates, maintains, and monitors a wastewater treatment facility (WWTF) that includes treatment, storage, and disposal facilities. The Union Mine WWTF receives Class II leachate generated from the Union Mine Landfill, condensate generated during extraction of landfill gas, and septage and portable toilet wastewater generated throughout El Dorado County.

The WWTF consists of aerobic digesters, a sludge centrifuge, disinfection facilities, and an effluent storage tank. Wastewater disposal (via spray irrigation) occurs on approximately 3.6 acres of land.

The WWTF was previously regulated by Waste Discharge Requirements (WDRs) Order No. 98-238 for the Union Mine Landfill. Updated requirements for the Union Mile Landfill, landfill gas collection and flare system, and Class II surface impoundment are included in separate WDRs. This Order only prescribes requirements for treatment, storage, and disposal of wastewater.

Waste Discharge Requirement Order No. 98-238 allowed a 30-day average dry weather flow limit not to exceed 30,000 gallons per day. The water balance submitted as part the RWD indicates that the WWTF has sufficient treatment, storage, and disposal capacity for average annual precipitation conditions. The water balance assumes that approximately 9,500 gpd (monthly average) of septage and portable toilet waste, and 3,100 gpd (monthly average) of Class II leachate and landfill gas condensate would be treated and disposed of.

The water balance submitted for 100 year annual precipitation conditions indicates that the WWTF has sufficient treatment and storage capacity provided that the Discharger installs two million gallons of additional storage capacity. However, the water balance indicates that the WWTF does not have sufficient disposal capacity based on 100-year annual precipitation conditions. Based on the water balance calculations for 100-year precipitation, there would be approximately 2.5 million gallons of effluent surplus that the Discharger would need to dispose of. The RWD states that the Discharger is currently installing a two million gallon above ground effluent storage tank, which is to be completed sometime in January 2006. The RWD also states that the Discharger is working with the El Dorado Irrigation District (EID) to obtain a permit to discharge the surplus effluent to the EID Deer Creek wastewater treatment plant. As of the date of this Order, such a permit is not in place.

The RWD also included a water balance, which calculated the flows at which the WWTF would have sufficient disposal capacity based on 100-year annual precipitation conditions. The water balance shows that the wastewater disposal system can dispose of approximately 2,600 gpd (monthly average) of septage and portable toilet waste, and 8,000 gpd (monthly average) of Class II leachate and landfill condensate, or approximately 10,600 gpd in total. This Order limits the monthly average influent flows to 10,500 gpd. However, if the Discharger obtains a permit with EID to discharge wastewater to the EID Deer Creek WWTP, then the Discharger may submit a report to the Executive Officer, and upon approval, the Executive Officer may increase the flow limit up to the calculated disposal capacity. In no case shall the flow shall exceed 16,000 gallons per day.

The RWD provides results of a salt balance conducted for the spray irrigation disposal areas. The results indicate that evaporation of applied effluent to the spray irrigation areas will cause a buildup of salts in the surficial soil in the sprayfields, thereby potentially causing highly soluble salts to redissolve into percolating rainwater during the winter, which could cause an increase in groundwater salinity. The RWD states that in order to prevent degradation of the groundwater from salts, that it may be necessary to periodically remove salt-laden surficial soils and replace them with new topsoil. The RWD recommends that annual testing of the soils within the spray disposal fields be performed to monitor the buildup of soluble salts and determine when to remove and replace topsoil, and recommends that soils be removed and be replaced with topsoil when the salinity in the upper six inches exceeds 4,000 omhos/cm. This Order requires the Discharger to conduct annual monitoring of the soils to determine whether soils in the spray disposal areas need to be removed and replaced, and requires surficial soils to be removed and replaced when soils exceed 4,000 omhos/cm.

Basin Plan, Beneficial Uses, and Regulatory Considerations

Surface water drainage from the spray disposal areas is to Martinez Creek, a tributary to the North Fork of the Consumnes River. The *Water Quality Control Plan for the California Regional Water Quality Control Board Central Valley Region, Fourth Edition* (Basin Plan), designates beneficial uses, establishes water quality objectives, and contains implementation plans and policies for all waters of the Basin. Beneficial uses often determine the water quality objectives that apply to a water body. For example, waters designated as municipal and domestic supply must meet the maximum contaminant levels (MCLs) for drinking waters. The Basin Plan sets forth the applicable beneficial uses (industrial, agricultural, and domestic supply in this instance) of groundwater, procedure for application of water quality objectives, and the process for and factors to consider in allocating waste assimilation capacity.

Antidegradation

The antidegradation directives of Section 13000 of the California Water Code require that waters of the State that are better in quality than established water quality objectives be maintained “consistent with the maximum benefit to the people of the State.” Waters can be of high quality for some constituents or beneficial uses and not others. Policies and procedures for complying with this directive are set forth in the Basin Plan (including by reference State Board Resolution No. 68-16, “Statement of Policy With Respect to Maintaining High Quality Waters in California,” or “Antidegradation” Policy).

Resolution 68-16 is applied on a case-by-case, constituent-by-constituent basis in determining whether a certain degree of degradation can be justified. It is incumbent upon the Discharger to provide technical information for the Board to evaluate that fully characterizes:

- All waste constituents to be discharged;
- The background quality of the uppermost layer of the uppermost aquifer;
- The background quality of other waters that may be affected;
- The underlying hydrogeologic conditions;

- Waste treatment and control measures;
- How treatment and control measures are justified as best practicable treatment and control;
- The extent the discharge will impact the quality of each aquifer; and
- The expected degradation to water quality objectives.

In allowing a discharge, the Board must comply with CWC section 13263 in setting appropriate conditions. The Board is required, relative to the groundwater that may be affected by the discharge, to implement the Basin Plan and consider the beneficial uses to be protected along with the water quality objectives essential for that purpose. The Board need not authorize the full utilization of the waste assimilation capacity of the groundwater (CWC 13263(b)) and must consider other waste discharges and factors that affect that capacity.

Certain waste constituents in municipal wastewater are not fully amenable to waste treatment and control and it is reasonable to expect some impact on groundwater. Some degradation for certain constituents is consistent with maximum benefit to the people of California because the technology, energy, water recycling, and waste management advantages of municipal utility service to the state far outweigh the environmental impact damage of a community that would otherwise be reliant on numerous concentrated individual wastewater systems. Economic prosperity of local communities is of maximum benefit to the people of California, and therefore sufficient reason to accommodate increases in wastewater discharge provided terms of reasonable degradation are defined and met. The proposed Order authorizes some degradation consistent with the maximum benefit to the people of the state, but does not authorize pollution.

Groundwater monitoring has been conducted at the site since December 2004. Because groundwater monitoring has only been conducted in wells located downgradient from the spray disposal areas and there are no upgradient wells around the sprayfields, staff are unable to establish the most appropriate groundwater limits. In addition, certain aspects of waste treatment and control practices may not be justified as representative of best practicable treatment and control (BPTC). Reasonable time is necessary to gather specific information about the WWTF and the site to make informed, appropriate, long-term decisions. This proposed Order, therefore, establishes interim receiving water limitations to assure protection of the beneficial uses of groundwater of the State pending the completion of certain tasks and provides time schedules to complete specified tasks. The Discharger is expected to identify, implement, and adhere to, BPTC as individual practices are reviewed and upgraded in this process. During this period, degradation may occur from certain constituents, but can never exceed water quality objectives (or background water quality should it exceed objectives) or cause nuisance.

Water quality objectives define the least stringent limits that could apply as water quality limitations for groundwater at this location, except where background quality unaffected by the discharge already exceeds the objective. The values below reflect water quality objectives that must be met to maintain specific beneficial uses of groundwater. Unless natural background for a constituent proves higher, the groundwater quality limit established in proposed Order is the most stringent of the values listed for the listed constituents.

INFORMATION SHEET
ORDER NO.
EL DORADO COUNTY
UNION MINE SEPTAGE/LEACHATE TREATMENT FACILITY
EL DORADO COUNTY

<u>Constituent</u>	<u>Units</u>	<u>Value</u>	<u>Beneficial Use</u>	<u>Criteria or Justification</u>
Ammonia	mg/L	1.5	MUN ¹	Taste and Odor ²
Boron	mg/L	0.7	AGR ³	Boron Sensitivity ⁴
Chloride	mg/L	1.0	MUN ¹	Calif. Drinking Water Action Level ¹¹
		106	AGR ³	Chloride sensitivity on certain crops irrigated via sprinklers ⁴
Iron	mg/L	142	AGR ³	Chloride sensitivity on certain crops ⁴
		250	MUN ¹	Recommended Secondary MCL ⁵
		500	MUN ¹	Upper Secondary MCL ⁵
		0.3	MUN ¹	Secondary MCL ⁶
Manganese	mg/L	0.05	MUN ¹	Secondary MCL ⁶
Nitrate plus Nitrite as N	mg/L	10	MUN ¹	Primary MCL ⁷
Nitrite as N	mg/L	1	MUN ¹	Primary MCL ⁷
Sodium	mg/L	69	AGR ³	Sodium sensitivity on certain crops ⁴
Total Dissolved Solids	mg/L	450 ⁸	AGR ³	Salt sensitivity ⁴
		500	MUN ¹	Recommended Secondary MCL ⁵
		1,000	MUN ¹	Upper Secondary MCL ⁵
Total Coliform Organisms	MPN/100 ml	<2.2	MUN ¹	Basin Plan
Trihalomethanes	µg/L	100	MUN ¹	MCL ⁸
Bromoform	µg/L	4	MUN ¹	USEPA Cancer Potency Factor ⁹
Bromodichloromethane	µg/L	0.27	MUN ¹	Cal/EPA Cancer Potency Factor ¹²
Chloroform	µg/L	1.1	MUN ¹	Cal/EPA Cancer Potency Factor ¹²
Dibromochloromethane	µg/L	0.37	MUN ¹	Cal/EPA Cancer Potency Factor ¹²
pH	pH Units	6.5 to 8.4	MUN ¹	Secondary MCL ¹⁰
		6.5 to 8.4	AGR ³	Protect sensitive crops ⁴

- 1 Municipal and domestic supply
- 2 J.E. Amooore and E. Hautala, *Odor as an Aid to Chemical Safety: Odor Thresholds Compared with Threshold Limit Values and Volatilities for 214 Industrial Chemicals in Air and Water Dilution*, Journal of Applied Toxicology, Vol. 3, No. 6 (1983).
- 3 Agricultural supply
- 4 Ayers, R. S. and D. W. Westcot, *Water Quality for Agriculture*, Food and Agriculture Organization of the United Nations – Irrigation and Drainage Paper No. 29, Rev. 1, Rome (1985)
- 5 Title 22, California Code of Regulations (CCR), Section 64449, Table 64449-B
- 6 Title 22, CCR, Section 64449, Table 64449-A
- 7 Title 22, CCR, Section 64431, Table 64431-A
- 8 Title 22, CCR, Section 64439
- 9 USEPA Integrated Risk Information System
- 10 Title 40, Code of Federal Regulations, Section 143.3
- 11 California Department of Health Services, Division of Drinking Water and Environmental Management, Drinking Water Action Levels, <http://www.dhs.cahwnet.gov/ps/ddwem>.
- 12 CAL/EPA Toxicity Criteria Database (OEHHA)

Septage waste contains numerous dissolved inorganic waste constituents (i.e., salts, minerals) that together comprise total dissolved solids (TDS). Each component constituent is not individually critical to any beneficial use. Critical constituents are individually listed. The cumulative impact from these other constituents, along with the cumulative affect of the constituents that are individually listed can be effectively controlled using TDS as a generic indicator parameter.

Not all TDS constituents pass through the treatment process and soil profile in the same manner or rate. Chloride tends to pass through both rapidly to groundwater. As chloride concentrations in most

groundwaters in the region are much lower than in treated municipal wastewater, chloride is a useful indicator parameter for evaluating the extent to which effluent reaches groundwater. Boron is another TDS constituent that may occur in wastewater in concentrations greater than groundwater depending on the source water, to the extent residents use cleaning products containing boron, and whether any industrial dischargers utilize boron (e.g., glass production, cosmetics). Other indicator constituents for monitoring for groundwater degradation due to recharged effluent include total coliform bacteria, ammonia, total nitrogen, and Total Trihalomethanes (TTHMs), a by-product of chlorination. Dissolved iron and manganese are useful indicators to determine whether components of the WWTF with high-strength waste constituents, such as sludge handling facilities, are ineffective in containing waste. Exceptionally high TDS and nitrogen also typifies this type of release.

Treatment Technology and Control

Given the character of Class II leachate, septage, and portable toilet waste, secondary treatment technology is generally sufficient to control degradation of groundwater from decomposable organic constituents. Adding disinfection significantly reduces populations of pathogenic organisms, and reasonable soil infiltration rates and unsaturated soils can reduce them further. Neither organics nor total coliform organisms, the indicator parameter for pathogenic organisms, should be found in groundwater in a well-designed, well-operated facility.

Sodium hypochlorite disinfection of effluent causes formation of trihalomethanes, which are priority pollutants. Treatment to reduce these in wastewater generally has not been performed, and little is known at this point on the typical impact on groundwater.

Septage waste typically contains nitrogen in concentrations greater than water quality objectives, which vary according to the form of nitrogen. Degradation by nitrogen can be controlled by tertiary treatment for nitrogen reduction, and agronomic reuse on harvested crops. The effectiveness varies, but generally best practicable treatment and control should be able to control nitrogen degradation at a concentration well below the water quality objectives. The proposed interim limitation reflects water quality objectives.

Waste constituents that are forms of salinity pass through the treatment process and soil profile and effective control of long-term effects relies upon effective source control and pretreatment measures. In the best of circumstances, long-term land discharge of treated municipal wastewater will degrade groundwater with salt (as measured by TDS and EC) and the individual components of salts (e.g., sodium, chloride). The proposed Order sets water quality objectives for the interim while site-specific, constituent-specific limits are developed in conjunction with a BPTC evaluation of source control and pretreatment. The next Order will likely contain effluent limits for salt components other than chloride that, if met, assure groundwater quality will be controlled to an acceptable level.

Other constituents in treated waste that may pass through the treatment process and the soil profile include recalcitrant organic compounds (e.g., ethylene glycol, or antifreeze), radionuclides, and pharmaceuticals. Hazardous compounds are not usually associated with domestic wastes and when

present are reduced in the discharge to inconsequential concentrations through dilution with domestic waste, treatment, and the implementation of effective pretreatment programs. It is inappropriate to allow degradation of groundwater with such constituents, so proposed limitations are nondetect.

A discharge of wastewater that overloads soils with nutrients and organics can result in anaerobic conditions in the soil profile, which in turn creates organic acids and decreases soil pH. Under conditions of low soil pH (i.e., below 5), iron and manganese compounds in the soil can solubilize and leach into groundwater. Discharge of residual sludge to land may also lead to increases in groundwater alkalinity and hardness to concentrations that impair the water's beneficial uses and contribute to an overall increase in TDS. Overloading is preventable. Though iron and manganese limits are set at the water quality objective, groundwater pH is expected to remain the same as background.

Title 27

Title 27, CCR, section 20380 et seq. ("Title 27"), contains regulations to address certain discharges to land. Title 27 establishes a waste classification system, specifies siting and construction standards for full containment of classified waste, requires extensive monitoring of groundwater and the unsaturated zone for any indication of failure of containment, and specifies closure and post-closure maintenance requirements. Generally, no degradation of groundwater quality by any waste constituent is acceptable.

Discharges of domestic sewage and treated effluent can be treated and controlled to a degree that will not result in unreasonable degradation of groundwater. For this reason, they have been conditionally exempted from Title 27, except for residual sludge and solid waste generated as part of the treatment process [section 20090(a) of Title 27]. The condition requires that the discharge not result in violation of any water quality objective in groundwater.

Treatment and storage facilities for sludge that are part of the WWTF are considered exempt from Title 27 under section 20090(a), under the condition that the facilities not result in a violation of any water quality objective. However, residual sludge (for the purposes of the proposed order, sludge that will not be subjected to further treatment by the WWTF) is not exempt from Title 27. Solid waste (e.g., grit and screenings) that results from treatment of domestic sewage and industrial waste also is not exempt from Title 27. This residual sludge and solid waste are subject to the provisions of Title 27.

Accordingly, the municipal discharge of effluent and the operation of treatment or storage facilities associated with a wastewater treatment facility can be allowed without requiring compliance with Title 27, but only if resulting degradation of groundwater is in accordance with the Basin Plan. This means, among other things, degradation of groundwater must be consistent with Resolution 68-16 and in no case greater than water quality objectives. The conditions for sludge, solid waste, and biosolids management proposed in this Order are intended to assure this and must all be evaluated along with other aspects of BPTC.

Proposed Order Terms and Conditions

Discharge Prohibitions and Specifications

The proposed Order establishes an average monthly dry weather flow limit of 10,500 gpd. However, if the Discharger obtains a permit with EID to discharge wastewater to the EID Deer Creek WWTP, the Executive Officer may increase the flow limit up to the calculated disposal capacity. In no case shall the flow shall exceed 16,000 gpd. The proposed discharge specifications for BOD₅ is based on the treatment technologies employed. The proposed Order requires the Discharger to disinfect the effluent when the Discharger disposes of wastewater to the spray disposal field. The discharge specifications regarding dissolved oxygen and freeboard are consistent with Board policy for the prevention of nuisance conditions, and are applied to all such facilities.

In order to protect public health and safety, the proposed Order requires the Discharger to comply with applicable provisions of Title 22 and to implement best management practices with respect to effluent disposal (e.g., to dispose of effluent at reasonable rates considering the crop, soil, climate, and irrigation management plan.).

Monitoring Requirements

Section 13267 of the CWC authorizes the Board to require monitoring and technical reports as necessary to investigate the impact of a waste discharge on waters of the state. In recent years there has been increased emphasis on obtaining all necessary information, assuring the information is timely as well as representative and accurate, and thereby improving accountability of any discharger for meeting the conditions of discharge. Section 13268 of the CWC authorizes assessment civil administrative liability where appropriate.

The proposed Order includes monitoring requirements for influent, effluent, storage tank, spray disposal area, groundwater, and sludge.

The Title 27 zero leakage protection strategy relies heavily on extensive groundwater monitoring to increase a discharger's awareness of, and accountability for, compliance with the prescriptive and performance standards. With a high volume, concentrated, uncontained discharge to land, monitoring takes on even greater importance. The proposed Order includes monitoring of applied waste quality, application rates, and groundwater.

Title 27 regulations pertaining to groundwater monitoring and the detection and characterization of waste constituents in groundwater have been in effect and successfully implemented for many years. No regulation currently specifies similar criteria more suitable for a situation where extensive infiltration into groundwater occurs. However, where, as here, such infiltration occurs, it is appropriate that the Title 27 groundwater monitoring procedures be extended and applied on a case-by-case basis under Water Code section 13267.

INFORMATION SHEET
ORDER NO.
EL DORADO COUNTY
UNION MINE SEPTAGE/LEACHATE TREATMENT FACILITY
EL DORADO COUNTY

8

The Discharger must monitor groundwater for constituents present in the discharge and capable of reaching groundwater and violating groundwater limitations if its treatment and control, and any dependency of the process on sustained environmental attenuation, proves inadequate.

Reopener

The conditions of discharge in the proposed Order were developed based on currently available technical information and applicable water quality laws, regulations, policies, and plans, and are intended to assure conformance with them. However, information is presently insufficient to develop final effluent and groundwater limitations, so the proposed Order contains interim limitations. Additional information must be developed and documented by the Discharger as required by schedules set forth in the proposed Order. As this additional information is obtained, decisions will be made concerning the best means of assuring the highest water quality possible and that could involve substantial cost. It may be appropriate to reopen the Order if applicable laws and regulations change, but the mere possibility that such laws and regulations may change is not sufficient basis for reopening the Order. The CWC requires that waste discharge requirements implement all applicable requirements.

JSK: 12-Jan-06