

California Regional Water Quality Control Board
San Diego Region

David Gibson, Executive Officer



Executive Officer's Report
May 8, 2024

Table of Contents

Part A – San Diego Region Staff Activities2

- 1. Personnel Report.....2
- 2. Response to the Board’s Request for Additional Information Related to Fireworks Events2
- 3. United States and Mexico Border Water Quality Update (*Attachment A-2*)3

Part B – Significant Regional Water Quality Issues20

- 1. Nitrate Exceedances in Domestic Wells in the San Diego Region20
- 2. Conditional Waivers of Waste Discharge Requirements Enrollment Update....21
- 3. Sanitary Sewer Overflows in the San Diego Region – February 2024 (*Attachment B-3*)23
- 4. Transboundary Flows from Mexico into the San Diego Region – January and February 2024 (*Attachment B-4*)25

Part C – Statewide Issues of Importance to the San Diego Region.....27

- 1. Data Solicitation Notice for the 2028 California Integrated Report27

The May report for the Tentative Schedule of Significant NPDES Permits, WDRs, and Actions, Agenda Items Requested by Board Members, and the attachments noted above are included at the end of this report.

Part A – San Diego Region Staff Activities

1. Personnel Report

Staff Contact: Dulce Romero

An updated San Diego Water Board staff list is available online at: [San Diego Regional Water Quality Control Board Staff List \(ca.gov\)](https://www.waterboards.ca.gov/sandiego/about-us/employment/).

Recruitment

We are recruiting for seven positions: one Scientific Aid, one Water Resource Control Engineer and one Environmental Scientist in the Surface Water Protection Branch; one Water Resources Control Engineer in the Healthy Waters Branch; two Water Resources Control Engineers and one Engineering Geologist in the Site Restoration and Groundwater Protection Branch.

Filled Vacancies

The Site Restoration and Groundwater Protection Branch welcomes our new Senior Water Resource Control Engineer, Olufisayo Osibodu. Fisayo worked previously as a Water Resource Control Engineer in the Water Sustainability and Protection Unit.

Information regarding our vacancies is located on the CalCareers and San Diego Water Board websites: <https://calcareers.ca.gov/CalHRPublic/Search/AdvancedJobSearch.aspx>
[https://www.waterboards.ca.gov/sandiego/about us/employment/](https://www.waterboards.ca.gov/sandiego/about-us/employment/).

2. Response to the Board's Request for Additional Information Related to Fireworks Events

Staff Contact: James Chhor

Summary

At its February 2024 meeting, San Diego Water Board's Board Member Gary Strawn requested staff investigate waste reduction methods that could be used to limit the amount of waste generated at fireworks shows, and asked how much of the waste recovered is toxic. In response to Board Member Strawn's request, San Diego Water Board staff conducted a literature review and revisited the most recent regional fireworks-related receiving water monitoring data. Results of that investigation conclude there is no new information to provide beyond what is currently in the record. Post-event cleanup remains the most reasonable and safest method of minimizing water quality pollution from fireworks events held over waterbodies, and data collected to date continues to support the conclusion that receiving water impacts related to fireworks events are short-lived.

Background

Enrollment under Order R9-2022-0002, NPDES Permit CAG999002, *General National Pollutant Discharge Elimination System (NPDES) Permit for Residual Firework Pollutant Waste Discharges to Waters of the United States in the San Diego Region from the Public Display of Fireworks* (General Order) requires implementation of best management practices (BMPs) to reduce and prevent fireworks related pollution to a practical extent.

Enrollees must include a Fireworks Best Management Practices Plan (FBMPP) as part of their application for enrollment under the General Order.

The General Order requires all enrollees to remove hazardous and pyrotechnics waste immediately after an event. However, enrollees have up to 24 hours after a fireworks event to clear the firing range and adjacent surface waters of debris. When drafting the General Order, the San Diego Water Board contemplated including requirements to remove debris from adjacent surface waters during or immediately after an event and to use a barge with sides or netting to prevent debris from entering surrounding waters. Based on interested parties' comments related to safety and conflicting regulations (such as fire code), the San Diego Water Board removed these requirements prior to permit adoption.

SeaWorld San Diego's 2021 monitoring report stated water quality analyses were similar to historical results and concentrations within the fallout area were below screening levels with the exception of total barium. However, total barium results were within historical ranges. Sediment toxicity for amphipod survival showed "low" toxic conditions but were the same for reference samples. Testing using polychaetae worms showed nontoxic conditions for the fallout area and reference samples.

Big Bay Boom's 2015 sampling stated most of the constituents were below applicable water quality standards and exceedances were typically indistinguishable pre- and post-show. The monitoring report did note that dissolved titanium, dissolved cobalt, dissolved lead, total mercury, and total zinc had decreasing trends relative to barge distance. The pattern was also consistent between the barges.

SeaWorld San Diego's and Big Bay Boom's monitoring results suggest water and sediment quality are generally within historical ranges and that fireworks' debris are not accumulating and creating deleterious effects.

The San Diego Water Board staff are currently unaware of any recent peer reviewed studies directly linking the effects of fireworks debris and pollution to either water quality or aquatic environment. The infrequency of fireworks events at most locations, coupled with the wide dispersion of constituents, makes more conclusive studies difficult.

3. United States and Mexico Border Water Quality Update (Attachment A-3)

Staff Contacts: David Gibson and Melissa Corona

Significant updates since April 2024 Executive Officer's Report:

- In late March, the United States Section of the International Boundary and Water Commission (USIBWC) began clean-up of the trash deposited at the West Coast Turf sod farm by transboundary flows in the main channel during the January 22, 2024 storm. USIBWC expects the clean-up will be complete by the end of May 2024. As of April 26, 2024, USIBWC has removed 248 tons of trash and debris.

- On March 29, USIBWC submitted a draft Tijuana River Valley Monitoring Program (TRVMP) Work Plan to the San Diego Water Board. The San Diego Water Board has reviewed the TRVMP Work Plan and will provide comments to USIBWC.
- In early April, USIBWC invited three progressive design-build contractors to submit their technical and cost proposals for the South Bay International Treatment Plant (SBIWTP) expansion from 25 million gallons per day (MGD) to 50 MGD.
- In April, Veolia, the SBIWTP operator, completed clean-out of the grit chamber and put one primary sedimentation tank (PST) back in service. These are critical steps for USIBWC to achieve compliance with secondary treatment standards at the SBIWTP.

Status of Border Infrastructure Repairs and Improvements

When operating properly, the 42-inch PB1A pipeline in the City of Tijuana conveys dry weather flows that are diverted by the Comisión Internacional de Límites y Aguas pump station (PBCILA) from crossing into the United States (U.S.) through the Tijuana River main channel. The PB1A pipeline conveys the flows to a shoreline discharge point at Punta Bandera approximately 4.2 miles south of the international border. On November 30, 2023, USIBWC reported that Mexico completed needed repairs of the PB1A pipeline. The Baja California water utility for the City of Tijuana (CESPT) previously reported that the PB1A pipeline would be fully operational by March 2024. In mid-March, the timeline was extended because CESPT must shut down upstream Mexican pump station PB1 for infrastructure rehabilitation and construction work. CESPT indicated to USIBWC that they expect the shut-down to last ten days. However, CESPT has not indicated the start date to USIBWC or when CESPT expects the PB1A pipeline to be in full service. The PB1 shut-down will likely result in 10-12 MGD of excess flows to the SBIWTP and/or transboundary flows.

Minute 328 of the 1944 U.S.-Mexico treaty, entitled *Utilization of the Colorado and Tijuana Rivers and of the Rio Grande*, approved in July 2022, outlines specific border pollution-related projects planned for 2022-2027 and potential projects for the unspecified future. Minute 328 projects in progress include expanding the SBIWTP, replacing the San Antonio de los Buenos Wastewater Treatment Plant (SABWTP), repairing the International Collector, repairing Los Laureles Pump Station 1, repairing the PB1 pump station, and installing back-up power supply for PB1 in the U.S. Minute 328 projects in progress include expanding the SBIWTP, replacing the San Antonio de los Buenos Wastewater Treatment Plant (SABWTP), repairing the International Collector, repairing Los Laureles Pump Station 1, repairing the PB1 pump station, and installing back-up power supply for PB1 in the U.S.

USIBWC accepted statements of qualifications from interested bidders on the SBIWTP expansion until February 8, 2024. USIBWC accepted statements of qualifications from interested bidders on the SBIWTP expansion until February 8, 2024. In April, the three best qualified bidders were invited to submit their technical and cost proposals by June 14, 2024, for final selection of the design-build contractor. USIBWC expects to select the progressive design-build contractor and award the contract in Summer 2024. Construction is expected to start within one year of the contract award. The SBIWTP average treatment capacity will be expanded from 25 MGD to 50 MGD.

The SBIWTP expansion is a core project of the USIBWC and U.S. Environmental Protection Agency (USEPA) June 2023 Joint Record of Decision (ROD) for projects to reduce transboundary water pollution. The cost of the SBIWTP expansion is expected to be approximately \$610 million. In 2020, the U.S. federal government, through USEPA, committed \$300 million in the United States-Mexico-Canada Agreement (USMCA). An additional funding request of \$310 million was announced by President Biden on October 25, 2023, in response to bipartisan efforts by local representatives to increase available funding to match the expected cost of the SBIWTP expansion. The cost of the SBIWTP expansion is expected to be approximately \$610 million. In 2020, the U.S. federal government, through USEPA, committed \$300 million in the United States-Mexico-Canada Agreement (USMCA). An additional funding request of \$310 million was announced by President Biden on October 25, 2023, in response to bipartisan efforts by local representatives to increase available funding to match the expected cost of the SBIWTP expansion. If Congress authorizes and allocates the needed supplemental funding, USIBWC expects the construction to be completed in 2027.

In March 2024, Congress authorized \$156 million for USIBWC projects in the federal Fiscal Year 2024 Appropriations Bill (HR 2882). A portion of this funding will go toward the SBIWTP expansion. USIBWC and USEPA have contingency plans if the remaining funds needed are not authorized. This includes expanding primary treatment to 50 MGD in the first phase and completing the expansion for secondary when full funding is authorized and allocated.

To date, no funding has been identified for any of the other eight projects included in the ROD to address transboundary flows. Without full implementation of the ROD, transboundary flows of polluted water and trash are likely to continue to impact the Tijuana River Valley, Tijuana River Estuary, and coastal waters from the international border to the City of Coronado. Without full implementation of the ROD, transboundary flows of polluted water and trash are likely to continue to impact the Tijuana River Valley, Tijuana River Estuary, and coastal waters from the international border to the City of Coronado.

As of January 11, 2024, the SABWTP is under construction. As of January 11, 2024, the SABWTP is under construction. The project is fully funded by Mexico and will include rehabilitation of the existing plant, treatment upgrades, and a 600-foot coastal outfall. The Mexican Secretariat of National Defense (SEDENA) is leading the construction and has completed the clean-out of one wastewater lagoon at the existing plant. Completion of the project is scheduled for September 2024. The new SABWTP will treat 18 MGD, which will reduce the volume of untreated wastewater that is currently discharged to the shoreline discharge point at Punta Bandera.

Repairs to the damaged 60-inch International Collector pipeline have been completed and it will be relined. The schedule to reline it is contingent upon a Mexican highway construction project, which requires sewage collection pipeline realignments. The schedule to reline it is contingent upon a Mexican highway construction project, which requires sewage collection pipeline realignments.

The rehabilitation of Los Laureles Pump Station 1 is underway. The rehabilitation of Los Laureles Pump Station 1 is underway. When in operation, the pump station conveys sewage from Los Laureles Canyon in Tijuana to the SABWTP. Currently, the SAWBTP does not

provide reliable wastewater treatment and flows are discharged to the shoreline at Punta Bandera. Until the pump station has been repaired, ongoing dry weather transboundary flows will continue to flow to Goat Canyon.

CESPT has completed the design for pump station PB1 rehabilitation and USIBWC has engaged San Diego Gas and Electric (SDG&E) on installation of back-up power supply for PB1 in the U.S. USIBWC reported that contracts for the rehabilitation of PB1 will be awarded in May 2024 with construction to begin in July 2024. The project is expected to take two years.

Status of Compliance at the SBIWTP

Average flows into the SBIWTP varied from approximately 20 MGD to 23 MGD in March and April 2024. While repairs and rehabilitation efforts described below are underway, USIBWC remains out of compliance with Order No. R9-2021-0001 as amended by Order No. R9-2023-0009, National Pollutant Discharge Elimination System No. CA0108928, *Waste Discharge Requirements for the United States Section of the International Boundary and Water Commission South Bay International Wastewater Treatment Plant Discharge to the Pacific Ocean Through the South Bay Ocean Outfall* (NPDES Permit) and Cease and Desist Order No. R9-2021-0107 as amended by Order No. R9-2021-0220, *United States Section of the International Boundary and Water Commission South Bay International Wastewater Treatment Plant Discharge to the Pacific Ocean Through the South Bay Ocean Outfall* (CDO). Violations include, but are not limited to, the following:

- Exceedances of secondary treatment effluent standards in the NPDES Permit.
- Re-submittal of at least six self-monitoring reports (SMRs) with reporting errors.

So far, the San Diego Water Board has issued seven notices of violation (NOVs) to USIBWC. The San Diego Water Board intends to continue issuing NOVs until USIBWC has attained compliance with the secondary treatment standards in the NPDES Permit. Copies of the NOVs and exhibits are attached.

On April 1, 2024, USIBWC submitted a draft TRVMP Work Plan to the San Diego Water Board by email. The TRVMP Work Plan was due by September 29, 2021, per Attachment E, Section 4.2.4 of the NPDES Permit. The San Diego Water Board will review the TRVMP Work Plan and provide comments to USIBWC by April 30, 2024.

The San Diego Water Board adopted Time Schedule Order No. R9-2023-0189, *United States Section of the International Boundary and Water Commission South Bay International Wastewater Treatment Plant Discharge to the Pacific Ocean Through the South Bay Ocean Outfall* (TSO) on December 18, 2023. The TSO establishes interim reporting requirements and a deadline of August 15, 2024, for return to full compliance with the NPDES Permit and CDO. The TSO establishes interim reporting requirements and a deadline of August 15, 2024, for return to full compliance with the NPDES Permit and CDO.

Board staff are meeting weekly with USIBWC to receive status updates and inspect the SBIWTP. Board staff are meeting weekly with USIBWC to receive status updates and inspect the SBIWTP. The San Diego Water Board has dedicated a full-time Water Resource Control Engineer to these efforts.

The TSO requires USIBWC to present an oral report to the San Diego Water Board within approximately 180 days of the adoption of the TSO. The report must summarize USIBWC's efforts to achieve compliance with the directives in the TSO. The Commissioner of USIBWC, Dr. Maria-Elena Giner, is scheduled to provide the update in person at the May 8, 2024, San Diego Water Board meeting.

Impacts of Winter Storms

The 2023-2024 storm season resulted in excess flows to the SBIWTP and excessive sediment into the plant, the Goat Canyon Collector, and the Smuggler's Gulch Canyon Collector.

Excessive sediment loading consistently rendered components of the SBIWTP headworks inoperable, necessitating time-consuming, costly, and sometimes complicated repairs. The sediment regularly impacted operations downstream of the headworks as well. High influent flows during storm events introduced excessive rags to the SBIWTP, which also impact operations and necessitate unanticipated, sometimes urgent, maintenance and repairs, which can take the SBIWTP operators away from other important (scheduled) maintenance and repairs.

Dry and wet weather transboundary flows have deposited immense volumes of sediment from large construction projects in Tijuana into these two canyon collector basins, rendering them inoperable. Veolia clears sediment and debris from the canyon collector basins between storm events and returns the canyon collectors to service once they are capable of diverting dry weather flows without causing damage to pumps. Veolia clears sediment and debris from the canyon collector basins between storm events and returns the canyon collectors to service once they are capable of diverting dry weather flows without causing damage to pumps.

Winter storms damaged the berm of Smuggler's Channel in the Tijuana River Valley, resulting in flows of wastewater, trash, and sediment onto private property. The flows also drained west, breaching a second berm and flooding the County of San Diego's Tijuana River Valley Regional Park Campground with wastewater.

During a January 22, 2024 large storm event, the main channel of the river flooded the West Coast Turf sod farm. This property is owned by USIBWC, located within the USIBWC Flood Control Channel, and leased by USIBWC to West Coast Turf. The flooding breached the north levee of the USIBWC Flood Control Channel, deposited significant amounts of trash, including on the sod farm, and resulted in significant ponding of wastewater. In March 2024, USIBWC initiated clean-up of the sod farm. As of April 23rd, 126 tons of trash had been removed. USIBWC expects the clean-up will be complete by the end of May 2024.

Figure 1: Sediment retrieved from wastewater influent at headworks. (MC 04/02/2024)



Figure 2: Trash and sediment at Smuggler's Gulch Canyon Collector. Bollards are approximately five feet in height. (Veolia 04/01/2024)



Figure 3: Wastewater and trash at the northwest corner of the sod farm. (MC 04/02/2024)



Status of Repairs to the SBIWTP

USIBWC is working on repairs to the SBIWTP related to deferred maintenance and damage caused by Tropical Storm Hilary in August 2023.

Status of Junction Box 1 (JB1) Repairs/Replacement

When operating properly, JB1 controls flows into the SBIWTP. USIBWC has been unable to control flows through JB1 since October 3, 2020.

JB1 has two inoperable gate valves, a 72-inch gate valve that connects to the International Collector and a 96-inch gate valve that connects to Junction Box 2. The 72-inch gate valve became inoperable on August 28, 2019. The 96-inch gate valve became inoperable on October 3, 2020. Since flows from Mexico to the SBIWTP are regulated at JB1 and the two gate valves are inoperable, USIBWC cannot regulate flows from Mexico and must accept all flows that reach JB1.

JB1 must be completely replaced. USIBWC awarded a contract to replace JB1 to Filanc, a design-build contractor, in August 2023. Filanc is in the process of designing the new junction box. USIBWC provided comments on the 60 percent design on March 28, 2024. Filanc is discussing the comments with USIBWC and working on the 90 percent design. USIBWC estimates that a new junction box will be installed by February 10, 2025.

Figure 4: Junction Box 1. (MC 01/10/2024)



Status of Influent Pump Repairs/Replacements

USIBWC reported that three of the six influent pumps are operational. The other three inoperable influent pumps have been removed. USIBWC received delivery of two new pumps in December 2023. USIBWC has indicated that three pumps are sufficient to meet their current needs. One pump (primary) is adequate for daily flows of 25 MGD, a second pump (peak flow pump) is on standby for peak flows, and a third pump is backup for the primary and peak flow pumps as a failsafe.

The TSO outlines tasks and interim goals related to long-term compliance with secondary effluent limitations. This includes replacement of two influent pumps by February 28, 2024. Veolia has attempted to install the pumps since January 31, 2024. Veolia has not yet been able to install them due to the build-up of sediment and rocks in the pump wet wells. Immense volumes of sediment are present in the wastewater influent from Mexico. The sediment accumulates in the wet wells of the pumps and disrupts treatment operations. USIBWC and Veolia are organizing a plan that would allow Veolia to remove the sediment and install the two influent pumps by July 2024. USIBWC aims to have all the influent pumps operational by the end of 2024.

Figure 5: Influent pumps. (MC 04/03/2024)



Figure 6: Two new influent pumps on the left. Three inoperable influent pumps on the right that have been removed for replacement. (MC 01/10/2024)



Figure 7: Closer view of one of the new influent pumps. (USIBWC 12/13/2023)



Status of Grit Chamber Cleaning

Veolia completed clean-out the grit chamber on April 10, 2024. Approximately 1,000 cubic yards of grit were removed, the full capacity of the grit chamber. The grit chamber had to be cleaned out before PST No. 5 was returned to operation.

Status of the PST Cleaning and Repairs

The primary treatment system at the SBIWTP includes five PSTs. Currently, only one is operational.

PST Nos. 1-4 are full of sediment and debris, and influent passes through these PSTs without significant treatment. The chains and flights are not functional and will be replaced. Chains and flights for PST Nos. 1-4 have been delivered.

As of April 15, 2024, PST No. 5 is now in service.

USIBWC has begun to rehabilitate PST Nos. 1 and 2 (replace the chain, flights, and other equipment) and will then rehabilitate PST Nos. 3 and 4.

USIBWC expects to have three PSTs operational by Summer 2024, and all PSTs operational by December 2024. USIBWC states that operation of three PSTs by July 2024 should be adequate to return the SBIWTP to compliance with secondary treatment standards by the compliance date of August 15, 2024, contingent upon the SBIWTP receiving reasonable flows despite JB1 not being operational until 2025.

Figure 8: Rehabilitated PST No. 5. in service (USIBWC 04/17/2024)



Figure 9: Skimmer trough at PST No. 5. prior to resuming service (MC 01/10/2024)



Figure 10: One of four inoperable PSTs. (MC 04/02/2024)



Status of Secondary Treatment Repairs and Replacement

The secondary treatment system at the SBIWTP includes seven aeration tanks and 13 secondary settling tanks. USIBWC plans to replace pumps, motors, mixers, waste activated sludge pumps, and non-potable pumps in the secondary treatment in 2024 as part of its capital improvements project package referred to as the “pumps and motors package,” which was awarded to Veolia in April 2024.

Once the PSTs are operational and the flow rate consistently remains below 25 MGD, USIBWC and Veolia expect the SBIWTP to be in compliance with secondary treatment requirements, with a trend towards compliance visible within the first month. Veolia expects the effluent from the primary treatment system not to overload the secondary treatment system, resulting in total suspended solids (TSS) results dropping from 300 mg/L to below 100 mg/L.

Figure 11: A photo of a secondary mixing tank.



Figure 12: Secondary settling tank. (MC 01/10/2024)



Status of Canyon Collector Pump Stations

There are two canyon collector pump stations: Goat Canyon Pump Station and Hollister Pump Station. Both are operational.

The Goat Canyon Pump Station has four pumps, three of which are operational. The Goat Canyon Pump Station moves flows from the Goat Canyon Collector to the Hollister Pump Station. All four pumps at the Goat Canyon Pump Station need to be replaced. USIBWC expects to award a contract to replace the pumps sometime before September 30, 2024.

The Hollister Pump Station moves flows from the Smuggler's Gulch Canyon Collector and from the Goat Canyon Pump Station to the SBIWTP. The Hollister Pump Station has four pumps, three of which are operational. Two of the pumps were replaced with new pumps in 2023, and the other two will be replaced in 2024.

Excessive sediment has been transported by transboundary flows to Smuggler's Gulch due to a large highway construction project in Matadero Canyon. There are ongoing excessive flows due to pump station failure in Matadero Canyon. This severely impedes the operation of the Smuggler's Gulch Canyon Collector and the pumps at the Hollister Pump Station.

Figure 13: Mexican construction project in Matadero Canyon. (MC 01/10/2024)



Status of State of California Projects to Mitigate Transboundary Pollution

Three projects in the Tijuana River Valley were funded by Senate Bill 170 through the State Water Resources Control Board Division of Financial Assistance:

- Tijuana River Flood Control Trash Control Structure (\$4.73 million – Rural Community Assistance Center)
- Smuggler's Gulch Dredging Project (\$4.25 million – County of San Diego)
- Tijuana River Valley Hydrology and Habitat Restoration (\$2 million – County of San Diego)

Each of the three projects are deeply rooted in the 13 years of coordinated federal, State of California, local agency, and non-governmental organization efforts in the Tijuana River Valley Recovery Team to restore and protect water quality. They were originally proposed in the 2012 *Tijuana River Valley Recovery Strategy: Living with the Water* and refined and analyzed in the 2020 *Tijuana River Needs and Opportunities Assessment Report*.

The Tijuana River trash control project involves the design, construction, operation, and maintenance of a floating trash boom system for one storm season in the main channel of the river, immediately downstream of the international border. The Rural Community Assistance Center is in the process of obtaining environmental permits to install the trash boom. Installation is expected to be complete by the beginning of the 2024-2025 storm season. This is a demonstration project. The information gathered will be used to develop permanent trash control infrastructure.

The Smuggler's Gulch dredging project will remove up to 30,000 cubic yards of accumulated sediment, trash, and debris in Smuggler's Gulch and the Tijuana River Pilot Channel. The accumulated sediment, trash, and debris contribute to flooding, which threatens public and private properties and critical habitats. In March 2024, the County of San Diego initiated trash and sediment removal activities, which are ongoing. Current efforts are focused on Smuggler's Gulch, north of Monument Road. The dredging is necessary prior to installation of permanent sediment and trash capture infrastructure at Smuggler's Gulch, which will be funded by a separate grant. The project will be completed by fall 2025.

The Tijuana River Valley habitat and hydrology restoration project will remediate a contaminated seven-acre property adjacent to the Tijuana River and restore it to native upland coastal sage scrub habitat. In January 2024, the County of San Diego started preparing the site for the upcoming demolition and removal of on-site structures containing hazardous materials, such as asbestos and lead. Demolition of on-site structures is complete. Site preparation, debris removal, and irrigation is now underway. The project will be completed by fall 2025.

Status of Advance Restoration Plan (ARP)

The San Diego Water Board developed the draft *Lower Tijuana River Indicator Bacteria and Trash Advance Restoration Plan for Total Maximum Daily Loads* (draft ARP) to address water quality impairments through an implementation plan with actions to restore and maintain water quality standards. The draft ARP was initially drafted as a total maximum daily load (TMDL) pollution control plan. Waters with an ARP remain on the Clean Water Act section 303(d) List

of Water Quality Limited Segments (303(d) List) until requirements to remove the 303(d) listing are met. If the lower Tijuana River remains on the 303(d) List due to indicator bacteria and trash despite implementation of the ARP, the San Diego Water Board will adopt TMDLs as an amendment to the *Water Quality Control Plan for the San Diego Basin (9)*.

The San Diego Water Board posted the draft ARP on its website for public review and comment on January 10, 2024, and accepted written comments until March 13, 2024. The San Diego Water Board hosted an in-person public workshop and a separate virtual public workshop on February 26 and 28, 2024, respectively. The purpose of the public workshops was for the San Diego Water Board to (1) provide an overview of the draft ARP; (2) receive verbal comments from interested parties on the draft ARP; and (3) in accordance with Assembly Bill 2108, receive verbal comments on any concerns related to environmental justice or potential impacts on water quality for disadvantaged communities and/or Native American Tribes due to the draft ARP's future implementation.

The San Diego Water Board received written comments on the draft ARP from the Mayor of Imperial Beach, San Diego Coastkeeper, and Phase I municipal separate storm sewer systems (MS4) Copermittees of the Tijuana River Watershed Management Area.

San Diego Water Board staff will present the ARP to the San Diego Water Board to consider adoption in 2024. The ARP implementation plan proposes a memorandum of understanding between the San Diego Water Board, USIBWC, USEPA, and possibly the Department of Homeland Security to establish agreements, roles, and responsibilities to control transboundary sources of pollution within specified timeframes, respective jurisdictions, and respective funding allocations.

Minute 320¹

Minute 320 meetings were convened by the U.S. and Mexican sections of IBWC in Imperial Beach and Tijuana on November 30 and December 1, 2023. Meeting participants proposed projects for further development in both countries to address sediment, trash, and water quality. Following the meetings, the Minute 320 Technical Secretariat and IBWC Commissioners reviewed the proposed projects. On March 19, 2024, the executive-level Minute 320 Binational Core Group met to review the proposed projects, select priorities, discuss project workgroups to advance technical work and financing, and submit invitations to proposed binational workgroup chair and co-chair candidates. The Minute 320 binational workgroups will meet to review the draft Tijuana River Valley Monitoring Plan (TRVMP) Work Plan (required per the NPDES Permit), document the process of addressing other SBIWTP NPDES permit requirements, discuss the status of projects and initiatives that are under development, establish a framework to monitor progress and impacts of proposed projects and initiatives, and establish a process for retaining information and coordinating monitoring efforts.

¹ Minute 320 of the 1944 U.S.-Mexico treaty, entitled *Utilization of the Colorado and Tijuana Rivers and of the Rio Grande*, establishes a framework of binational collaboration to address trash, sediment, and water quality issues.

Part B – Significant Regional Water Quality Issues

1. Nitrate Exceedances in Domestic Wells in the San Diego Region

Staff Contacts: Cailynn Smith and Abigail Pashina

Under the California Safe Drinking Water Act of 1996, the Office of Environmental Health Hazard Assessment (OEHHA) develops Public Health Goals (PHGs) for drinking water contaminants in California based exclusively on public health considerations.² The State Water Resources Control Board (State Water Board) uses the PHGs to establish primary drinking water standards (California Maximum Contaminant Levels, or CA MCLs). The CA MCL established by the State Water Board for nitrate is 45 mg/L as NO₃, which is consistent with the PHG developed by OEHHA. The State Water Board Division of Drinking Water (DDW) regulates public drinking water systems and requires drinking water systems to notify their customers when there is an exceedance of CA MCLs, including the CA MCL for nitrate.

Ingesting water containing nitrate above the CA MCL can cause nitrate poisoning as nitrate can inhibit the blood's ability to carry oxygen by turning hemoglobin into methemoglobin.³ Common symptoms of nitrate poisoning include shortness of breath and blueness of the skin around the eyes and mouth (commonly referred to as "blue-baby syndrome" in infants). Infants under six months of age, pregnant persons, the elderly, and people with heart or lung diseases are particularly susceptible to nitrate poisoning. Due to these risks, it is vital to monitor drinking water for nitrate.

Order No. R9-2016-0004, *General Waste Discharge Requirements for Discharges from Commercial Agricultural Operations for Dischargers that are Members of a Third-Party Group in the San Diego Region*, and Order No. R9-2016-0005, *General Waste Discharge Requirements for Discharges from Commercial Agricultural Operations for Dischargers Not Participating in a Third-Party Group in the San Diego Region* (collectively, the Ag Orders), require Third-Party Groups, on behalf of their members, and growers enrolled as individuals to monitor on-farm drinking water wells for nitrate. The Ag Orders include this requirement because (1) nitrogen applied to the land as fertilizer is a potential source for nitrate in groundwater and (2) DDW does not have a formal mechanism in place to notify individuals who have a private water system of any exceedances of the nitrate CA MCL. To fill this gap, the Ag Orders require Third-Party Groups or the San Diego Water Board to notify growers with drinking water wells with samples that exceed the nitrate CA MCL of the exceedance and the health risks associated with drinking water contaminated with nitrate.

² Office of Environmental Health Hazard Assessment's Public Health Goals for Nitrate and Nitrite in Drinking Water:

<https://oehha.ca.gov/media/downloads/water/chemicals/phg/nitratephg051118.pdf>.

³ Groundwater Fact Sheet Nitrate:

https://www.waterboards.ca.gov/water_issues/programs/gama/docs/coc_nitrate.pdf.

2. Conditional Waivers of Waste Discharge Requirements Enrollment Update

Staff Contacts: Mahsa Izadmehr and Fisayo Osibodu

The California Water Code allows the San Diego Water Board to conditionally waive waste discharge requirements for a specific discharge or type of discharge, if the waiver is consistent with *the Water Quality Control Plan for the San Diego Basin* (Basin Plan) and is in the interest of the public. Conditional waivers allow the San Diego Water Board to use fewer resources to regulate discharges that pose a low threat to water quality, allowing staff resources to focus on discharges that have a higher potential threat to water quality in the San Diego Region. Dischargers also benefit from fewer regulatory requirements when discharging in compliance with a waiver.

The San Diego Water Board adopted [Order No. R9-2024-0001](#), *Conditional Waivers of Waste Discharge Requirements for Low Threat Discharges in the San Diego Region* (Order No. R9-2024-0001) in March 2024. The Board's adoption of Order No. R9-2024-0001 revised and renewed ten existing waivers that were set to expire in May 2024. Order No. R9-2024-0001 identifies several types of discharges for which the requirements to file a Report of Waste Discharge and regulation under waste discharge requirements were appropriately waived. Instead of developing waivers for each specific type of discharge, Order No. R9-2024-0001 groups types of waste discharges that are similar in nature or originate from a common setting or operation together into ten "discharge classifications." The discharge classifications are:

1. Discharges from On-site Graywater Disposal Systems
2. Miscellaneous "Low Threat" Discharges to Land
3. Discharges of Winery Process Water to Lined Evaporation Ponds at Small Wineries
4. Discharges from Silvicultural Operations
5. Discharges from Animal Operations
6. Discharges from Aquatic Animal Production Facilities
7. Discharges of Slurries to Land
8. Discharges/Disposal of Solid Wastes to Land
9. Aerially Discharged Wastes Over Land
10. Discharges of Emergency/Disaster Related Wastes.

Figure 14 illustrates the distribution of waiver enrollments since 2014 and shows the most frequently used waivers continue to be:

- Waiver No. 2 - Miscellaneous "Low Threat" Discharges to Land
- Waiver No. 7 - Discharges of Slurries to Land
- Waiver No. 8 - Discharges/Disposal of Solid Wastes to Land
- Waiver No. 9 - Aerially Discharged Wastes Over Land.

Figure 14: Number of Enrollments in Each Waiver from 2014 to Date





Figure 15 shows the enrollment trends per year for the four most frequently used waivers from 2014 to date. Overall, the number of new enrollments per year for these waivers shows a downward trend, which could be due to fewer development projects in the region.

Figure 15 Number of Waiver Enrollments Per Year from 2014 to March 2024 (For Waivers 2, 7, 8, and 9)



3. Sanitary Sewer Overflows in the San Diego Region – February 2024 (Attachment B-3)

Staff Contacts: James Chhor

Sanitary sewer systems experience periodic failures resulting in sanitary sewer overflow (SSO) discharges that may affect waters of the United States and/or the State of California (State). There are many factors (including factors related to geology, design, construction methods and materials, age of the system, population growth, and system operation and maintenance), that can influence the likelihood of an SSO and the volume of the discharge. Major causes of SSOs include: grease blockages, root blockages, sewer line flood damage, manhole structure failures, vandalism, pump station failures, power outages, excessive stormwater inflow or groundwater infiltration, debris blockages, failures due to aging sanitary sewer systems, lack of proper operation and maintenance, insufficient capacity, and contractor-caused damages. Many SSOs are preventable with adequate and appropriate facilities, source control measures, and proper operation and maintenance of the sanitary sewer system.

SSO discharges from public sewage collection systems and private laterals in the San Diego Region can contain high levels of suspended solids, pathogens, toxic pollutants, nutrients, and oil and grease. SSO discharges can pollute surface and ground waters, thereby threatening

public health, adversely affecting aquatic life, and impairing the recreational use and aesthetic enjoyment of surface waters. Typical impacts of SSO discharges include closure of beaches and other recreational areas, inundation of property, and pollution of rivers, estuaries, and beaches.

State agencies, municipalities, counties, districts, and other entities (collectively referred to as public entities) that own or operate sewage collection systems report SSO spills through an on-line database system, the *California Integrated Water Quality System* (CIWQS). These SSOs are required to be reported under the [Statewide General SSO Order](#),⁴ the [San Diego Regional General SSO Order](#),⁵ and/or individual National Pollutant Discharge Elimination System (NPDES) permit requirements. Some federal entities⁶ report this information voluntarily. Most SSO reports are available to the public on a real-time basis at the [State Water Board Public SSO Report Database](#).

Details on the reported SSOs and private lateral sewage discharges (PLSDs) for February 2024 are provided in the following attached tables:

- Table 1: February 2024- Summary of Public and Federal Sanitary Sewer Overflow Events
- Table 2: February 2024 - Summary of Private Lateral Sewage Discharge Events
- Table 3: February 2024 - Summary of Sewage Discharges by Source

A summary view of information on sewage spill trends from February 2023 to February 2024 are provided in the following attached figures:

- Figure 1: Number of Spills per Month
- Figure 2: Volume of Public SSOs per Month
- Figure 3: Volume of Federal SSOs per Month
- Figure 4: Volume of PLSDs per Month

The Statewide General SSO Order which became effective on June 5, 2023, no longer requires agencies to submit electronic spill reports for public SSOs that are less than 50 gallons in volume that do not reach surface waters. Some agencies may still voluntarily report

⁴ State Water Board Order WQ 2022-0103-DWQ, *Statewide General Waste Discharge Requirements General Order for Sanitary Sewer Systems*. State Water Board Order WQ 2022-0103-DWQ was adopted on December 9, 2022, and became effective on June 5, 2023. State Water Board Order WQ 2022-0103-DWQ supersedes Order 2006-0003-DWQ, the previous statewide waste discharge requirements for sanitary sewer systems.

⁵ San Diego Water Board Order No. R9-2007-0005, *Waste Discharge Requirements for Sewage Collection Agencies in the San Diego Region*.

⁶ Marine Corp Base Camp Pendleton reports sewage spills to CIWQS as required by its individual NPDES permit, Order No R9-2019-0167, NPDES Permit No. CA0109347, *Waste Discharge Requirements for the Marine Corps Base, Camp Pendleton, Southern Regional Tertiary Treatment Plant and Advanced Water Treatment Plant at Haybarn Canyon, Discharge to the Pacific Ocean through the Oceanside Ocean Outfall*. The United States Marine Corps Recruit Depot and the United States Navy voluntarily report sewage spills through CIWQS.

that information. As a result, tables 1 and 3, and figures 1 and 2 may not include information from public SSOs that are less than 50 gallons in volume that did not reach surface waters. Some agencies are still voluntarily submitting electronic spill reports for spills from private laterals less than 50 gallons in volume that do not reach surface waters.

From February 2023 to February 2024, 33 of the 68 collection systems in the San Diego Region reported one or more sewage spills. Thirty-five collection systems did not report any sewage spills. A total of 207 sewage spills were reported with about 30,674,896 gallons of sewage reaching surface waters.

Additional information about the San Diego Water Board sewage overflow regulatory program is available on the [San Diego Water Board's SSO Website](#).

4. Transboundary Flows from Mexico into the San Diego Region – January and February 2024 (Attachment B-4)

Staff Contact: Melissa Corona

Water and wastewater in the Tijuana River and from canyons located along the international border ultimately drain from the City of Tijuana, Baja California, Mexico (Tijuana) into the United States (U.S.). The water and wastewater flows are collectively referred to as transboundary flows. The U.S. Section of the International Boundary and Water Commission (USIBWC) built canyon collectors that are intended to capture dry weather transboundary flows for treatment at the South Bay International Wastewater Treatment Plant (SBIWTP) located in U.S. near the U.S.-Mexico border. Dry weather transboundary flows that are not captured by the canyon collectors for treatment at the SBIWTP, such as flows within the main channel of the Tijuana River,⁷ are reported by USIBWC pursuant to [Order No. R9-2021-0001](#), the National Pollutant Discharge Elimination System (NPDES) permit for the SBIWTP discharge. These uncaptured flows can enter waters of the U.S. and/or the State of California (State), potentially polluting the Tijuana River Valley and Estuary, and south San Diego beach coastal waters.

According to the 1944 *Water Treaty for the Utilization of Waters of the Colorado and Tijuana Rivers and of the Rio Grande* and stipulations established in [IBWC Minute No. 283](#), the U.S. and Mexican sections of the International Boundary and Water Commission (IBWC) share responsibility for addressing border sanitation problems, including transboundary flows. Efforts on both sides of the border have led to the construction and ongoing operation of several pump stations and treatment plants to reduce the frequency, volume, and pollutant levels of transboundary flows. This infrastructure includes, but is not limited to, the following:

- The SBIWTP, located just north of the U.S.-Mexico border, which provides secondary treatment for a portion of the sewage from Tijuana and dry weather transboundary flows conveyed from canyon collectors located in Stewart's Drain, Silva Drain, Canyon del Sol,

⁷ Tijuana River transboundary flows typically consist of a mixture of groundwater, urban runoff, storm water, treated sewage wastewater, and untreated sewage wastewater from infrastructure deficiencies and other sources in Mexico.

Smugglers Gulch, and Goat Canyon. The treated wastewater is discharged to the Pacific Ocean through the South Bay Ocean Outfall. The discharge is regulated by USIBWC's NPDES permit, Order No. R9-2021-0001.

- Several pump stations and wastewater treatment plants (WWTPs) in Mexico, including the San Antonio de los Buenos WWTP, the La Morita WWTP, and the Arturo Herrera WWTP.
- The River Diversion Structure and Pump Station CILA in Tijuana are intended to divert dry weather transboundary flows in the main channel of the Tijuana River. The flows are diverted to a discharge point at the Pacific Ocean shoreline, approximately 4.2 miles south of the U.S.-Mexico border; or the flows can be diverted to the SBIWTP or the San Antonio de los Buenos WWTP, depending on how the Baja California water utility for the City of Tijuana (CESPT) directs the flow. The River Diversion Structure is not designed to collect wet weather river flows of any dry weather flows over 1,000 liters per second (35.3 cubic feet per second, 22.8 million gallons per day).

In January 2024, there were a total of two new dry weather transboundary flows reported by USIBWC, resulting in approximately 24,070 gallons of contaminated water flowing from Mexico into the U.S. This includes one spill from the Goat Canyon Pump Station. In February 2024, USIBWC reported that there were no new dry weather transboundary flows.

Wastewater has been flowing through the main channel since October 2023 due to ongoing storm water runoff that exceeds the dry weather diversion capacity.

Details on the transboundary flows reported for January and February 2024 are provided in the attached tables:

- Table 1: January and February 2024 - Summary of Transboundary Flows from Mexico by Event
- Table 2: January and February 2024 - Summary of Transboundary Flows from Mexico

A summary view of information on transboundary flow trends are provided in the following attached figures:

- Figure 1: Number of Transboundary Flows per Month
- Figure 2: Tijuana River Transboundary Flow Volume per Month
- Figure 3: Canyon Collector Transboundary Flow Volume per Month

These figures show the number and volume of transboundary flows per month from January 2023 through February 2024. During this period, there were a total of 27 reported transboundary flows resulting in approximately 32 billion gallons of contaminated water flowing from Mexico into the United States.

Part C – Statewide Issues of Importance to the San Diego Region

1. Data Solicitation Notice for the 2028 California Integrated Report

Staff Contact: Chad Loflen

The State Water Board is soliciting data and information for water bodies in the San Diego Region to inform the compilation of the 2028 Integrated Report. Data and information received will be evaluated and, if appropriate, used to assess the overall surface water quality conditions including identifying impaired waters (i.e., waters not meeting water quality standards). [See the solicitation notice here.](#)

For the 2028 California Integrated Report, the Central Coast Regional Water Quality Control Board, Sacramento-San Joaquin River Delta and the Tulare Lake Basin of the Central Valley Regional Water Quality Control Board, and the San Diego Regional Water Quality Control Board will evaluate all readily available data from surface waters within their regional boundaries.

To be considered for the 2028 California Integrated Report:

- Data and information can be submitted via the California Environmental Data Exchange Network ([CEDEN](#)), or the [Integrated Report Upload Portal webpage](#) for datasets incompatible with CEDEN. Guidance on how to submit data and information is detailed on the [Submitting Data and Information for the Integrated Report webpage](#).
- Submittals must include the data elements required for assessment. Required data elements and instructions for submitting data are detailed in the [solicitation notice](#).

Data and information submissions must be received by the State Water Board no later than 12:00 p.m. on October 23, 2024.

The 2028 Integrated Report satisfies two of the state's reporting requirements under the Clean Water Act (CWA). One is the CWA section 303(d) requirement to identify impaired waterbodies that are not meeting or not expected to meet water quality standards (commonly called the "303(d) list of impaired waters" or the "303(d) list"). The 303(d) list is used to identify that a total maximum daily load or other regulatory control action is needed to address an impairment and restore water quality standards. The other is the CWA section 305(b) requirement to report on water quality conditions (commonly called the "305(b) report").

Questions regarding data or information submittals, or about other information included in this notice, should be directed to WQAssessment@waterboards.ca.gov.

The solicitation notice and information specific to the 2028 California Integrated Report are available on the 2028 Integrated Report webpage: https://www.waterboards.ca.gov/water_issues/programs/water_quality_assessment/2028-integrated-report.html.

Additional information about the California Integrated Report is available on the Surface Water Quality Assessment webpage:

https://www.waterboards.ca.gov/water_issues/programs/water_quality_assessment/.

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
SAN DIEGO REGION

Significant NPDES Permits,
WDRs, and Actions of the
San Diego Water Board

May 8, 2024

APPENDED TO EXECUTIVE OFFICER'S REPORT

**TENTATIVE SCHEDULE
SIGNIFICANT NPDES PERMITS, WDRs, AND ACTIONS
OF THE SAN DIEGO WATER BOARD**

June 12, 2024
Meeting Cancelled

July 2024
No Meeting Scheduled

August 14, 2024
San Diego Water Board

| Action Agenda Item | Action Type | Written Comments Due |
|---|--------------------|-------------------------------------|
| Tentative Resolution for FY 2024-2025 Operational Plan | Informational Item | NA |

Agenda Items Requested by Board Members**March 10, 2021**

| Requested Agenda Item | Board Member | Status |
|---|---------------------|---------------|
| Region-wide workshop regarding the water quality issues in the Tijuana River Valley, including a discussion of water quality objectives and steps needed to achieve them. | Abarbanel | 2024 |

May 11, 2022

| Requested Agenda Item | Board Member | Status |
|--------------------------------------|---------------------|---------------|
| Environmental Justice outreach event | Warren | 2024 |

March 8, 2023

| Requested Agenda Item | Board Member | Status |
|---|---------------------|---------------|
| Update regarding the Southern California ROMS-BEC coastal water-quality model | Abarbanel | June 2024 |

May 10, 2023

| Requested Agenda Item | Board Member | Status |
|--|---------------------|-------------------------------|
| Information regarding agricultural water quality best practices that are working in other regions and other topics raised during the agricultural workshop | Olson, Warren | Complete September 2023 |

June 14, 2023

| Future | Board Member | Status |
|--|---------------------|---------------|
| A tour of the Harbor Island Living Shoreline Project | Warren | June 2024 |

October 11, 2023

| Requested Agenda Item | Board Member | Status |
|--|---------------------|---------------|
| Look for duplicative monitoring in San Diego Bay and identify opportunities to reduce monitoring as a result of this assessment. | Warren | Ongoing |

December 13 and 18, 2023

| Requested Agenda Item | Board Member | Status |
|--|---------------------|----------------------|
| Information regarding the affordability and operational and capital costs of General Atomics' Industrial Supercritical Water Oxidation (iSCWO) technology system used to treat PFAS and the energy needs associated with the system. | Warren, Olson | May 2024 |
| Information regarding "Blue Baby Syndrome" and how it is related to nitrogen in drinking water and groundwater such as private wells. | Cantú | Complete May 2024 |
| Updates on the status of all upgrades at the South Bay International Wastewater Treatment Plant, especially when USIBWC will not meet estimated completion dates provided in previous Executive Officer Reports | Olson | Ongoing |

February 14, 2024

| Requested Agenda Item | Board Member | Status |
|---|---------------------|----------------------|
| Information on waste reduction methods that could be used to limit the amount of waste generated at the fireworks shows and how much of the waste is toxic. | Strawn | Complete May 2024 |
| Update regarding the annual homeless populations surveys that occur in many watersheds in our Region, including information regarding the water quality impacts in the areas of identified homeless populations | Strawn, Cantú | Summer 2024 |



San Diego Regional Water Quality Control Board

September 5, 2023

Dr. Maria-Elena Giner, P.E.
Commissioner
International Boundary and Water
Commission, United States Section
4191 N. Mesa
El Paso, Texas 79902
mariaelena.giner@ibwc.gov

Sent by Email Only

In reply refer to:
257821:VRodriguez

Subject: Notice of Violation No. R9-2023-0162 to the United States International Boundary and Water Commission for Violations of Order No. R9-2021-0001, NPDES No. CA0108928, *Waste Discharge Requirements for the United States Section of the International Boundary and Water Commission, South Bay International Wastewater Treatment Plant Discharge to the Pacific Ocean through the South Bay Ocean Outfall*

Dr. Maria-Elena Giner:

As detailed in the attached Notice of Violation (NOV) No. R9-2023-0162, the California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) alleges that the United States International Boundary and Water Commission (USIBWC or Discharger) has violated Order No. R9-2021-0001, NPDES No. CA0108928, *Waste Discharge Requirements for the United States Section of the International Boundary and Water Commission, South Bay International Wastewater Treatment Plant Discharge to the Pacific Ocean through the South Bay Ocean Outfall* (Order).

The San Diego Water Board appreciates USIBWC's transparency and open communication regarding the state of the South Bay International Wastewater Treatment Plant (SBIWTP). The San Diego Water Board acknowledges the operational challenges presented in treating wastewater from a collection system in Mexico outside the USIBWC's direct control or authority and appreciates the efforts to coordinate operations and improvements with agencies in Mexico through Minute 320 and Minute 328. During our meeting with USIBWC staff on August 16, 2023, the pathway to return to compliance with the Order and Cease and Desist Order R9-2021-0709 (CDO) was described in detail.

Tropical Cyclone Hilary (Hilary) brought significant inflow and infiltration with excessive sedimentation and debris into the SBIWTP. Throughout the storm itself and in the day following, USIBWC staff kept the San Diego Water Board informed regarding operations and impacts. The damage to the SBIWTP is extensive and serious throughout the

Dr. Maria-Elena Giner
USIBWC

-2-

September 5, 2023

treatment plant. The San Diego Water appreciates the detailed plans USIBWC shared on August 31, 2023, to make emergency repairs and restore operations.

Nonetheless, it is imperative that USIBWC take note of the secondary exceedances pre- and post-Hilary and overdue reports and continue to make every possible effort to restore the SBIWTP to operational status and compliance with the Order and CDO in the shortest possible time. It should be noted that at other, non-federal facilities, the 86 Chronic Violations and 125 Serious Violations reported would constitute 211 Minimum Mandatory Penalty Violations and would result in assessment of Administrative Civil Liabilities of \$633,000. Implementation of the plan shared on August 16, 2023, to restore compliance with the Order and CDO in the shortest possible time is a critical environmental responsibility.

Regarding the overdue submission of the Tijuana River Valley Monitoring Program Work Plan (Att. E, section 4.2.4 (pp.E-62,E-63), it has been indicated that this is planned as a binational project being developed as a Minute 320 project. In the interest of the most useful and informative monitoring and assessment of water quality in the Tijuana River watershed, please work with the Minute 320 Secretariats and Commissioner Resendez of the Comisión Internacional de Limites y Aguas (CILA, the Mexican Section of the IBWC) to expedite completion of the draft plan and a schedule for implementation to achieve compliance with the Order at the soonest date.

For questions or concerns regarding this NOV, please contact Vicente Rodriguez by phone at 619-521-3966 or by email at Vicente.Rodriguez@waterboards.ca.gov. In the subject line of any written response, please include the following: 257821:VRodriguez.

Respectfully,

David W. Gibson
Executive Officer

Attachment: Notice of Violation (NOV) No. R9-2023-0162

Copies to:

Laurie Walsh, San Diego Water Board, Laurie.Walsh@waterboards.ca.gov

Brandi Outwin-Beals, San Diego Water Board, Brandi.Outwin-Beals@waterboards.ca.gov

Morgan Rogers, Commissioner, International Boundary and Water Commission, U.S. Section, morgan.roger@ibwc.gov

Dr. Maria-Elena Giner
USIBWC

-3-

September 5, 2023

| Tech Staff Info & Use | |
|---|--------------|
| Technical Information | Number |
| Order No. | R9-2021-0001 |
| NPDES No. | CA0108928 |
| CW Place ID (South Bay International WTP) | CW-257821 |
| CW Party/Organization ID (IBWC-US & Mexico Section) | 21523 |
| CW Party/Person ID (Dr. Maria-Elena Giner) | 634777 |
| CW Regulatory Measure (Order No. R9-2021-0001) | 442331 |
| CW Regulatory Measure (NOV R9-2023-0162) | 453821 |
| WDID | 9 000000732 |

Dr. Maria-Elena Giner
USIBWC

-4-

September 5, 2023

| Tech Staff Info & Use (continued) | |
|-----------------------------------|--|
| Violation IDs | 1095194, 1095195, 1095939, 1095941, 1095942, 1095943, 1098935, 1098937, 1100628, 1103622, 1103623, 1103624, 1103625, 1103626, 1103628, 1103629, 1103630, 1103631, 1103632, 1103633, 1103634, 1103635, 1103636, 1103637, 1103638, 1103943, 1103944, 1103945, 1103947, 1103948, 1103949, 1103950, 1103951, 1103952, 1103953, 1103954, 1103955, 1103956, 1103957, 1103958, 1104355, 1104356, 1104357, 1104358, 1104359, 1104360, 1104361, 1104362, 1104363, 1104364, 1104365, 1104366, 1104368, 1104369, 1105851, 1105852, 1105853, 1105854, 1105855, 1105856, 1105857, 1105858, 1105860, 1105861, 1105862, 1105863, 1105864, 1105865, 1106693, 1108811, 1108812, 1108814, 1108815, 1108816, 1108817, 1108819, 1108820, 1108821, 1108822, 1109623, 1109624, 1109625, 1109626, 1109627, 1109628, 1109630, 1109631, 1109632, 1109633, 1110722, 1110723, 1110724, 1110725, 1110726, 1110727, 1110729, 1110731, 1110732, 1110733, 1110734, 1110735, 1110736, 1111588, 1111589, 1111590, 1111591, 1111592, 1111593, 1111595, 1111597, 1111598, 1111599, 1111600, 1111601, 1112867, 1112868, 1112869, 1112870, 1112871, 1112872, 1112873, 1112874, 1112875, 1112877, 1112878, 1112879, 1112881, 1112882, 1112883, 1113382, 1114378, 1114380, 1114381, 1114382, 1114383, 1114384, 1114385, 1114386, 1114387, 1114388, 1114390, 1114391, 1114392, 1114393, 1114394, 1114947, 1114948, 1114949, 1114950, 1114951, 1114953, 1114954, 1114955, 1114956, 1114957, 1114959, 1114960, 1114961, 1114962, 1114963, 1114964, 1115867, 1115868, 1115869, 1115870, 1115871, 1115872, 1115873, 1115874, 1115875, 1115876, 1115877, 1115879, 1115880, 1117391, 1117392, 1117393, 1117394, 1117395, 1117396, 1117397, 1117398, 1117399, 1117400, 1117401, 1117402, 1117403, 1118212, 1118213, 1118215, 1118216, 1118217, 1118218, 1118219, 1118220, 1118221, 1118222, 1118223, 1118224, 1118225, 1118890, 1118892, 1118893, 1118894, 1118895, 1118896, 1118897, 1118898, 1118899, 1118900, 1118901, 1118902, 1118903, 1118904 |

Notice of Violation No. R9-2023-0162**to the United States International Boundary and Water Commission for Violations of Order No. R9-2021-0001, NPDES No. CA0108928, *Waste Discharge Requirements for the United States Section of the International Boundary and Water Commission, South Bay International Wastewater Treatment Plant, Discharge to the Pacific Ocean through the South Bay Ocean Outfall***

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) hereby issues Notice of Violation (NOV) No. R9-2023-0162 to the United States International Boundary and Water Commission (USIBWC or Discharger) for violations of Order No. R9-2021-0001, NPDES No. CA0108928, *Waste Discharge Requirements for the United States Section of the International Boundary and Water Commission, South Bay International Wastewater Treatment Plant, Discharge to the Pacific Ocean through the South Bay Ocean Outfall* (Order). These violations are a result of the Discharger's failure to comply with the Order.

1. Background

The Discharger is required to maintain and operate the South Bay International Wastewater Treatment Plant (SBIWTP) in compliance with requirements contained in the Order. Consistent with the Order, the Discharger is required to submit self-monitoring reports and other technical reports. Between September 30, 2021, and June 30, 2023, the Discharger self-reported 208 violations, and the San Diego Water Board identified six missing or late reports. The Discharger reported that most of the violations were caused by the inflow of sewage from Tijuana, Mexico exceeding the design flow capacity of the SBIWTP.

2. Summary of Alleged Violations the Order

The Discharger is alleged to have violated the following sections of the Order:

- 2.1. Section 4 of the Order:** The Discharger is required to maintain compliance with effluent limitations in section 4.1.1.1.

Observation: The Discharger self-reported 208¹ exceedances of the effluent limitations in the California Integrated Water Quality System (CIWQS) database.

- 2.2. Section 6.3.2.1 of the Order:** The Discharger was required to submit an Updated Flow Prevention/Response Plan Section 6.3.2.1.2 by December 28, 2021.

Observation: This Discharger submitted the Updated Flow Prevention/Response Plan Section 6.3.2.1.2 on December 15, 2022.

- 2.3. Section 6.3.2.5.1 of the Order:** The Discharger was required to submit an Asset Management Plan by December 28, 2021.

Observation: This Discharger submitted the Asset Management Plan on December 5, 2022.

- 2.4. Section 6.3.3.2.5 of the Order:** The Discharger was required to submit a Pollutant Minimization Program Annual Status Report by February 1, 2022.

¹ Exhibit 1, List of Violations

Notice of Violation No. R9-2023-0162 -2-
USIBWC

September 5, 2023

Observation: This Discharger submitted the Pollutant Minimization Program Annual Status Report on December 15, 2022.

- 2.5. Section 6.3.3.2.5 of the Order:** The Discharger was required to submit a Pollutant Minimization Program Annual Status Report by February 1, 2023.

Observation: This Discharger submitted the Pollutant Minimization Program Annual Status Report on February 21, 2023.

- 2.6. Attachment D, Section 1.1 of the Order:** The Discharger is required to comply with all terms, requirements, and conditions of the Order. Any noncompliance constitutes a violation of the Clean Water Act (CWA) and the California Water Code (Water Code) and is grounds for enforcement action including permit termination, revocation and reissuance, or modification; denial of a permit renewal application; or a combination thereof.

Observation: The Discharger had 214 violations of the Order.

- 2.7. Attachment E, Section 4.2.4 of the Order:** The Discharger was required to submit a Tijuana River Valley Monitoring Plan (TRVMP) Work Plan by September 29, 2021.

Observation: This Discharger has not submitted the TRVMP Work Plan.

- 2.8. Attachment E, Section 3.3.6 of the Order:** The Discharger was required to submit an Initial Investigation TRE Work Plan by September 29, 2021.

Observation: This Discharger submitted the Initial Investigation TRE Work Plan on March 8, 2022.

3. Potential Enforcement Actions

The alleged violations may potentially subject the Discharger to additional enforcement by the San Diego Water Board or the State Water Resources Control Board (State Water Board). The San Diego Water Board intends and desires to continue to engage proactively and constructively with the Discharger through judicious and progressive enforcement efforts.

Notice of Violation R9-2023-0162**Exhibit 1, List of Violations**

| No. | Violation ID | Occurrence Date(s) | Violation Type | Violation Description |
|------------|---------------------|---------------------------|-----------------------|--|
| 1 | 1095939 | 09/05/21 through 09/11/21 | OEV | Settleable Solids concentration exceeded the weekly average effluent limitation of 1.5 milliliters per liter (ml/L) with a result of 1.8 ml/L. |
| 2 | 1095943 | 9/8/2021 | OEV | Settleable Solids concentration exceeded the instantaneous maximum effluent limitation of 3 ml/L with a result of 3.4 ml/L. |
| 3 | 1095941 | 9/9/2021 | OEV | Settleable Solids concentration exceeded the instantaneous maximum effluent limitation of 3 ml/L with a result of 4 ml/L. |
| 4 | 1095942 | 9/10/2021 | OEV | Settleable Solids concentration exceeded the instantaneous maximum effluent limitation of 3 ml/L with a result of 4 ml/L. |
| 5 | 1095194 | 09/30/21 through ongoing | Late Report | Tijuana River Valley Work Plan (Doc ID:2523482), due 09/29/2021, has not been submitted. |
| 6 | 1095195 | 09/30/21 through 03/08/22 | Late Report | Initial Investigation TRE Work Plan (Doc ID:2523481), due 09/29/2021, was submitted on 3/8/2022. |
| 7 | 1098935 | 12/29/21 through 12/15/22 | Late Report | Updated Flow Prevention/Response Plan Section 6.3.2.1.2 (Doc ID:2528203), due 12/28/2021, was submitted on 12/15/2022. |
| 8 | 1098937 | 12/29/21 through 12/05/22 | Late Report | Asset Management Plan (Doc ID:2528204), due 12/28/2021, was submitted on 12/5/2022. |
| 9 | 1103943 | 02/01/22 through 02/28/22 | CAT1 | Carbonaceous Biochemical Oxygen Demand 5-day @ 20°C (CBOD) concentration exceeded the monthly average effluent limitation of 25 milligram per liter (mg/L) with a result of 55 mg/L. |

Notice of Violation R9-2023-0162**Exhibit 1, List of Violations**

| No. | Violation ID | Occurrence Date(s) | Violation Type | Violation Description |
|-----|--------------|---------------------------|----------------|---|
| 10 | 1103945 | 02/01/22 through 02/28/22 | CAT1 | Total Suspended Solids (TSS) percent removal did not meet the monthly average minimum requirement of 85% with a result of 63.59%. |
| 11 | 1103951 | 02/01/22 through 02/28/22 | CAT1 | TSS concentration exceeded the monthly average effluent limitation of 30 mg/L with a result of 100 mg/L. |
| 12 | 1103952 | 02/01/22 through 02/28/22 | CAT1 | CBOD mass emission rate exceeded the monthly average effluent limitation of 5,213 pounds per day (lb/day) with a result of 14,151 lb/day. |
| 13 | 1103954 | 02/01/22 through 02/28/22 | CAT1 | TSS mass emission rate exceeded the monthly average effluent limitation of 6,255 lb/day with a result of 26,591 lb/day. |
| 14 | 1103955 | 02/01/22 through 02/28/22 | CAT1 | CBOD percent removal did not meet the monthly average minimum requirement of 85 % with a result of 76.21 % |
| 15 | 1103958 | 02/01/22 through 02/28/22 | OEV | Settleable Solids concentration exceeded the monthly average effluent limitation of 1 ml/L with a result of 2.68 ml/L. |
| 16 | 1100628 | 02/02/22 through 12/15/22 | Late Report | Pollutant Minimization Program Annual Status Report (Doc ID:2528201), due 02/01/2022, was submitted on 12/15/2022. |
| 17 | 1103948 | 02/13/22 through 02/19/22 | OEV | Settleable Solids concentration exceeded the weekly average effluent limitation of 1.5 ml/L with a result of 5.8 ml/L. |
| 18 | 1103956 | 2/16/2022 | OEV | Settleable Solids concentration exceeded the instantaneous maximum effluent limitation of 3 ml/L with a result of 40 ml/L. |
| 19 | 1103944 | 02/20/22 through 02/26/22 | CAT1 | CBOD concentration exceeded the weekly average effluent limitation of 40 mg/L with a result of 142.09 mg/L. |

Notice of Violation R9-2023-0162
Exhibit 1, List of Violations

| No. | Violation ID | Occurrence Date(s) | Violation Type | Violation Description |
|-----|--------------|---------------------------|----------------|--|
| 20 | 1103947 | 02/20/22 through 02/26/22 | CAT1 | TSS concentration exceeded the weekly average effluent limitation of 45 mg/L with a result of 264 mg/L. |
| 21 | 1103949 | 02/20/22 through 02/26/22 | OEV | Turbidity concentration exceeded the weekly average effluent limitation of 100 Nephelometric Turbidity Units (NTU) with a result of 169.6 NTU. |
| 22 | 1103950 | 02/20/22 through 02/26/22 | CAT1 | TSS mass emission rate exceeded the weekly average effluent limitation of 9,383 lb/day with a result of 79,454 lb/day. |
| 23 | 1103953 | 02/20/22 through 02/26/22 | CAT1 | CBOD mass emission rate exceeded the weekly average effluent limitation of 8,340 lb/day with a result of 41,591 lb/day. |
| 24 | 1103957 | 2/23/2022 | OEV | Turbidity cloudiness exceeded the instantaneous maximum effluent limitation of 225 NTU with a result of 800 NTU. |
| 25 | 1104360 | 02/27/22 through 03/05/22 | OEV | Turbidity cloudiness exceeded the weekly average effluent limitation of 100 NTU with a result of 146.33 NTU. |
| 26 | 1103622 | 03/01/22 through 03/31/22 | OEV | Settleable Solids concentration exceeded the monthly average effluent limitation of 1 ml/L with a result of 1.78 ml/L. |
| 27 | 1103624 | 03/01/22 through 03/31/22 | CAT1 | TSS percent removal did not meet the monthly average minimum requirement of 85% with a result of 57.1%. |
| 28 | 1103629 | 03/01/22 through 03/31/22 | CAT1 | TSS concentration exceeded the monthly average effluent limitation of 30 mg/L with a result of 143 mg/L. |
| 29 | 1103631 | 03/01/22 through 03/31/22 | CAT1 | TSS mass emission rate exceeded the monthly average effluent limitation of 6,255 lb/day with a result of 33,887 lb/day. |

Notice of Violation R9-2023-0162**Exhibit 1, List of Violations**

| No. | Violation ID | Occurrence Date(s) | Violation Type | Violation Description |
|------------|---------------------|---------------------------|-----------------------|--|
| 30 | 1103636 | 03/01/22 through 03/31/22 | CAT1 | CBOD concentration exceeded the monthly average effluent limitation of 25 mg/L with a result of 48 mg/L. |
| 31 | 1103637 | 03/01/22 through 03/31/22 | CAT1 | CBOD percent removal did not meet the monthly average minimum requirement of 85% with a result of 82.06%. |
| 32 | 1103638 | 03/01/22 through 03/31/22 | CAT1 | CBOD mass emission rate exceeded the monthly average effluent limitation of 5,213 lb/day with a result of 11,102 lb/day. |
| 33 | 1103625 | 03/06/22 through 03/12/22 | OEV | Settleable Solids concentration exceeded the weekly average effluent limitation of 1.5 ml/L with a result of 1.94 ml/L. |
| 34 | 1103630 | 03/13/22 through 03/19/22 | CAT1 | TSS mass emission rate exceeded the weekly average effluent limitation of 9,383 lb/day with a result of 40,701 lb/day. |
| 35 | 1103632 | 03/13/22 through 03/19/22 | CAT1 | TSS concentration exceeded the weekly average effluent limitation of 45 mg/L with a result of 194 mg/L. |
| 36 | 1103634 | 03/13/22 through 03/19/22 | OEV | Turbidity cloudiness exceeded the weekly average effluent limitation of 100 NTU with a result of 124.19 NTU. |
| 37 | 1103623 | 03/27/22 through 04/02/22 | CAT1 | CBOD mass emission rate exceeded the weekly average effluent limitation of 8,340 lb/day with a result of 13,722 lb/day. |
| 38 | 1103633 | 03/27/22 through 04/02/22 | OEV | Turbidity cloudiness exceeded the weekly average effluent limitation of 75 NTU with a result of 83.4 NTU. |
| 39 | 1103635 | 03/27/22 through 04/02/22 | CAT1 | CBOD concentration exceeded the weekly average effluent limitation of 40 mg/L with a result of 65.29 mg/L. |

Notice of Violation R9-2023-0162**Exhibit 1, List of Violations**

| No. | Violation ID | Occurrence Date(s) | Violation Type | Violation Description |
|------------|---------------------|---------------------------|-----------------------|--|
| 40 | 1104358 | 03/27/22 through 04/02/22 | OEV | Settleable Solids concentration exceeded the weekly average effluent limitation of 1.5 ml/L with a result of 5.51 ml/L. |
| 41 | 1103626 | 3/29/2022 | OEV | Settleable Solids concentration exceeded the instantaneous maximum effluent limitation of 3 ml/L with a result of 38 ml/L. |
| 42 | 1103628 | 3/29/2022 | OEV | Turbidity cloudiness exceeded the instantaneous maximum effluent limitation of 225 NTU with a result of 797 NTU. |
| 43 | 1104355 | 04/01/22 through 04/30/22 | CAT1 | TSS percent removal did not meet the monthly average minimum requirement of 85% with a result of 62.39%. |
| 44 | 1104356 | 04/01/22 through 04/30/22 | CAT1 | TSS concentration exceeded the monthly average effluent limitation of 30 mg/L with a result of 128 mg/L. |
| 45 | 1104357 | 04/01/22 through 04/30/22 | CAT1 | CBOD percent removal did not meet the monthly average minimum requirement of 85% with a result of 77.91%. |
| 46 | 1104359 | 04/01/22 through 04/30/22 | CAT1 | TSS mass emission rate exceeded the monthly average effluent limitation of 6,255 lb/day with a result of 25,897 lb/day. |
| 47 | 1104364 | 04/01/22 through 04/30/22 | CAT1 | CBOD concentration exceeded the monthly average effluent limitation of 25 mg/L with a result of 61 mg/L. |
| 48 | 1104366 | 04/01/22 through 04/30/22 | CAT1 | CBOD mass emission rate exceeded the monthly average effluent limitation of 5,213 lb/day with a result of 12,351 lb/day. |
| 49 | 1104363 | 4/16/2022 | OEV | Settleable Solids concentration exceeded the instantaneous maximum effluent limitation of 3 ml/L with a result of 5 ml/L. |

Notice of Violation R9-2023-0162**Exhibit 1, List of Violations**

| No. | Violation ID | Occurrence Date(s) | Violation Type | Violation Description |
|------------|---------------------|---------------------------|-----------------------|---|
| 50 | 1104361 | 04/24/22 through 04/30/22 | CAT1 | TSS concentration exceeded the weekly average effluent limitation of 45 mg/L with a result of 267 mg/L. |
| 51 | 1104362 | 04/24/22 through 04/30/22 | CAT1 | TSS mass emission rate exceeded the weekly average effluent limitation of 9,383 lb/day with a result of 65,429 lb/day. |
| 52 | 1104368 | 04/24/22 through 04/30/22 | CAT1 | CBOD concentration exceeded the weekly average effluent limitation of 40 mg/L with a result of 135.29 mg/L. |
| 53 | 1104369 | 04/24/22 through 04/30/22 | CAT1 | CBOD mass emission rate exceeded the weekly average effluent limitation of 8,340 lb/day with a result of 27,819 lb/day. |
| 54 | 1104365 | 4/26/2022 | OEV | Turbidity cloudiness exceeded the instantaneous maximum effluent limitation of 225 NTU with a result of 227 NTU. |
| 55 | 1105852 | 05/01/22 through 05/31/22 | CAT1 | TSS concentration exceeded the monthly average effluent limitation of 30 mg/L with a result of 77 mg/L. |
| 56 | 1105853 | 05/01/22 through 05/31/22 | CAT1 | CBOD concentration exceeded the monthly average effluent limitation of 25 mg/L with a result of 45 mg/L. |
| 57 | 1105854 | 05/01/22 through 05/31/22 | CAT1 | TSS mass emission rate exceeded the monthly average effluent limitation of 6,255 lb/day with a result of 14,442 lb/day. |
| 58 | 1105857 | 05/01/22 through 05/31/22 | CAT1 | CBOD percent removal did not meet the monthly average minimum requirement of 85% with a result of 82.3%. |
| 59 | 1105860 | 05/01/22 through 05/31/22 | CAT1 | CBOD mass emission rate exceeded the monthly average effluent limitation of 5,213 lb/day with a result of 8,325 lb/day. |

Notice of Violation R9-2023-0162
Exhibit 1, List of Violations

| No. | Violation ID | Occurrence Date(s) | Violation Type | Violation Description |
|-----|--------------|---------------------------|----------------|--|
| 60 | 1105862 | 05/01/22 through 05/31/22 | CAT1 | TSS percent removal did not meet the monthly average minimum requirement of 85% with a result of 76.87%. |
| 61 | 1105851 | 05/08/22 through 05/14/22 | OEV | Settleable Solids concentration exceeded the weekly average effluent limitation of 1.5 ml/L with a result of 1.67 ml/L. |
| 62 | 1105856 | 05/08/22 through 05/14/22 | CAT1 | TSS concentration exceeded the weekly average effluent limitation of 45 mg/L with a result of 173 mg/L. |
| 63 | 1105861 | 05/08/22 through 05/14/22 | CAT1 | CBOD mass emission rate exceeded the weekly average effluent limitation of 8,340 lb/day with a result of 18,794 lb/day. |
| 64 | 1105863 | 05/08/22 through 05/14/22 | CAT1 | TSS mass emission rate exceeded the weekly average effluent limitation of 9,383 lb/day with a result of 31,258 lb/day. |
| 65 | 1105864 | 05/08/22 through 05/14/22 | CAT1 | CBOD concentration exceeded the weekly average effluent limitation of 104 mg/L with a result of 40 mg/L. |
| 66 | 1105865 | 05/08/22 through 05/14/22 | OEV | Turbidity cloudiness exceeded the weekly average effluent limitation of 100 NTU with a result of 113.84 NTU. |
| 67 | 1105855 | 5/10/2022 | OEV | Turbidity cloudiness exceeded the instantaneous maximum effluent limitation of 225 NTU with a result of 286 NTU. |
| 68 | 1105858 | 5/10/2022 | OEV | Settleable Solids concentration exceeded the instantaneous maximum effluent limitation of 3 ml/L with a result of 11 ml/L. |
| 69 | 1106693 | 06/05/22 through 06/11/22 | CAT1 | TSS concentration exceeded the weekly average effluent limitation of 45 mg/L with a result of 45.57 mg/L. |

Notice of Violation R9-2023-0162**Exhibit 1, List of Violations**

| No. | Violation ID | Occurrence Date(s) | Violation Type | Violation Description |
|------------|---------------------|---------------------------|-----------------------|---|
| 70 | 1108811 | 08/01/22 through 08/31/22 | CAT1 | CBOD concentration exceeded the monthly average effluent limitation of 25 mg/L with a result of 32 mg/L. |
| 71 | 1108814 | 08/01/22 through 08/31/22 | OEV | Flow volume rate exceeded the monthly average effluent limitation of 25 MGD with a result of 31.31 MGD. |
| 72 | 1108815 | 08/01/22 through 08/31/22 | CAT1 | TSS mass emission rate exceeded the monthly average effluent limitation of 6,255 lb/day with a result of 15,890 lb/day. |
| 73 | 1108820 | 08/01/22 through 08/31/22 | CAT1 | CBOD mass emission rate exceeded the monthly average effluent limitation of 5,213 lb/day with a result of 8,327 lb/day. |
| 74 | 1108821 | 08/01/22 through 08/31/22 | CAT1 | TSS percent removal did not meet the monthly average minimum requirement of 85% with a result of 78.78%. |
| 75 | 1108822 | 08/01/22 through 08/31/22 | CAT1 | TSS concentration exceeded the monthly average effluent limitation of 30 mg/L with a result of 62 mg/L. |
| 76 | 1108812 | 08/21/22 through 08/27/22 | CAT1 | CBOD concentration exceeded the weekly average effluent limitation of 40 mg/L with a result of 49.4 mg/L. |
| 77 | 1108819 | 08/21/22 through 08/27/22 | CAT1 | CBOD mass emission rate exceeded the weekly average effluent limitation of 8,340 lb/day with a result of 12,175 lb/day. |
| 78 | 1108816 | 08/28/22 through 09/03/22 | CAT1 | TSS concentration exceeded the monthly average effluent limitation of 45 mg/L with a result of 82 mg/L. |
| 79 | 1108817 | 08/28/22 through 09/03/22 | CAT1 | TSS mass emission rate exceeded the monthly average effluent limitation of 9,383 lb/day with a result of 20,267 lb/day. |
| 80 | 1109623 | 09/01/22 through 09/30/22 | CAT1 | CBOD percent removal did not meet the monthly average minimum requirement of 85% with a result of 84.37%. |

Notice of Violation R9-2023-0162**Exhibit 1, List of Violations**

| No. | Violation ID | Occurrence Date(s) | Violation Type | Violation Description |
|------------|---------------------|---------------------------|-----------------------|--|
| 81 | 1109624 | 09/01/22 through 09/30/22 | CAT1 | CBOD concentration exceeded the monthly average effluent limitation of 25 mg/L with a result of 39 mg/L. |
| 82 | 1109627 | 09/01/22 through 09/30/22 | CAT1 | TSS concentration exceeded the monthly average effluent limitation of 30 mg/L with a result of 72 mg/L. |
| 83 | 1109628 | 09/01/22 through 09/30/22 | CAT1 | TSS mass emission rate exceeded the monthly average effluent limitation of 6,255 lb/day with a result of 19,365 lb/day. |
| 84 | 1109631 | 09/01/22 through 09/30/22 | CAT1 | TSS percent removal did not meet the monthly average minimum requirement of 85% with a result of 76.7%. |
| 85 | 1109633 | 09/01/22 through 09/30/22 | CAT1 | CBOD mass emission rate exceeded the monthly average effluent limitation of 5,213 lb/day with a result of 10,372 lb/day. |
| 86 | 1109625 | 09/25/22 through 10/01/22 | CAT1 | CBOD concentration exceeded the weekly average effluent limitation of 40 mg/L with a result of 54.46 mg/L. |
| 87 | 1109626 | 09/25/22 through 10/01/22 | CAT1 | CBOD mass emission rate exceeded the weekly average effluent limitation of 8,340 lb/day with a result of 15,122 lb/day. |
| 88 | 1109630 | 09/25/22 through 10/01/22 | CAT1 | TSS mass emission rate exceeded the weekly average effluent limitation of 9,383 lb/day with a result of 27,487 lb/day. |
| 89 | 1109632 | 09/25/22 through 10/01/22 | CAT1 | TSS concentration exceeded the weekly average effluent limitation of 45 mg/L with a result of 99 mg/L. |
| 90 | 1110722 | 10/01/22 through 10/31/22 | CAT1 | CBOD concentration exceeded the monthly average effluent limitation of 25 mg/L with a result of 46 mg/L. |
| 91 | 1110724 | 10/01/22 through 10/31/22 | CAT1 | CBOD mass emission rate exceeded the monthly average effluent limitation of 5,213 lb/day with a result of 12,355 lb/day. |

Notice of Violation R9-2023-0162**Exhibit 1, List of Violations**

| No. | Violation ID | Occurrence Date(s) | Violation Type | Violation Description |
|------------|---------------------|---------------------------|-----------------------|---|
| 92 | 1110725 | 10/01/22 through 10/31/22 | CAT1 | TSS percent removal did not meet the monthly average minimum requirement of 85% with a result of 70.5%. |
| 93 | 1110727 | 10/01/22 through 10/31/22 | OEV | Flow volume rate exceeded the monthly average effluent limitation of 25 MGD with a result of 32.17 MGD. |
| 94 | 1110731 | 10/01/22 through 10/31/22 | CAT1 | TSS concentration exceeded the monthly average effluent limitation of 30 mg/L with a result of 88 mg/L. |
| 95 | 1110735 | 10/01/22 through 10/31/22 | CAT1 | TSS mass emission rate exceeded the monthly average effluent limitation of 6,255 lb/day with a result of 23,519 lb/day. |
| 96 | 1110736 | 10/01/22 through 10/31/22 | CAT1 | CBOD percent removal did not meet the monthly average minimum requirement of 85% with a result of 80.46%. |
| 97 | 1110723 | 10/30/22 through 11/05/22 | CAT1 | CBOD concentration exceeded the weekly average effluent limitation of 40 mg/L with a result of 81.81 mg/L. |
| 98 | 1110729 | 10/30/22 through 11/05/22 | CAT1 | TSS concentration exceeded the weekly average effluent limitation of 45 mg/L with a result of 151 mg/L. |
| 99 | 1110732 | 10/30/22 through 11/05/22 | CAT1 | CBOD mass emission rate exceeded the weekly average effluent limitation of 8,340 lb/day with a result of 21,821 lb/day. |
| 100 | 1110733 | 10/30/22 through 11/05/22 | CAT1 | TSS mass emission rate exceeded the weekly average effluent limitation of 9,383 lb/day with a result of 40,368 lb/day. |
| 101 | 1110734 | 10/30/22 through 11/05/22 | OEV | Turbidity cloudiness exceeded the weekly average effluent limitation of 100 NTU with a result of 104.51 NTU. |
| 102 | 1111591 | 10/30/22 through 11/05/22 | CAT1 | TSS concentration exceeded the weekly average effluent limitation of 45 mg/L with a result of 159 mg/L. |

Notice of Violation R9-2023-0162**Exhibit 1, List of Violations**

| No. | Violation ID | Occurrence Date(s) | Violation Type | Violation Description |
|------------|---------------------|---------------------------|-----------------------|--|
| 103 | 1111593 | 10/30/22 through 11/05/22 | CAT1 | TSS mass emission rate exceeded the weekly average effluent limitation of 9,383 lb/day with a result of 41,982 lb/day. |
| 104 | 1111595 | 10/30/22 through 11/05/22 | CAT1 | CBOD concentration exceeded the weekly average effluent limitation of 40 mg/L with a result of 88.43 mg/L. |
| 105 | 1110726 | 10/31/2022 | OEV | Turbidity cloudiness exceeded the instantaneous maximum effluent limitation of 225 NTU with a result of 389 NTU. |
| 106 | 1111588 | 11/01/22 through 11/30/22 | CAT1 | TSS concentration exceeded the monthly average effluent limitation of 30 mg/L with a result of 130 mg/L. |
| 107 | 1111589 | 11/01/22 through 11/30/22 | CAT1 | TSS mass emission rate exceeded the monthly average effluent limitation of 6,255 lb/day with a result of 36,536 lb/day. |
| 108 | 1111590 | 11/01/22 through 11/30/22 | CAT1 | CBOD mass emission rate exceeded the monthly average effluent limitation of 5,213 lb/day with a result of 19,647 lb/day. |
| 109 | 1111592 | 11/01/22 through 11/30/22 | CAT1 | CBOD concentration exceeded the monthly average effluent limitation of 25 mg/L with a result of 70 mg/L. |
| 110 | 1111597 | 11/01/22 through 11/30/22 | CAT1 | CBOD percent removal did not meet the monthly average minimum requirement of 85% with a result of 72.08%. |
| 111 | 1111598 | 11/01/22 through 11/30/22 | CAT1 | TSS percent removal did not meet the monthly average minimum requirement of 85% with a result of 61.1%. |
| 112 | 1111600 | 11/06/22 through 11/12/22 | OEV | Settleable Solids concentration exceeded the weekly average effluent limitation of 1.5 ml/L with a result of 2.51 ml/L. |
| 113 | 1111601 | 11/06/22 through 11/12/22 | CAT1 | CBOD mass emission rate exceeded the weekly average effluent limitation of 8,340 lb/day with a result of 23,468 lb/day. |

Notice of Violation R9-2023-0162**Exhibit 1, List of Violations**

| No. | Violation ID | Occurrence Date(s) | Violation Type | Violation Description |
|-----|--------------|---------------------------|----------------|--|
| 114 | 1111599 | 11/9/2022 | OEV | Settleable Solids concentration exceeded the instantaneous maximum effluent limitation of 3 mg/L with a result of 17 mg/L. |
| 115 | 1112868 | 12/01/22 through 12/31/22 | CAT1 | CBOD concentration exceeded the monthly average effluent limitation of 25 mg/L with a result of 67 mg/L. |
| 116 | 1112869 | 12/01/22 through 12/31/22 | CAT1 | CBOD mass emission rate exceeded the monthly average effluent limitation of 5,213 lb/day with a result of 17,511 lb/day. |
| 117 | 1112871 | 12/01/22 through 12/31/22 | OEV | Flow volume rate exceeded the monthly average effluent limitation of 25 MGD with a result of 28.64 MGD. |
| 118 | 1112877 | 12/01/22 through 12/31/22 | CAT1 | CBOD percent removal did not meet the monthly average minimum requirement of 85% with a result of 77.07%. |
| 119 | 1112878 | 12/01/22 through 12/31/22 | CAT1 | TSS percent removal did not meet the monthly average minimum requirement of 85% with a result of 68.06%. |
| 120 | 1112879 | 12/01/22 through 12/31/22 | OEV | Settleable Solids concentration exceeded the monthly average effluent limitation of 1 ml/L with a result of 1.39 ml/L. |
| 121 | 1112882 | 12/01/22 through 12/31/22 | CAT1 | TSS concentration exceeded the monthly average effluent limitation of 30 mg/L with a result of 117 mg/L. |
| 122 | 1112883 | 12/01/22 through 12/31/22 | CAT1 | TSS mass emission rate exceeded the monthly average effluent limitation of 6,255 lb/day with a result of 31,147 lb/day. |
| 123 | 1112867 | 12/25/22 through 12/31/22 | CAT1 | CBOD mass emission rate exceeded the weekly average effluent limitation of 8,340 lb/day with a result of 31,849 lb/day. |
| 124 | 1112870 | 12/25/22 through 12/31/22 | CAT1 | CBOD concentration exceeded the weekly average effluent limitation of 40 mg/L with a result of 121.91 mg/L. |

Notice of Violation R9-2023-0162**Exhibit 1, List of Violations**

| No. | Violation ID | Occurrence Date(s) | Violation Type | Violation Description |
|------------|---------------------|---------------------------|-----------------------|--|
| 125 | 1112872 | 12/25/22 through 12/31/22 | CAT1 | TSS concentration exceeded the weekly average effluent limitation of 45 mg/L with a result of 184 mg/L. |
| 126 | 1112873 | 12/25/22 through 12/31/22 | CAT1 | TSS mass emission rate exceeded the weekly average effluent limitation of 9,383 lb/day with a result of 49,021 lb/day. |
| 127 | 1112875 | 12/25/22 through 12/31/22 | OEV | Settleable Solids concentration exceeded the weekly average effluent limitation of 1.5 ml/L with a result of 5.8 ml/L. |
| 128 | 1112874 | 12/28/2022 | OEV | Turbidity cloudiness exceeded the instantaneous maximum effluent limitation of 225 NTU with a result of 283 NTU. |
| 129 | 1112881 | 12/28/2022 | OEV | Settleable Solids concentration exceeded the instantaneous maximum effluent limitation of 3 ml/L with a result of 40 ml/L. |
| 130 | 1114378 | 01/01/23 through 01/31/23 | CAT1 | CBOD concentration exceeded the monthly average effluent limitation of 25 mg/L with a result of 37 mg/L. |
| 131 | 1114380 | 01/01/23 through 01/31/23 | OEV | Flow volume rate exceeded the monthly average effluent limitation of 25 MGD with a result of 27.46 MGD. |
| 132 | 1114381 | 01/01/23 through 01/31/23 | CAT1 | TSS concentration exceeded the monthly average effluent limitation of 30 mg/L with a result of 75 mg/L. |
| 133 | 1114382 | 01/01/23 through 01/31/23 | CAT1 | CBOD percent removal did not meet the monthly average minimum requirement of 85% with a result of 86.86%. |
| 134 | 1114386 | 01/01/23 through 01/31/23 | CAT1 | TSS percent removal did not meet the monthly average minimum requirement of 85% with a result of 78.31%. |
| 135 | 1114387 | 01/01/23 through 01/31/23 | CAT1 | TSS mass emission rate exceeded the monthly average effluent limitation of 6,255 lb/day with a result of 21,856 lb/day. |

Notice of Violation R9-2023-0162**Exhibit 1, List of Violations**

| No. | Violation ID | Occurrence Date(s) | Violation Type | Violation Description |
|------------|---------------------|---------------------------|-----------------------|--|
| 136 | 1114388 | 01/01/23 through 01/31/23 | OEV | Settleable Solids concentration exceeded the monthly average effluent limitation of 1 ml/L with a result of 1.6 ml/L. |
| 137 | 1114392 | 01/01/23 through 01/31/23 | CAT1 | CBOD mass emission rate exceeded the monthly average effluent limitation of 5,213 lb/day with a result of 10,748 lb/day. |
| 138 | 1114383 | 01/15/23 through 01/21/23 | CAT1 | TSS concentration exceeded the weekly average effluent limitation of 9,383 mg/L with a result of 39,877 mg/L. |
| 139 | 1114384 | 01/15/23 through 01/21/23 | OEV | Settleable Solids concentration exceeded the weekly average effluent limitation of 1.5 ml/L with a result of 1.51 ml/L. |
| 140 | 1114391 | 01/15/23 through 01/21/23 | CAT1 | CBOD concentration exceeded the weekly average effluent limitation of 40 mg/L with a result of 54.61 mg/L. |
| 141 | 1114385 | 01/29/23 through 02/04/23 | CAT1 | CBOD mass emission rate exceeded the weekly average effluent limitation of 8,340 lb/day with a result of 19,840 lb/day. |
| 142 | 1114393 | 01/29/23 through 02/04/23 | CAT1 | TSS concentration exceeded the weekly average effluent limitation of 45 mg/L with a result of 112 mg/L. |
| 143 | 1114951 | 01/29/23 through 02/04/23 | OEV | Settleable Solids concentration exceeded the weekly average effluent limitation of 1.5 ml/L with a result of 3.74 ml/L. |
| 144 | 1114390 | 1/31/2023 | OEV | Turbidity cloudiness exceeded the instantaneous maximum effluent limitation of 225 NTU with a result of 314 NTU. |
| 145 | 1114394 | 1/31/2023 | OEV | Settleable Solids concentration exceeded the instantaneous maximum effluent limitation of 3 ml/L with a result of 25 ml/L. |
| 146 | 1114948 | 02/01/23 through 02/28/23 | CAT1 | TSS percent removal did not meet the monthly average minimum requirement of 85% with a result of 47.94%. |

Notice of Violation R9-2023-0162**Exhibit 1, List of Violations**

| No. | Violation ID | Occurrence Date(s) | Violation Type | Violation Description |
|------------|---------------------|---------------------------|-----------------------|--|
| 147 | 1114949 | 02/01/23 through 02/28/23 | CAT1 | TSS mass emission rate exceeded the monthly average effluent limitation of 6,255 lb/day with a result of 39,243 lb/day. |
| 148 | 1114954 | 02/01/23 through 02/28/23 | CAT1 | TSS concentration exceeded the monthly average effluent limitation of 30 mg/L with a result of 146 mg/L. |
| 149 | 1114959 | 02/01/23 through 02/28/23 | OEV | Flow volume rate exceeded the monthly average effluent limitation of 25 MGD with a result of 28.83 MGD. |
| 150 | 1114960 | 02/01/23 through 02/28/23 | CAT1 | CBOD concentration exceeded the monthly average effluent limitation of 25 mg/L with a result of 84 mg/L. |
| 151 | 1114961 | 02/01/23 through 02/28/23 | CAT1 | CBOD mass emission rate exceeded the monthly average effluent limitation of 5,213 lb/day with a result of 22,471 lb/day. |
| 152 | 1114963 | 02/01/23 through 02/28/23 | OEV | Turbidity cloudiness exceeded the monthly average effluent limitation of 75 NTU with a result of 87.99 NTU. |
| 153 | 1114964 | 02/01/23 through 02/28/23 | CAT1 | CBOD percent removal did not meet the monthly average minimum requirement of 85% with a result of 63.25%. |
| 154 | 1113382 | 02/02/23 through 02/21/23 | Late Report | Pollutant Minimization Program Annual Status Report (Doc ID:2528232), due 02/01/2023, was submitted on 2/21/23. |
| 155 | 1114947 | 02/12/23 through 02/18/23 | OEV | Turbidity cloudiness exceeded the weekly average effluent limitation of 100 NTU with a result of 167.09 NTU. |
| 156 | 1114950 | 02/12/23 through 02/18/23 | CAT1 | TSS concentration exceeded the weekly average effluent limitation of 45 mg/L with a result of 242 mg/L. |
| 157 | 1114953 | 02/12/23 through 02/18/23 | CAT1 | CBOD concentration exceeded the weekly average effluent limitation of 40 mg/L with a result of 123 mg/L. |

Notice of Violation R9-2023-0162**Exhibit 1, List of Violations**

| No. | Violation ID | Occurrence Date(s) | Violation Type | Violation Description |
|------------|---------------------|---------------------------|-----------------------|--|
| 158 | 1114955 | 02/12/23 through 02/18/23 | CAT1 | CBOD mass emission rate exceeded the weekly average effluent limitation of 8,340 lb/day with a result of 35,298 lb/day. |
| 159 | 1114962 | 02/12/23 through 02/18/23 | CAT1 | TSS mass emission rate exceeded the weekly average effluent limitation of 9,383 lb/day with a result of 70,259 lb/day. |
| 160 | 1114957 | 2/13/2023 | OEV | Turbidity cloudiness exceeded the instantaneous maximum effluent limitation of 225 NTU with a result of 620 NTU. |
| 161 | 1114956 | 2/23/2023 | OEV | Settleable Solids concentration exceeded the instantaneous maximum 3 ml/L with a result of 5 ml/L. |
| 162 | 1115870 | 02/26/23 through 03/04/23 | CAT1 | CBOD mass emission rate exceeded the weekly average effluent limitation of 8,340 lb/day with a result of 20,801 lb/day. |
| 163 | 1115871 | 02/26/23 through 03/04/23 | CAT1 | CBOD concentration exceeded the weekly average effluent limitation of 40 mg/L with a result of 84.54 mg/L. |
| 164 | 1115867 | 03/01/23 through 03/31/23 | CAT1 | CBOD concentration exceeded the monthly average effluent limitation of 25 mg/L with a result of 63 mg/L. |
| 165 | 1115868 | 03/01/23 through 03/31/23 | CAT1 | CBOD mass emission rate exceeded the monthly average effluent limitation of 5,213 lb/day with a result of 14,957 lb/day. |
| 166 | 1115872 | 03/01/23 through 03/31/23 | CAT1 | TSS concentration exceeded the monthly average effluent limitation of 30 mg/L with a result of 145 mg/L. |
| 167 | 1115873 | 03/01/23 through 03/31/23 | CAT1 | TSS mass emission rate exceeded the monthly average effluent limitation of 6,255 lb/day with a result of 34,885 lb/day. |
| 168 | 1115877 | 03/01/23 through 03/31/23 | OEV | Settleable Solids concentration exceeded the monthly average effluent limitation of 1 ml/L with a result of 1.82 ml/L. |

Notice of Violation R9-2023-0162**Exhibit 1, List of Violations**

| No. | Violation ID | Occurrence Date(s) | Violation Type | Violation Description |
|------------|---------------------|---------------------------|-----------------------|--|
| 169 | 1115879 | 03/01/23 through 03/31/23 | CAT1 | TSS percent removal did not meet the monthly average minimum requirement of 85% with a result of 44.17%. |
| 170 | 1115869 | 03/05/23 through 03/11/23 | CAT1 | TSS concentration exceeded the weekly average effluent limitation of 45 mg/L with a result of 174 mg/L. |
| 171 | 1115876 | 03/05/23 through 03/11/23 | CAT1 | TSS mass emission rate exceeded the weekly average effluent limitation of 9,383 lb/day with a result of 47,873 lb/day. |
| 172 | 1115880 | 3/11/2023 | OEV | Turbidity cloudiness exceeded the instantaneous maximum effluent limitation of 225 NTU with a result of 279 NTU. |
| 173 | 1115874 | 03/12/23 through 03/18/23 | OEV | Settleable Solids concentration exceeded the weekly average effluent limitation of 1.5 ml/L with a result of 5.8 ml/L. |
| 174 | 1115875 | 3/15/2023 | OEV | Settleable Solids concentration exceeded the instantaneous maximum effluent limitation of 3 ml/L with a result of 40 ml/L. |
| 175 | 1117403 | 04/01/23 through 04/30/23 | OEV | Turbidity cloudiness exceeded the monthly average effluent limitation of 75 NTU with a result of 93.35 NTU. |
| 176 | 1117393 | 04/01/23 through 04/30/23 | CAT1 | TSS concentration exceeded the monthly average effluent limitation of 30 mg/L with a result of 198 mg/L. |
| 177 | 1117395 | 04/01/23 through 04/30/23 | CAT1 | CBOD concentration exceeded the monthly average effluent limitation of 25 mg/L with a result of 116 mg/L. |
| 178 | 1117398 | 04/01/23 through 04/30/23 | CAT1 | CBOD percent removal did not meet the monthly average minimum requirement of 85% with a result of 34.41%. |
| 179 | 1117399 | 04/01/23 through 04/30/23 | CAT1 | TSS percent removal did not meet the monthly average minimum requirement of 85% with a result of 19.81%. |

Notice of Violation R9-2023-0162**Exhibit 1, List of Violations**

| No. | Violation ID | Occurrence Date(s) | Violation Type | Violation Description |
|------------|---------------------|---------------------------|-----------------------|--|
| 180 | 1117400 | 04/01/23 through 04/30/23 | CAT1 | CBOD mass emission rate exceeded the monthly average effluent limitation of 5,213 lb/day with a result of 20,602 lb/day. |
| 181 | 1117401 | 04/01/23 through 04/30/23 | CAT1 | TSS mass emission rate exceeded the monthly average effluent limitation of 6,255 lb/day with a result of 35,389 lb/day. |
| 182 | 1117396 | 04/09/23 through 04/15/23 | OEV | Turbidity cloudiness exceeded the weekly average effluent limitation of 100 NTU with a result of 115.43 NTU. |
| 183 | 1117397 | 4/21/2023 | OEV | Turbidity cloudiness exceeded the instantaneous maximum effluent limitation of 225 NTU with a result of 236 NTU. |
| 184 | 1117391 | 04/23/23 through 04/29/23 | CAT1 | CBOD concentration exceeded the weekly average effluent limitation of 40 mg/L with a result of 142.29 mg/L. |
| 185 | 1117392 | 04/23/23 through 04/29/23 | CAT1 | CBOD mass emission rate exceeded the weekly average effluent limitation of 8,340 lb/day with a result of 25,628 lb/day. |
| 186 | 1117394 | 04/23/23 through 04/29/23 | CAT1 | TSS mass emission rate exceeded the weekly average effluent limitation of 9,383 lb/day with a result of 41,825 lb/day. |
| 187 | 1117402 | 04/23/23 through 04/29/23 | CAT1 | TSS concentration exceeded the weekly average effluent limitation of 45 mg/L with a result of 232 mg/L. |
| 188 | 1118212 | 04/30/23 through 05/06/23 | OEV | Turbidity cloudiness exceeded the weekly average effluent limitation of 100 NTU with a result of 125.86 NTU. |
| 189 | 1118220 | 04/30/23 through 05/06/23 | CAT1 | TSS concentration exceeded the weekly average effluent limitation of 45 mg/L with a result of 188 mg/L. |
| 190 | 1118221 | 04/30/23 through 05/06/23 | CAT1 | CBOD mass emission rate exceeded the weekly average effluent limitation of 8,340 lb/day with a result of 26,431 lb/day. |

Notice of Violation R9-2023-0162**Exhibit 1, List of Violations**

| No. | Violation ID | Occurrence Date(s) | Violation Type | Violation Description |
|------------|---------------------|---------------------------------|-----------------------|--|
| 191 | 1118222 | 04/30/23 through 05/06/23 | CAT1 | CBOD concentration exceeded the weekly average effluent limitation of 40 mg/L with a result of 108.86 mg/L. |
| 192 | 1118225 | 04/30/23 through 05/06/23 | CAT1 | TSS mass emission rate exceeded the weekly average effluent limitation of 9,383 lb/day with a result of 42,864 lb/day. |
| 193 | 1118215 | 05/01/23 through 05/31/23 | CAT1 | TSS concentration exceeded the monthly average effluent limitation of 30 mg/L with a result of 130 mg/L. |
| 194 | 1118216 | 05/01/23 through 05/31/23 | CAT1 | TSS mass emission rate exceeded the monthly average effluent limitation of 6,255 lb/day with a result of 29,778 lb/day. |
| 195 | 1118217 | 05/01/23 through 05/31/23 | CAT1 | TSS percent removal did not meet the monthly average minimum requirement of 85% with a result of 53.36%. |
| 196 | 1118218 | 05/01/23 through 05/31/23 | CAT1 | CBOD mass emission rate exceeded the monthly average effluent limitation of 5,213 lb/day with a result of 17,513 lb/day. |
| 197 | 1118219 | 05/01/23 through 05/31/23 | CAT1 | CBOD concentration exceeded the monthly average effluent limitation of 25 mg/L with a result of 76 mg/L. |
| 198 | 1118223 | 05/01/23 through 05/31/23 | OEV | Flow volume rate exceeded the monthly average effluent limitation of 25 MGD with a result of 26.89 MGD. |
| 199 | 1118224 | 05/01/23 through 05/31/23 | CAT1 | CBOD percent removal did not meet the monthly average minimum requirement of 85% with a result of 63.17%. |
| 200 | 1118213 | 5/1/2023 | OEV | Turbidity cloudiness exceeded the instantaneous maximum effluent limitation of 225 NTU with a result of 409 NTU. |
| 201 | 1118892 | 06/01/23 through 06/30/23 | OEV | Flow volume rate exceeded the monthly average effluent limitation of 25 MGD with a result of 29.43 MGD. |

Notice of Violation R9-2023-0162**Exhibit 1, List of Violations**

| No. | Violation ID | Occurrence Date(s) | Violation Type | Violation Description |
|------------|---------------------|---------------------------|-----------------------|--|
| 202 | 1118894 | 06/01/23 through 06/30/23 | CAT1 | TSS concentration exceeded the monthly average effluent limitation of 30 mg/L with a result of 161 mg/L. |
| 203 | 1118895 | 06/01/23 through 06/30/23 | CAT1 | CBOD mass emission rate exceeded the monthly average effluent limitation of 5,213 lb/day with a result of 20,850 lb/day. |
| 204 | 1118896 | 06/01/23 through 06/30/23 | CAT1 | TSS mass emission rate exceeded the monthly average effluent limitation of 6,255 lb/day with a result of 40,187 lb/day. |
| 205 | 1118898 | 06/01/23 through 06/30/23 | CAT1 | CBOD percent removal did not meet the monthly average minimum requirement of 85% with a result of 65.07%. |
| 206 | 1118901 | 06/01/23 through 06/30/23 | CAT1 | CBOD concentration exceeded the monthly average effluent limitation of 25 mg/L with a result of 83 mg/L. |
| 207 | 1118903 | 06/01/23 through 06/30/23 | CAT1 | TSS percent removal did not meet the monthly average minimum requirement of 85% with a result of 44.71%. |
| 208 | 1118904 | 06/01/23 through 06/30/23 | OEV | Turbidity cloudiness exceeded the monthly average effluent limitation of 75 NTU with a result of 80.94 NTU. |
| 209 | 1118893 | 06/11/23 through 06/17/23 | CAT1 | CBOD mass emission rate exceeded the weekly average effluent limitation of 8,340 lb/day with a result of 25,202 lb/day. |
| 210 | 1118897 | 06/11/23 through 06/17/23 | CAT1 | TSS concentration exceeded the weekly average effluent limitation of 45 mg/L with a result of 199 mg/L. |
| 211 | 1118899 | 06/11/23 through 06/17/23 | CAT1 | TSS mass emission rate exceeded the weekly average effluent limitation of 9,383 lb/day with a result of 49,968 lb/day. |
| 212 | 1118900 | 06/11/23 through 06/17/23 | OEV | Turbidity cloudiness exceeded the weekly average effluent limitation of 100 NTU with a result of 107.78 NTU. |

Notice of Violation R9-2023-0162**Exhibit 1, List of Violations**

| No. | Violation ID | Occurrence Date(s) | Violation Type | Violation Description |
|------------|---------------------|---------------------------------|-----------------------|--|
| 213 | 1118902 | 06/11/23 through 06/17/23 | CAT1 | CBOD concentration exceeded the weekly average effluent limitation of 40 mg/L with a result of 101.29 mg/L. |
| 214 | 1118890 | 6/13/2023 | OEV | Turbidity cloudiness exceeded the instantaneous maximum effluent limitation of 225 NTU with a result of 278 NTU. |

Notice of Violation R9-2023-0162
Exhibit 1, List of Violations

| TERM | DEFINITION |
|-----------------------|--|
| CAT1 | Category 1 violation type. This violation type is identified when the water quality effluent parameter is part of the Group I pollutant. |
| CAT2 | Category 2 violation type. This violation type is identified when the water quality effluent parameter is part of the Group II pollutant. |
| CIWQS | California Integrated Water Quality System database. |
| GROUP | The list of pollutants is based on Appendix A to section 123.45 of title 40 of the Code of Federal Regulations. |
| Occurrence Date(s) | Date that a violation occurred. For continuing violations, such as a monthly average, the days of the reporting period are used. If the occurrence date is unknown, the date is entered as the day it was first discovered by staff, the discharger, or a third party. For deficient or late reports, the occurrence date is the day after the report was due. |
| OEV | Violation of any constituent-specific effluent limitation not included in Group I or Group II. |
| Violation Description | Narrative description of the violation. |
| Violation ID | Identification number assigned to a violation in CIWQS. |



San Diego Regional Water Quality Control Board

October 27, 2023

Dr. Maria-Elena Giner, P.E.
Commissioner
International Boundary and Water
Commission, United States Section
4191 N. Mesa
El Paso, Texas 79902
mariaelena.giner@ibwc.gov

Sent by Email Only
In reply refer to:
257821:VRodriguez

**Subject: Notice of Violation No. R9-2023-0205 to the United States
International Boundary and Water Commission for Violations of
Order No. R9-2021-0001**

Dr. Maria-Elena Giner:

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) hereby issues Notice of Violation (NOV) No. R9-2023-0205 to the United States International Boundary and Water Commission (USIBWC or Discharger) for alleged violations of Order No. R9-2021-0001, NPDES No. CA0108928, *Waste Discharge Requirements for the United States Section of the International Boundary and Water Commission, South Bay International Wastewater Treatment Plant, Discharge to the Pacific Ocean through the South Bay Ocean Outfall* (Order). These alleged violations are a result of the Discharger's failure to comply with the Order.

1. Background

The Discharger is required to operate and maintain the South Bay International Wastewater Treatment Plant (SBIWTP) in compliance with requirements contained in the Order. Consistent with the Order, the Discharger is required to submit self-monitoring reports and other technical reports. Between July 1, 2023, and August 30, 2023, the Discharger self-reported 27 effluent limitation exceedances. The Discharger reported that most of the effluent limitation exceedances were caused by the inflow of sewage from Tijuana, Mexico exceeding the design flow capacity of the SBIWTP. In addition, the Discharger has not submitted six self-monitoring reports with appropriate units and values consistent with the Order, as directed by the State Water Resources Control Board (State Water Board). The missing reports are for the months of April 2022 through September 2022.

Dr. Maria-Elena Giner
USIBWC

-2-

October 27, 2023

2. Summary of Alleged Violations of the Order

The Discharger is alleged to have violated the following sections of the Order:

- 2.1. Section 4 of the Order:** The Discharger is required to maintain compliance with effluent limitations in section 4.1.1.1 of the Order.

Observation: The Discharger self-reported 27¹ exceedances of effluent limitations in the California Integrated Water Quality System (CIWQS) database.

- 2.2. Attachment D, Section 1.1 of the Order:** The Discharger is required to comply with all terms, requirements, and conditions of the Order. Any noncompliance constitutes a violation of the Clean Water Act (CWA) and the California Water Code (Water Code) and is grounds for enforcement action including permit termination, revocation and reissuance, or modification; denial of a permit renewal application; or a combination thereof.

Observation: The Discharger self-reported 27 exceedances of effluent limitations.

- 2.3 Attachment E, Section 7.2 of the Order:** The Discharger is required to submit Self-Monitoring Reports to CIWQS consistent with the Order.

Observation: The Discharger submitted six self-monitoring reports for the months of April 2022 through September 2022 (CIWQS Document IDs 2528323, 2528324, 2528325, 2528326, 2528327, and 2528328). The State Water Board identified that the values for arsenic, cadmium, cyanide, copper, lead, molybdenum, nickel, selenium, silver, thallium, and zinc were submitted with incorrect units and calculated values.

On December 1, 2022, the State Water Board withdrew the submitted reports and directed the Discharger to re-submit the Self-Monitoring Reports with the corrected units and values.

The Discharger has not submitted self-monitoring reports to CIWQS with appropriate units and values consistent with the Order.

3. Potential Enforcement Actions

The alleged violations may subject the Discharger to additional enforcement by the San Diego Water Board or the State Water Board. The San Diego Water Board intends and desires to continue to engage proactively and constructively with the Discharger through judicious and progressive enforcement efforts.

For questions or concerns regarding this NOV, please contact Vicente Rodriguez by phone at 619-521-3966 or by email at Vicente.Rodriguez@waterboards.ca.gov. In the subject line of any written response, please include the following: 257821:VRodriguez.

¹ Exhibit 1, List of Violations

Dr. Maria-Elena Giner
USIBWC

-3-

October 27, 2023

Respectfully,

Laurie A. Walsh, P.E.
Supervising Water Resource Control Engineer
Surface Water Protection Branch

Attachment: Exhibit 1, List of Violations

Copies to:

Brandi Outwin-Beals, San Diego Water Board,
Brandi.Outwin-Beals@waterboards.ca.gov

Vicente Rodriguez, San Diego Water Board, Vicente.Rodriguez@waterboards.ca.gov

Morgan Rogers, Area Operations Manager, International Boundary and Water
Commission, U.S. Section, morgan.roger@ibwc.gov

Dr. Maria-Elena Giner
USIBWC

-4-

October 27, 2023

| Tech Staff Info & Use | |
|---|--|
| Technical Information | Number |
| Order No. | R9-2021-0001 |
| NPDES No. | CA0108928 |
| CW Place ID (South Bay International WTP) | CW-257821 |
| CW Party/Organization ID (IBWC-US & Mexico Section) | 21523 |
| CW Party/Person ID (Dr. Maria-Elena Giner) | 634777 |
| CW Regulatory Measure (Order No. R9-2021-0001) | 442331 |
| CW Regulatory Measure (NOV R9-2023-0205) | 454744 |
| WDID | 9 000000732 |
| Violation IDs | 1119739, 1119743, 1119745, 1119746, 1119747, 1119749, 1119750, 1119751, 1119740, 1119744, 1119748, 1119752, 1119753, 1120606, 1120607, 1120608, 1120609, 1120610, 1120611, 1120613, 1120614, 1120601, 1120602, 1120604, 1120612, 1120603, 1120605, 1121285, 1121286, 1121287, 1121288, 1121289 |

Notice of Violation R9-2023-0205**Exhibit 1****Table 1 – List of Violations**

| No. | Violation ID | Occurrence Date(s) | Violation Type | Violation Description |
|------------|---------------------|-------------------------------|-----------------------|---|
| 1 | 1119739 | 07/01/2023 through 07/31/2023 | OEV | Turbidity cloudiness exceeded the monthly average effluent limitation of 75 Nephelometric Turbidity Units (NTU) with a result of 86 NTU. |
| 2 | 1119743 | 07/01/2023 through 07/31/2023 | CAT1 | Total Suspended Solids (TSS) mass emission rate exceeded the monthly average of effluent limitation of 6,255 pounds per day (lb/day) with a result of 49,323 lb/day. |
| 3 | 1119745 | 07/01/2023 through 07/31/2023 | CAT1 | TSS percent removal did not meet the monthly average minimum requirement of 85% with a result of 51%. |
| 4 | 1119746 | 07/01/2023 through 07/31/2023 | CAT1 | TSS mass emission rate exceeded the monthly average effluent limitation of 30 milligram per liter (mg/L) with a result of 174 mg/L. |
| 5 | 1119747 | 07/01/2023 through 07/31/2023 | CAT1 | Carbonaceous Biochemical Oxygen Demand 5-day @ 20°C (CBOD) mass emission rate exceeded the monthly average of effluent limitation of 5,213 lb/day with a result of 23,975 lb/day. |
| 6 | 1119749 | 07/01/2023 through 07/31/2023 | OEV | Flow volume rate exceeded the monthly average effluent limitation of 25 million gallons per day (MGD) with a result of 33 MGD. |
| 7 | 1119750 | 07/01/2023 through 07/31/2023 | CAT1 | CBOD percent removal did not meet the monthly average minimum requirement of 85% with a result of 69%. |
| 8 | 1119751 | 07/01/2023 through 07/31/2023 | CAT1 | CBOD concentration exceeded the monthly average effluent limitation of 25 mg/L with a result of 85 mg/L. |

Notice of Violation R9-2023-0205**Exhibit 1**

| No. | Violation ID | Occurrence Date(s) | Violation Type | Violation Description |
|------------|---------------------|-------------------------------|-----------------------|---|
| 9 | 1119740 | 07/09/2023 through 07/15/2023 | OEV | Turbidity cloudiness exceeded the weekly average effluent limitation of 100 NTU with a result of 114 NTU. |
| 10 | 1119744 | 07/09/2023 through 07/15/2023 | CAT1 | CBOD concentration exceeded the weekly average effluent limitation of 40 mg/L with a result of 101 mg/L. |
| 11 | 1119748 | 07/09/2023 through 07/15/2023 | CAT1 | CBOD mass emission rate exceeded the weekly average effluent limitation of 8,340 lb/day with a result of 27,804 lb/day. |
| 12 | 1119752 | 07/09/2023 through 07/15/2023 | CAT1 | TSS mass emission rate exceeded the weekly average effluent limitation of 9,383 lb/day with a result of 62,306 lb/day. |
| 13 | 1119753 | 07/09/2023 through 07/15/2023 | CAT1 | TSS concentration exceeded the weekly average effluent limitation of 45 mg/L with a result of 227 mg/L. |
| 14 | 1120606 | 08/01/2023 through 08/31/2023 | OEV | Flow volume rate exceeded the monthly average effluent limitation of 25 MGD with a result of 27 MGD. |
| 15 | 1120607 | 08/01/2023 through 08/31/2023 | CAT1 | CBOD percent removal did not meet the monthly average minimum requirement of 85% with a result of 67%. |
| 16 | 1120608 | 08/01/2023 through 08/31/2023 | CAT1 | CBOD mass emission rate exceeded the monthly average of effluent limitation of 5,213 lb/day with a result of 18,013 lb/day. |
| 17 | 1120609 | 08/01/2023 through 08/31/2023 | CAT1 | TSS percent removal did not meet the monthly average minimum requirement of 85% with a result of 52%. |
| 18 | 1120610 | 08/01/2023 through 08/31/2023 | CAT1 | TSS mass emission rate exceeded the monthly average of effluent limitation of 30 lb/day with a result of 142 lb/day. |

Notice of Violation R9-2023-0205
Exhibit 1

| No. | Violation ID | Occurrence Date(s) | Violation Type | Violation Description |
|------------|---------------------|-------------------------------|-----------------------|--|
| 19 | 1120611 | 08/01/2023 through 08/31/2023 | CAT1 | TSS mass emission rate exceeded the monthly average of effluent limitation of 6,255 lb/day with a result of 34,835 lb/day. |
| 20 | 1120613 | 08/01/2023 through 08/31/2023 | OEV | Turbidity cloudiness exceeded the monthly average of effluent limitation of 75 NTU with a result of 83 NTU. |
| 21 | 1120614 | 08/01/2023 through 08/31/2023 | CAT1 | CBOD concentration exceeded the monthly average of effluent limitation of 25 mg/L with a result of 73 mg/L. |
| 22 | 1120601 | 08/06/2023 through 08/12/2023 | CAT1 | CBOD concentration exceeded the weekly average effluent limitation of 40 mg/L with a result of 110 mg/L. |
| 23 | 1120602 | 08/06/2023 through 08/12/2023 | CAT1 | CBOD mass emission rate exceeded the weekly average effluent limitation of 8,340 lb/day with a result of 275,415 lb/day. |
| 24 | 1120604 | 08/06/2023 through 08/12/2023 | CAT1 | TSS mass emission rate exceeded the weekly average effluent limitation of 9,383 lb/day with a result of 45,716 lb/day. |
| 25 | 1120612 | 08/06/2023 through 08/12/2023 | CAT1 | TSS concentration exceeded the weekly average effluent limitation of 45 mg/L with a result of 184 mg/L. |
| 26 | 1120603 | 08/20/2023 through 08/26/2023 | OEV | Turbidity cloudiness exceeded the weekly average effluent limitation of 100 NTU with a result of 126 NTU. |
| 27 | 1120605 | 08/21/2023 | OEV | Turbidity cloudiness exceeded the instantaneous maximum effluent limitation of 225 NTU with a result of 708 NTU. |

Notice of Violation R9-2023-0205**Exhibit 1****Table 2 - Definitions**

| TERM | DEFINITION |
|-----------------------|--|
| CAT1 | Category 1 violation type. This violation type is identified when the water quality effluent parameter is part of the Group I pollutant. |
| CAT2 | Category 2 violation type. This violation type is identified when the water quality effluent parameter is part of the Group II pollutant. |
| CIWQS | California Integrated Water Quality System database. |
| GROUP | The list of pollutants is based on Appendix A to section 123.45 of title 40 of the Code of Federal Regulations. |
| Occurrence Date(s) | Date that a violation occurred. For continuing violations, such as a monthly average, the days of the reporting period are used. If the occurrence date is unknown, the date is entered as the day it was first discovered by staff, the discharger, or a third party. For deficient or late reports, the occurrence date is the day after the report was due. |
| OEV | Violation of any constituent-specific effluent limitation not included in Group I or Group II. |
| Violation Description | Narrative description of the violation. |
| Violation ID | Identification number assigned to a violation in CIWQS. |



San Diego Regional Water Quality Control Board

November 16, 2023

Dr. Maria-Elena Giner, P.E.
Commissioner
International Boundary and Water
Commission, United States Section
4191 N. Mesa
El Paso, Texas 79902
mariaelena.giner@ibwc.gov

Sent by Email Only
In reply refer to:
257821:VRodriguez

**Subject: Notice of Violation No. R9-2023-0216 to the United States
International Boundary and Water Commission for Violations of
Order No. R9-2021-0001**

Dr. Maria-Elena Giner:

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) hereby issues Notice of Violation (NOV) No. R9-2023-0216 to the United States International Boundary and Water Commission (USIBWC or Discharger) for alleged violations of Order No. R9-2021-0001, NPDES No. CA0108928, *Waste Discharge Requirements for the United States Section of the International Boundary and Water Commission, South Bay International Wastewater Treatment Plant, Discharge to the Pacific Ocean through the South Bay Ocean Outfall* (Order). These alleged violations are a result of the Discharger's failure to comply with the Order.

1. Background

The Discharger is required to operate and maintain the South Bay International Wastewater Treatment Plant (SBIWTP) in compliance with requirements contained in the Order. Consistent with the Order, the Discharger is required to submit self-monitoring reports and other technical reports. Between September 1, 2023, and September 30, 2023, the Discharger self-reported ten effluent limitation exceedances.

2. Summary of Alleged Violations of the Order

The Discharger is alleged to have violated the following sections of the Order:

2.1. Section 4 of the Order: The Discharger is required to maintain compliance with effluent limitations in section 4.1.1.1 of the Order.

Observation: The Discharger self-reported ten¹ exceedances of effluent limitations in the California Integrated Water Quality System (CIWQS) database.

¹ Exhibit 1, List of Violations

Dr. Maria-Elena Giner
USIBWC

-2-

November 16, 2023

2.2. Attachment D, Section 1.1 of the Order: The Discharger is required to comply with all terms, requirements, and conditions of the Order. Any noncompliance constitutes a violation of the Clean Water Act (CWA) and the California Water Code (Water Code) and is grounds for enforcement action including permit termination, revocation and reissuance, or modification; denial of a permit renewal application; or a combination thereof.

Observation: The Discharger self-reported 10 exceedances of effluent limitations.

3. Potential Enforcement Actions

The alleged violations may subject the Discharger to additional enforcement by the San Diego Water Board or the State Water Board. The San Diego Water Board intends and desires to continue to engage proactively and constructively with the Discharger through judicious and progressive enforcement efforts.

For questions or concerns regarding this NOV, please contact Vicente Rodriguez by phone at 619-521-3966 or by email at Vicente.Rodriguez@waterboards.ca.gov. In the subject line of any written response, please include the following: 257821:VRodriguez.

Respectfully,

Brandi Outwin-Beals, P.E.
Senior Water Resource Control Engineer
Source Control Regulation Unit

Attachment: Exhibit 1, List of Violations

Copies to:

Laurie A. Walsh, San Diego Water Board, Laurie.Walsh@waterboards.ca.gov

Vicente Rodriguez, San Diego Water Board, Vicente.Rodriguez@waterboards.ca.gov

Morgan Rogers, Area Operations Manager, International Boundary and Water Commission, U.S. Section, morgan.roger@ibwc.gov

Dr. Maria-Elena Giner
USIBWC

-3-

November 16, 2023

| Tech Staff Info & Use | |
|---|---|
| Technical Information | Number |
| Order No. | R9-2021-0001 |
| NPDES No. | CA0108928 |
| CW Place ID (South Bay International WTP) | CW-257821 |
| CW Party/Organization ID (IBWC-US & Mexico Section) | 21523 |
| CW Party/Person ID (Dr. Maria-Elena Giner) | 634777 |
| CW Regulatory Measure (Order No. R9-2021-0001) | 442331 |
| CW Regulatory Measure (NOV R9-2023-0216) | 455044 |
| WDID | 9 000000732 |
| Violation IDs | 1121385, 1121387, 1121388, 1121389, 1121392, 1121386, 1121390, 1121393, 1121394, 1121391 |

Notice of Violation R9-2023-0216**Exhibit 1****Table 1 – List of Violations**

| No. | Violation ID | Occurrence Date(s) | Violation Type | Violation Description |
|------------|---------------------|-------------------------------|-----------------------|--|
| 1 | 1121385 | 09/01/2023 through 09/30/2023 | CAT1 | Carbonaceous Biochemical Oxygen Demand 5-day @ 20°C (CBOD) concentration exceeded the monthly average effluent limitation of 25 mg/L with a result of 29 mg/L. |
| 2 | 1121387 | 09/01/2023 through 09/30/2023 | CAT1 | Total Suspended Solids (TSS) percent removal did not meet the monthly average minimum requirement of 85% with a result of 76%. |
| 3 | 1121388 | 09/01/2023 through 09/30/2023 | CAT1 | TSS concentration exceeded the monthly average effluent limitation of 30 mg/L with a result of 60 mg/L. |
| 4 | 1121389 | 09/01/2023 through 09/30/2023 | CAT1 | TSS mass emission rate exceeded the monthly average effluent limitation of 6,255 lb/day with a result of 13,035 lb/day. |
| 5 | 1121392 | 09/01/2023 through 09/30/2023 | CAT1 | CBOD mass emission rate exceeded the monthly average effluent limitation of 5,213 lb/day with a result of 6,268 lb/day. |
| 6 | 1121386 | 09/17/2023 through 09/23/2023 | CAT1 | CBOD concentration exceeded the weekly average effluent limitation of 40 mg/L with a result of 60 lb/day. |
| 7 | 1121390 | 09/17/2023 through 09/23/2023 | CAT1 | TSS mass emission rate exceeded the weekly average effluent limitation of 9,383 lb/day with a result of 32,230 lb/day. |
| 8 | 1121393 | 09/17/2023 through 09/23/2023 | CAT1 | CBOD mass emission rate exceeded the weekly average effluent limitation of 8,340 lb/day with a result of 13,650 lb/day. |
| 9 | 1121394 | 09/17/2023 through 09/23/2023 | CAT1 | TSS concentration exceeded the weekly average effluent limitation of 45 mg/L with a result of 141 mg/L. |
| 10 | 1121391 | 09/20/2023 | OEV | Turbidity cloudiness exceeded the instantaneous effluent limitation of 225 NTU with a result of 405 NTU. |

Notice of Violation R9-2023-0216
Exhibit 1

Table 2 - Definitions

| TERM | DEFINITION |
|-----------------------|--|
| CAT1 | Category 1 violation type. This violation type is identified when the water quality effluent parameter is part of the Group I pollutant. |
| CAT2 | Category 2 violation type. This violation type is identified when the water quality effluent parameter is part of the Group II pollutant. |
| CIWQS | California Integrated Water Quality System database. |
| GROUP | The list of pollutants is based on Appendix A to section 123.45 of title 40 of the Code of Federal Regulations. |
| Occurrence Date(s) | Date that a violation occurred. For continuing violations, such as a monthly average, the days of the reporting period are used. If the occurrence date is unknown, the date is entered as the day it was first discovered by staff, the discharger, or a third party. For deficient or late reports, the occurrence date is the day after the report was due. |
| OEV | Violation of any constituent-specific effluent limitation not included in Group I or Group II. |
| Violation Description | Narrative description of the violation. |
| Violation ID | Identification number assigned to a violation in CIWQS. |



San Diego Regional Water Quality Control Board

December 21, 2023

Dr. Maria-Elena Giner, P.E.
Commissioner
International Boundary and Water
Commission, United States Section
4191 N. Mesa
El Paso, Texas 79902
mariaelena.giner@ibwc.gov

Sent by Email Only

In reply refer to:
257821:VRodriguez

**Subject: Notice of Violation No. R9-2023-0222 to the United States
International Boundary and Water Commission for Violations of
Order No. R9-2021-0001**

Dr. Maria-Elena Giner:

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) hereby issues Notice of Violation (NOV) No. R9-2023-0222 to the United States International Boundary and Water Commission (USIBWC or Discharger) for alleged violations of Order No. R9-2021-0001, NPDES No. CA0108928, *Waste Discharge Requirements for the United States Section of the International Boundary and Water Commission, South Bay International Wastewater Treatment Plant, Discharge to the Pacific Ocean through the South Bay Ocean Outfall* (Order). These alleged violations are a result of the Discharger's failure to comply with the Order.

1. Background

The Discharger is required to operate and maintain the South Bay International Wastewater Treatment Plant (SBIWTP) in compliance with requirements contained in the Order. Consistent with the Order, the Discharger is required to submit self-monitoring reports and other technical reports. Between October 1, 2023, and October 31, 2023, the Discharger self-reported 16 effluent limitation exceedances. In addition, the Discharger has not submitted six self-monitoring reports with appropriate units and values consistent with the Order, as directed by the State Water Resources Control Board (State Water Board). The missing reports are for the months of April 2022 through September 2022.

2. Summary of Alleged Violations of the Order

The Discharger is alleged to have violated the following sections of the Order:

- 2.1. Section 4 of the Order:** The Discharger is required to maintain compliance with effluent limitations in section 4.1.1.1 of the Order.

Dr. Maria-Elena Giner
USIBWC

-2-

December 21, 2023

Observation: The Discharger self-reported 16¹ exceedances of effluent limitations in the California Integrated Water Quality System (CIWQS) database.

- 2.2. Attachment D, Section 1.1 of the Order:** The Discharger is required to comply with all terms, requirements, and conditions of the Order. Any noncompliance constitutes a violation of the Clean Water Act (CWA) and the California Water Code (Water Code) and is grounds for enforcement action including permit termination, revocation and reissuance, or modification; denial of a permit renewal application; or a combination thereof.

Observation: The Discharger had 22 violations of the Order.

- 2.3. Attachment E, Section 7.2 of the Order:** The Discharger is required to submit Self-Monitoring Reports to CIWQS consistent with the Order.

Observation: The Discharger submitted six self-monitoring reports for the months of April 2022 through September 2022 (CIWQS Document IDs 2528323 2528324, 2528325, 2528326, 2528327, and 2528328). The State Water Board identified that the values for arsenic, cadmium, cyanide, copper, lead, molybdenum, nickel, selenium, silver, thallium, and zinc were submitted with incorrect units and calculated values.

On December 1, 2022, the State Water Board withdrew the submitted reports and directed the Discharger to re-submit the Self-Monitoring Reports with the corrected units and values.

The Discharger has not submitted self-monitoring reports to CIWQS with appropriate units and values consistent with the Order.

3. Potential Enforcement Actions

The alleged violations may subject the Discharger to additional enforcement by the San Diego Water Board or the State Water Board. The San Diego Water Board intends and desires to continue to engage proactively and constructively with the Discharger through judicious and progressive enforcement efforts.

For questions or concerns regarding this NOV, please contact Vicente Rodriguez by phone at 619-521-3966 or by email at Vicente.Rodriguez@waterboards.ca.gov. In the subject line of any written response, please include the following: 257821:VRodriguez.

Respectfully,

Kelly Dorsey
Assistant Executive Officer

¹ Exhibit 1, List of Violations

Dr. Maria-Elena Giner
USIBWC

-3-

December 21, 2023

Attachment: Exhibit 1, List of Violations

Copies to:

Laurie A. Walsh, San Diego Water Board, laurie.walsh@waterboards.ca.gov

Brandi Outwin-Beals, San Diego Water Board, brandi.outwin-beals@waterboards.ca.gov

Vicente Rodriguez, San Diego Water Board, vicente.rodriguez@waterboards.ca.gov

Morgan Rogers, Area Operations Manager, International Boundary and Water Commission, U.S. Section, morgan.roger@ibwc.gov

| Tech Staff Info & Use | |
|---|--|
| Technical Information | Number |
| Order No. | R9-2021-0001 |
| NPDES No. | CA0108928 |
| CW Place ID (South Bay International WTP) | CW-257821 |
| CW Party/Organization ID (IBWC-US & Mexico Section) | 21523 |
| CW Party/Person ID (Dr. Maria-Elena Giner) | 634777 |
| CW Regulatory Measure (Order No. R9-2021-0001) | 442331 |
| CW Regulatory Measure (NOV R9-2023-0222) | 455365 |
| WDID | 9 000000732 |
| Violation IDs | 1122285, 1122286, 1122276, 1122277, 1122281, 1122282, 1122287, 1122288, 1122289, 1122290, 1122275, 1122280, 1122283, 1122284, 1121285, 1121286, 1121287, 1121288, 1121289, 1121290, 1122278, 1122279 |

Notice of Violation R9-2023-0222**Exhibit 1****Table 1 – List of Violations**

| No. | Violation ID | Occurrence Date(s) | Violation Type | Violation Description |
|------------|---------------------|-------------------------------|-----------------------|--|
| 1 | 1122285 | 10/01/2023 | OEV | Turbidity cloudiness exceeded the instantaneous effluent limitation of 225 NTU with a result of 653 NTU. |
| 2 | 1122286 | 10/01/2023 | OEV | Settleable Solids concentration exceeded the instantaneous effluent limitation of 3 mg/L with a result of 21 mg/L. |
| 3 | 1122276 | 10/01/2023 through 10/31/2023 | CAT1 | Total Suspended Solids (TSS) concentration exceeded the monthly average effluent limitation of 30 mg/L with a result of 233 mg/L. |
| 4 | 1122277 | 10/01/2023 through 10/31/2023 | CAT1 | TSS mass emission rate exceeded the monthly average effluent limitation of 6,255 lb/day with a result of 51,038 lb/day. |
| 5 | 1122281 | 10/01/2023 through 10/31/2023 | CAT1 | Carbonaceous Biochemical Oxygen Demand 5-day @ 20°C (CBOD) concentration exceeded the monthly average effluent limitation of 25 mg/L with a result of 89 mg/L. |
| 6 | 1122282 | 10/01/2023 through 10/31/2023 | CAT1 | CBOD mass emission rate exceeded the monthly average effluent limitation of 5,213 lb/day with a result of 19,520 lb/day. |
| 7 | 1122287 | 10/01/2023 through 10/31/2023 | OEV | Turbidity cloudiness exceeded the monthly average effluent limitation of 75 NTU with a result of 144 NTU. |
| 8 | 1122288 | 10/01/2023 through 10/31/2023 | CAT1 | TSS percent removal did not meet the monthly average minimum requirement of 85% with a result of 20%. |
| 9 | 1122289 | 10/01/2023 through 10/31/2023 | OEV | Flowrate exceeded the monthly average effluent limitation of 25 million gallons per day (MGD) with a result of 25.41 MGD. |
| 10 | 1122290 | 10/01/2023 through 10/31/2023 | CAT1 | CBOD percent removal did not meet the monthly average minimum requirement of 85% with a result of 59%. |

Notice of Violation R9-2023-0222**Exhibit 1**

| No. | Violation ID | Occurrence Date(s) | Violation Type | Violation Description |
|------------|---------------------|-------------------------------|-----------------------|--|
| 11 | 1122275 | 10/08/2023 through 10/14/2023 | CAT1 | TSS mass emission rate exceeded the weekly average effluent limitation of 9,383 lb/day with a result of 79,055 lb/day. |
| 12 | 1122280 | 10/08/2023 through 10/14/2023 | CAT1 | CBOD mass emission rate exceeded the weekly average effluent limitation of 8,340 lb/day with a result of 31,994 lb/day. |
| 13 | 1122283 | 10/08/2023 through 10/14/2023 | OEV | Settleable Solids concentration exceeded the weekly average effluent limitation of 2 mg/L with a result of 3 mg/L. |
| 14 | 1122284 | 10/08/2023 through 10/14/2023 | OEV | Turbidity cloudiness exceeded the weekly average effluent limitation of 100 NTU with a result of 235 NTU. |
| 15 | 1121285 | 10/18/2023 | Late Report | Failure to re-submit report following withdrawal. Monthly self-monitoring report for April 2022 - Not Submitted. Doc ID: 2528323 |
| 16 | 1121286 | 10/18/2023 | Late Report | Failure to re-submit report following withdrawal. Monthly self-monitoring report for May 2022 - Not Submitted. Doc ID: 2528324 |
| 17 | 1121287 | 10/18/2023 | Late Report | Failure to re-submit report following withdrawal. Monthly self-monitoring report for June 2022 - Not Submitted. Doc ID: 2528325 |
| 18 | 1121288 | 10/18/2023 | Late Report | Failure to re-submit report following withdrawal. Monthly self-monitoring report for July 2022 - Not Submitted. Doc ID: 2528326 |
| 19 | 1121289 | 10/18/2023 | Late Report | Failure to re-submit report following withdrawal. Monthly self-monitoring report for August 2022 - Not Submitted. Doc ID: 2528327 |
| 20 | 1121290 | 10/18/2023 | Late Report | Failure to re-submit report following withdrawal. Monthly self-monitoring report for September 2022 - Not Submitted. Doc ID: 2528328 |

Notice of Violation R9-2023-0222**Exhibit 1**

| No. | Violation ID | Occurrence Date(s) | Violation Type | Violation Description |
|------------|---------------------|-------------------------------|-----------------------|--|
| 21 | 1122278 | 10/29/2023 through 10/31/2023 | CAT1 | TSS concentration exceeded the weekly average effluent limitation of 45 mg/L with a result of 327 mg/L. |
| 22 | 1122279 | 10/29/2023 through 10/31/2023 | CAT1 | CBOD concentration exceeded the weekly average effluent limitation of 40 mg/L with a result of 134 mg/L. |

Table 2 - Definitions

| TERM | DEFINITION |
|-----------------------|--|
| CAT1 | Category 1 violation type. This violation type is identified when the water quality effluent parameter is part of the Group I pollutant. |
| CAT2 | Category 2 violation type. This violation type is identified when the water quality effluent parameter is part of the Group II pollutant. |
| CIWQS | California Integrated Water Quality System database. |
| GROUP | The list of pollutants is based on Appendix A to section 123.45 of title 40 of the Code of Federal Regulations. |
| Occurrence Date(s) | Date that a violation occurred. For continuing violations, such as a monthly average, the days of the reporting period are used. If the occurrence date is unknown, the date is entered as the day it was first discovered by staff, the discharger, or a third party. For deficient or late reports, the occurrence date is the day after the report was due. |
| OEV | Violation of any constituent-specific effluent limitation not included in Group I or Group II. |
| Violation Description | Narrative description of the violation. |
| Violation ID | Identification number assigned to a violation in CIWQS. |



San Diego Regional Water Quality Control Board

January 18, 2023

Dr. Maria-Elena Giner, P.E.
Commissioner
International Boundary and Water
Commission, United States Section
4191 N. Mesa
El Paso, Texas 79902
mariaelena.giner@ibwc.gov

Sent by Email Only

In reply refer to:
257821:VRodriguez

**Subject: Notice of Violation No. R9-2024-0026 to the United States
International Boundary and Water Commission for Violations of
Order No. R9-2021-0001**

Dr. Maria-Elena Giner:

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) hereby issues Notice of Violation (NOV) No. R9-2024-0026 to the United States International Boundary and Water Commission (USIBWC or Discharger) for alleged violations of Order No. R9-2021-0001, NPDES No. CA0108928, *Waste Discharge Requirements for the United States Section of the International Boundary and Water Commission, South Bay International Wastewater Treatment Plant, Discharge to the Pacific Ocean through the South Bay Ocean Outfall* (Order). These alleged violations are a result of the Discharger's failure to comply with the Order.

1. Background

The Discharger is required to operate and maintain the South Bay International Wastewater Treatment Plant (SBIWTP) in compliance with requirements contained in the Order. Consistent with the Order, the Discharger is required to submit self-monitoring reports and other technical reports. Between November 1, 2023, and November 30, 2023, the Discharger self-reported 11 effluent limitation exceedances. In addition, the Discharger has not submitted six self-monitoring reports with appropriate units and values consistent with the Order, as directed by the State Water Resources Control Board (State Water Board). The missing reports are for the months of April 2022 through September 2022.

2. Summary of Alleged Violations of the Order

The Discharger is alleged to have violated the following sections of the Order:

2.1. Section 4 of the Order: The Discharger is required to maintain compliance with effluent limitations in section 4.1.1.1 of the Order.

Dr. Maria-Elena Giner
USIBWC

-2-

January 18, 2024

Observation: The Discharger self-reported 11¹ exceedances of effluent limitations in the California Integrated Water Quality System (CIWQS) database.

- 2.2. Attachment D, Section 1.1 of the Order:** The Discharger is required to comply with all terms, requirements, and conditions of the Order. Any noncompliance constitutes a violation of the Clean Water Act (CWA) and the California Water Code (Water Code) and is grounds for enforcement action including permit termination, revocation and reissuance, or modification; denial of a permit renewal application; or a combination thereof.

Observation: The Discharger had 17 violations of the Order.

- 2.3. Attachment E, Section 7.2 of the Order:** The Discharger is required to submit self-monitoring reports to CIWQS consistent with the Order.

Observation: The Discharger submitted six self-monitoring reports for the months of April 2022 through September 2022 (CIWQS Document IDs 2528323, 2528324, 2528325, 2528326, 2528327, and 2528328). The State Water Board identified that the values for arsenic, cadmium, cyanide, copper, lead, molybdenum, nickel, selenium, silver, thallium, and zinc were submitted with incorrect units and calculated values.

On December 1, 2022, the State Water Board withdrew the submitted reports and directed the Discharger to re-submit the self-monitoring reports with the corrected units and values.

The Discharger has not submitted self-monitoring reports to CIWQS with appropriate units and values consistent with the Order.

3. Potential Enforcement Actions

The alleged violations may subject the Discharger to additional enforcement by the San Diego Water Board or the State Water Board. The San Diego Water Board intends and desires to continue to engage proactively and constructively with the Discharger through judicious and progressive enforcement efforts.

For questions or concerns regarding this NOV, please contact Vicente Rodriguez by phone at 619-521-3966 or by email at Vicente.Rodriguez@waterboards.ca.gov. In the subject line of any written response, please include the following: 257821:VRodriguez.

Respectfully,

Brandi Outwin-Beals
Senior Water Resource Control Engineer
Source Control Regulation Unit

¹ Exhibit 1, List of Violations

Dr. Maria-Elena Giner
USIBWC

-3-

January 18, 2024

Attachment: Exhibit 1, List of Violations

Copies to:

Morgan Rogers, Area Operations Manager, International Boundary and Water Commission, U.S. Section, morgan.roger@ibwc.gov

Isela Canava, International Boundary and Water Commission, U.S. Section, isela.canava@ibwc.gov

Rebecca Rizzuti, International Boundary and Water Commission, U.S. Section, rebecca.rizzuti@ibwc.gov

David Gibson, San Diego Water Board, david.gibson@waterboards.ca.gov

Kelly Dorsey, San Diego Water Board, kelly.dorsey.gibson@waterboards.ca.gov

Laurie A. Walsh, San Diego Water Board, laurie.walsh@waterboards.ca.gov

Brandi Outwin-Beals, San Diego Water Board, brandi.outwin-beals@waterboards.ca.gov

Vicente Rodriguez, San Diego Water Board, vicente.rodriquez@waterboards.ca.gov

| Tech Staff Info & Use | |
|---|---|
| Technical Information | Number |
| Order No. | R9-2021-0001 |
| NPDES No. | CA0108928 |
| CW Place ID (South Bay International WTP) | CW-257821 |
| CW Party/Organization ID (IBWC-US & Mexico Section) | 21523 |
| CW Party/Person ID (Dr. Maria-Elena Giner) | 634777 |
| CW Regulatory Measure (Order No. R9-2021-0001) | 442331 |
| CW Regulatory Measure (NOV R9-2024-0026) | 455560 |
| WDID | 9 000000732 |
| Violation IDs | 1122951, 1122952, 1122953, 1122954, 1122956, 1122957, 1122959, 1122950, 1122955, 1122958, 1122960, 1121285, 1121286, 1121287, 1121288, 1121289, 1121290 |

Notice of Violation R9-2024-0026**Exhibit 1****Table 1 – List of Violations**

| No. | Violation ID | Occurrence Date(s) | Violation Type | Violation Description |
|------------|---------------------|-------------------------------|-----------------------|---|
| 1 | 1122951 | 11/01/2023 through 11/30/2023 | OEV | Flowrate exceeded the monthly average effluent limitation of 25 million gallons per day (MGD) with a result of 26.22 MGD. |
| 2 | 1122952 | 11/01/2023 through 11/30/2023 | CAT1 | CBOD percent removal did not meet the monthly average minimum requirement of 85% with a result of 74%. |
| 3 | 1122953 | 11/01/2023 through 11/30/2023 | CAT1 | CBOD concentration exceeded the monthly average effluent limitation of 25 mg/L with a result of 69 mg/L. |
| 4 | 1122954 | 11/01/2023 through 11/30/2023 | CAT1 | CBOD mass emission rate exceeded the monthly average effluent limitation of 5,213 lb/day with a result of 15,900 lb/day. |
| 5 | 1122956 | 11/01/2023 through 11/30/2023 | CAT1 | TSS percent removal did not meet the monthly average minimum requirement of 85% with a result of 53%. |
| 6 | 1122957 | 11/01/2023 through 11/30/2023 | CAT1 | TSS concentration exceeded the monthly average effluent limitation of 30 mg/L with a result of 168 mg/L. |
| 7 | 1122959 | 11/01/2023 through 11/30/2023 | CAT1 | TSS mass emission rate exceeded the monthly average effluent limitation of 6,255 lb/day with a result of 39,390 lb/day. |
| 8 | 1122950 | 11/12/2023 through 11/18/2023 | CAT1 | CBOD mass emission rate exceeded the weekly average effluent limitation of 8,340 lb/day with a result of 26,180 lb/day. |
| 9 | 1122955 | 11/12/2023 through 11/18/2023 | CAT1 | CBOD concentration exceeded the weekly average effluent limitation of 40 mg/L with a result of 110 mg/L. |
| 10 | 1122958 | 11/12/2023 through 11/18/2023 | CAT1 | TSS mass emission rate exceeded the weekly average effluent limitation of 9,383 lb/day with a result of 69,648 lb/day. |

Notice of Violation R9-2024-0026**Exhibit 1**

| No. | Violation ID | Occurrence Date(s) | Violation Type | Violation Description |
|------------|---------------------|-------------------------------|-----------------------|--|
| 11 | 1122960 | 11/12/2023 through 11/18/2023 | CAT1 | TSS concentration exceeded the weekly average effluent limitation of 45 mg/L with a result of 292 mg/L. |
| 12 | 1121285 | 10/18/2023 | Late Report | Failure to re-submit report following withdrawal. Monthly self-monitoring report for April 2022 - Not Submitted. Doc ID: 2528323 |
| 13 | 1121286 | 10/18/2023 | Late Report | Failure to re-submit report following withdrawal. Monthly self-monitoring report for May 2022 - Not Submitted. Doc ID: 2528324 |
| 14 | 1121287 | 10/18/2023 | Late Report | Failure to re-submit report following withdrawal. Monthly self-monitoring report for June 2022 - Not Submitted. Doc ID: 2528325 |
| 15 | 1121288 | 10/18/2023 | Late Report | Failure to re-submit report following withdrawal. Monthly self-monitoring report for July 2022 - Not Submitted. Doc ID: 2528326 |
| 16 | 1121289 | 10/18/2023 | Late Report | Failure to re-submit report following withdrawal. Monthly self-monitoring report for August 2022 - Not Submitted. Doc ID: 2528327 |
| 17 | 1121290 | 10/18/2023 | Late Report | Failure to re-submit report following withdrawal. Monthly self-monitoring report for September 2022 - Not Submitted. Doc ID: 2528328 |

Notice of Violation R9-2024-0026
Exhibit 1

Table 2 - Definitions

| TERM | DEFINITION |
|-----------------------|--|
| CAT1 | Category 1 violation type. This violation type is identified when the water quality effluent parameter is part of the Group I pollutant. |
| CAT2 | Category 2 violation type. This violation type is identified when the water quality effluent parameter is part of the Group II pollutant. |
| CIWQS | California Integrated Water Quality System database. |
| GROUP | The list of pollutants is based on Appendix A to section 123.45 of title 40 of the Code of Federal Regulations. |
| Occurrence Date(s) | Date that a violation occurred. For continuing violations, such as a monthly average, the days of the reporting period are used. If the occurrence date is unknown, the date is entered as the day it was first discovered by staff, the discharger, or a third party. For deficient or late reports, the occurrence date is the day after the report was due. |
| OEV | Violation of any constituent-specific effluent limitation not included in Group I or Group II. |
| Violation Description | Narrative description of the violation. |
| Violation ID | Identification number assigned to a violation in CIWQS. |



San Diego Regional Water Quality Control Board

February 14, 2024

Dr. Maria-Elena Giner, P.E.
Commissioner
International Boundary and Water
Commission, United States Section
4191 N. Mesa
El Paso, Texas 79902
mariaelena.giner@ibwc.gov

Sent by Email Only
In reply refer to:
257821:VRodriguez

**Subject: Notice of Violation No. R9-2024-0045 to the United States
International Boundary and Water Commission for Violations of
Order No. R9-2021-0001**

Dr. Maria-Elena Giner:

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) hereby issues Notice of Violation (NOV) No. R9-2024-0045 to the United States International Boundary and Water Commission (USIBWC or Discharger) for alleged violations of Order No. R9-2021-0001, NPDES No. CA0108928, *Waste Discharge Requirements for the United States Section of the International Boundary and Water Commission, South Bay International Wastewater Treatment Plant, Discharge to the Pacific Ocean through the South Bay Ocean Outfall* (Order). These alleged violations are a result of the Discharger's failure to comply with the Order.

1. Background

The Discharger is required to operate and maintain the South Bay International Wastewater Treatment Plant (SBIWTP) in compliance with requirements contained in the Order. Consistent with the Order, the Discharger is required to submit self-monitoring reports and other technical reports. Between December 1, 2023, and December 31, 2023, the Discharger self-reported 16 effluent limitation exceedances, and the San Diego Water Board identified a missing report. In addition, the Discharger has not re-submitted 18 self-monitoring reports with appropriate units and values consistent with the Order.

2. Summary of Alleged Violations of the Order

The Discharger is alleged to have violated the following sections of the Order:

2.1. Section 4 of the Order: The Discharger is required to maintain compliance with effluent limitations in section 4.1.1.1 of the Order.

Dr. Maria-Elena Giner
USIBWC

-2-

February 14, 2024

Observation: The Discharger self-reported 16¹ exceedances of effluent limitations in the California Integrated Water Quality System (CIWQS) database.

- 2.2. Attachment E, Section 4.2.4 of the Order:** The Discharger was required to submit a Tijuana River Valley Monitoring Plan (TRVMP) Work Plan by September 29, 2021.

Observation: This Discharger has not submitted the TRVMP Work Plan.

- 2.3. Attachment D, Section 1.1 of the Order:** The Discharger is required to comply with all terms, requirements, and conditions of the Order. Any noncompliance constitutes a violation of the Clean Water Act (CWA) and the California Water Code (Water Code) and is grounds for enforcement action including permit termination, revocation and reissuance, or modification; denial of a permit renewal application; or a combination thereof.

Observation: The Discharger had 35 violations of the Order.

- 2.4. Attachment E, Section 7.2 of the Order:** The Discharger is required to submit Self-Monitoring Reports to CIWQS consistent with the Order.

Observation: The Discharger submitted 18 self-monitoring reports for the months of April 2022 through March 2023, August 2023, November 2023, and quarters Q2 2022, Q3 2022, Q4 2022, Q1 2023. (CIWQS Document IDs 2528323, 2528324, 2528227, 2528325, 2528326, 2528327, 2528328, 2528228, 2528329, 2528330, 2528229, 2528331, 2528332, 2528333, 2528249, 2528334, 2528339, 2528342).

The State Water Board identified that the values for arsenic, cadmium, cyanide, copper, lead, molybdenum, nickel, selenium, silver, thallium, and zinc were submitted with incorrect units and calculated values.

On December 1, 2022, the State Water Board withdrew six of the submitted reports (April 2022 through September 2022) and directed the Discharger to re-submit the Self-Monitoring Reports with the corrected units and values.

On January 18, 2024, the Discharger requested that self-monitoring reports for the months of May 2022 through November 2023 and all quarters listed above be withdrawn, so the Discharger could re-submit with corrected values.

The Discharger has not re-submitted the self-monitoring reports to CIWQS with appropriate units and values consistent with the Order.

3. Potential Enforcement Actions

The alleged violations may subject the Discharger to additional enforcement by the San Diego Water Board or the State Water Board. The San Diego Water Board intends and desires to continue to engage proactively and constructively with the Discharger through judicious and progressive enforcement efforts.

¹ Exhibit A, List of Violations

Dr. Maria-Elena Giner
USIBWC

-3-

February 14, 2024

For questions or concerns regarding this NOV, please contact Vicente Rodriguez by phone at 619-521-3966 or by email at Vicente.Rodriguez@waterboards.ca.gov. In the subject line of any written response, please include the following: 257821:VRodriguez.

Respectfully,

Brandi Outwin-Beals
Senior Water Resource Control Engineer
Source Control Regulation Unit

Attachment: Exhibit A, Record of Violations

Copies to:

Morgan Rogers, Area Operations Manager, International Boundary and Water Commission, U.S. Section, morgan.roger@ibwc.gov

Isela Canava, International Boundary and Water Commission, U.S. Section, Isela.canava@ibwc.gov

Rebecca Rizzuti, International Boundary and Water Commission, U.S. Section, rebecca.rizzuti@ibwc.gov

David Gibson, San Diego Water Board, david.gibson@waterboards.ca.gov

Laurie A. Walsh, San Diego Water Board, laurie.walsh@waterboards.ca.gov

Brandi Outwin-Beals, San Diego Water Board, brandi.outwin-beals@waterboards.ca.gov

Vicente Rodriguez, San Diego Water Board, vicente.rodriguez@waterboards.ca.gov

| Tech Staff Info & Use | |
|---|--------------|
| Technical Information | Number |
| Order No. | R9-2021-0001 |
| NPDES No. | CA0108928 |
| CW Place ID (South Bay International WTP) | CW-257821 |
| CW Party/Organization ID (IBWC-US & Mexico Section) | 21523 |
| CW Party/Person ID (Dr. Maria-Elena Giner) | 634777 |
| CW Regulatory Measure (Order No. R9-2021-0001) | 442331 |
| CW Regulatory Measure (NOV R9-2024-0045) | 455817 |

Dr. Maria-Elena Giner
USIBWC

February 14, 2024

| Tech Staff Info & Use | |
|-----------------------|---|
| WDID | 9 000000732 |
| Violation IDs | 1095311, 1121285, 1121286, 1121287, 1121288, 1121289, 1121290, 1123495, 1123496, 1123497, 1123498, 1123499, 1123500, 1123501, 1123502, 1123503, 1123504, 1123505, 1123506, 1123507, 1123508, 1123509, 1123510, 1123930, 1123931, 1123932, 1123933, 1123934, 1123935, 1123936, 1123937, 1123938, 1123939, 1123940, 1123941 |

EXHIBIT A
RECORD OF VIOLATIONS
NOTICE OF VIOLATION R9-2024-0026

United State International Boundary and Water Commission
South Bay International Wastewater Treatment Plant
RECORD OF VIOLATIONS (December 1, 2023 – December 31, 2023)
Data reported under Monitoring and Reporting Programs R9-2021-0001

Table A. Effluent Violations²

| Item | Date | Parameter | Units | Permit Limit | Measured / Calculated | Period | Violation Type | CIWQS Violation ID |
|------|------------|-------------------|--------|--------------|-----------------------|-----------------------|----------------|--------------------|
| 1 | 12/08/2023 | Turbidity | NTU | 225 | 483 | Instantaneous Maximum | OEV | 1123502 |
| 2 | 12/09/2023 | TSS | mg/L | 45 | 363 | Average Weekly | CAT1 | 1123497 |
| 3 | 12/09/2023 | TSS | lb/day | 9,383 | 105,325 | Average Weekly | CAT1 | 1123501 |
| 4 | 12/09/2023 | Turbidity | NTU | 100 | 269 | Average Weekly | OEV | 1123506 |
| 5 | 12/09/2023 | CBOD | mg/L | 40 | 159 | Average Weekly | CAT1 | 1123507 |
| 6 | 12/09/2023 | CBOD | lb/day | 8,340 | 46,431 | Average Weekly | CAT1 | 1123510 |
| 7 | 12/22/2023 | Settleable Solids | ml/L | 3 | 23 | Instantaneous Maximum | OEV | 1123504 |
| 8 | 12/23/2023 | Settleable Solids | ml/L | 2 | 3 | Average Weekly | OEV | 1123498 |
| 9 | 12/31/2023 | CBOD | lb/day | 521 | 25,987 | Average Monthly | CAT1 | 1123495 |
| 10 | 12/31/2023 | Flow | MGD | 25 | 29 | Average Monthly | OEV | 1123496 |
| 11 | 12/31/2023 | TSS | % | 85 | 24 | Average Monthly | CAT1 | 1123499 |
| 12 | 12/31/2023 | TSS | mg/L | 30 | 242 | Average Monthly | CAT1 | 1123500 |
| 13 | 12/31/2023 | TSS | lb/day | 6,255 | 62,599 | Average Monthly | CAT1 | 1123503 |
| 14 | 12/31/2023 | Turbidity | NTU | 75 | 172 | Average Monthly | OEV | 1123505 |
| 15 | 12/31/2023 | CBOD | mg/L | 25 | 98 | Average Monthly | CAT1 | 1123508 |
| 16 | 12/31/2023 | CBOD | % | 85 | 60 | Average Monthly | CAT1 | 1123509 |

² See Exhibit A, Table C for definitions of abbreviations.

EXHIBIT A
RECORD OF VIOLATIONS
NOTICE OF VIOLATION R9-2024-0026

Table B. Reporting Violations

| <u>Item</u> | <u>Report</u> | <u>Document ID</u> | <u>Due Date</u> | <u>Date Submitted</u> | <u>Date Withdrawn</u> | <u>CIWQS Violation ID</u> |
|-------------|---|--------------------|-----------------|-----------------------|-----------------------|---------------------------|
| 1 | Tijuana River Valley Monitoring Program Work Plan | 2528207 | 09/29/2021 | -- | Not Applicable | 1095311 |
| 2 | April 2022 Monthly | 2528323 | 06/01/2022 | 05/23/2022 | 12/1/2022 | 1121285 |
| 3 | May 2022 Monthly | 2528324 | 07/01/2022 | 06/30/2022 | 12/1/2022 | 1121286 |
| 4 | Q2 2022 Quarterly | 2528227 | 08/01/2022 | 07/30/2022 | 1/18/2024 | 1123930 |
| 5 | June 2022 Monthly | 2528325 | 08/01/2022 | 07/30/2022 | 12/1/2022 | 1121287 |
| 6 | July 2022 Monthly | 2528326 | 09/01/2022 | 08/31/2022 | 12/1/2022 | 1121288 |
| 7 | August 2022 Monthly | 2528327 | 10/01/2022 | 09/30/2022 | 12/1/2022 | 1121289 |
| 8 | Q3 2022 Quarterly | 2528228 | 11/01/2022 | 10/31/2022 | 1/18/2024 | 1123931 |
| 9 | September 2022 Monthly | 2528328 | 11/01/2022 | 10/31/2022 | 12/1/2022 | 1121290 |
| 10 | October 2022 Monthly | 2528329 | 12/01/2022 | 11/30/2022 | 1/18/2024 | 1123932 |
| 11 | November 2022 Monthly | 2528330 | 01/01/2023 | 12/30/2022 | 1/18/2024 | 1123933 |
| 12 | December 2022 Monthly | 2528331 | 02/01/2023 | 01/31/2023 | 1/18/2024 | 1123934 |
| 13 | Q4 2022 Quarterly | 2528229 | 02/01/2023 | 01/31/2023 | 1/18/2024 | 1123935 |
| 14 | January 2023 Monthly | 2528332 | 03/01/2023 | 03/08/2023 | 1/18/2024 | 1123936 |
| 15 | February 2023 Monthly | 2528333 | 04/01/2023 | 03/28/2023 | 1/18/2024 | 1123937 |
| 16 | Q1 2023 Quarterly | 2528249 | 05/01/2023 | 04/26/2023 | 1/18/2024 | 1123938 |
| 17 | March 2023 Monthly | 2528334 | 05/01/2023 | 04/27/2023 | 1/18/2024 | 1123939 |
| 18 | August 2023 Monthly | 2528339 | 10/01/2023 | 09/27/2023 | 1/18/2024 | 1123940 |
| 19 | November 2023 Monthly | 2528342 | 01/01/2024 | 12/28/2023 | 1/18/2024 | 1123941 |

EXHIBIT A
RECORD OF VIOLATIONS
NOTICE OF VIOLATION R9-2024-0026

Table C - Definitions

| TERM | DEFINITION |
|--------------|---|
| CAT1 | Category 1 violation type. This violation type is identified when the water quality effluent parameter is part of the Group I pollutant. |
| CAT2 | Category 2 violation type. This violation type is identified when the water quality effluent parameter is part of the Group II pollutant. |
| CBOD | Carbonaceous Biochemical Oxygen Demand 5-day @ 20°C |
| CIWQS | California Integrated Water Quality System database. |
| GROUP | The list of pollutants is based on Appendix A to section 123.45 of title 40 of the Code of Federal Regulations. |
| lb/day | pounds per day |
| mg/L | milligrams per liter |
| MGD | million gallons per day |
| ml/L | milliliters per liter |
| NTU | Nephelometric Turbidity Units |
| Date | Date that a violation occurred. For continuing violations, such as a monthly average, the last day of the reporting period is used. If the occurrence date is unknown, the date is entered as the day it was first discovered by staff, the discharger, or a third party. For deficient or late reports, the occurrence date is the day after the report was due. |
| OEV | Violation of any constituent-specific effluent limitation not included in Group I or Group II. |
| TSS | Total Suspended Solids |
| Violation ID | Identification number assigned to a violation in CIWQS. |



San Diego Regional Water Quality Control Board

April 23, 2024

Dr. Maria-Elena Giner, P.E.
Commissioner
International Boundary and Water
Commission, United States Section
4191 N. Mesa Street
El Paso, Texas 79902
mariaelena.giner@ibwc.gov

Sent by Email Only

**In reply refer to:
257821:MCorona**

**Subject: Notice of Violation No. R9-2024-0084 to the United States
International Boundary and Water Commission for Violations of
Order No. R9-2021-0001**

Dr. Maria-Elena Giner:

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) hereby issues Notice of Violation (NOV) No. R9-2024-0084 to the United States International Boundary and Water Commission (USIBWC or Discharger) for alleged violations of Order No. R9-2021-0001, NPDES No. CA0108928, *Waste Discharge Requirements for the United States Section of the International Boundary and Water Commission, South Bay International Wastewater Treatment Plant, Discharge to the Pacific Ocean through the South Bay Ocean Outfall* (Order). These alleged violations are a result of the Discharger's failure to comply with the Order.

1. Background

The Discharger is required to operate and maintain the South Bay International Wastewater Treatment Plant (SBIWTP) in compliance with requirements contained in the Order. Consistent with the Order, the Discharger is required to submit self-monitoring reports and other technical reports. Between January 1, 2024, and February 29, 2024, the Discharger self-reported 34 effluent limitation exceedances. In addition, the Discharger has not re-submitted 18 self-monitoring reports with appropriate units and values consistent with the Order.

In accordance with Attachment E, Section 4.2.4 of the Order, the Discharger was required to submit a Tijuana River Valley Monitoring Program (TRVMP) Work Plan by September 29, 2021. The Discharger did not submit the TRVMP Work Plan by the due date, which was noted as a violation in Notice of Violation No. R9-2024-0026, issued by the San Diego Water Board to the Discharger on January 18, 2024. The Discharger subsequently submitted a draft TRVMP Work Plan on March 29, 2024.

Dr. Maria-Elena Giner
USIBWC

-2-

April 23, 2024

2. Summary of Alleged Violations of the Order

The Discharger is alleged to have violated the following sections of the Order:

- 2.1. Section 6.3.3 of the Order:** The Discharger is required to submit a Pollutant Minimization Program (PMP) Annual Status Report on February 1 each year.

Observation: The Discharger submitted the PMP Annual Status Report to the California Integrated Water Quality System database (CIWQS) on February 27, 2024.

- 2.2. Section 4 of the Order:** The Discharger is required to maintain compliance with effluent limitations in section 4.1.1.1 of the Order.

Observation: The Discharger self-reported 34¹ exceedances of effluent limitations in CIWQS for the period of January 1, 2024, through February 29, 2024. Three of the CIWQS violation entries contain errors.

- 2.3. Attachment D, Section 1.1 of the Order:** The Discharger is required to comply with all terms, requirements, and conditions of the Order. Any noncompliance constitutes a violation of the Clean Water Act (CWA) and the California Water Code (Water Code) and is grounds for enforcement action, including permit termination, revocation and reissuance, or modification; denial of a permit renewal application; or a combination thereof.

Observation: The Discharger had 35 violations of the Order.

- 2.4. Attachment E, Section 7.2 of the Order:** The Discharger is required to submit self-monitoring reports to CIWQS consistent with the Order.

Observation: The Discharger submitted 18 self-monitoring reports for the months of April 2022 through March 2023, August 2023, November 2023, and quarters Q2 2022, Q3 2022, Q4 2022, Q1 2023. (CIWQS Document IDs 2528323, 2528324, 2528227, 2528325, 2528326, 2528327, 2528328, 2528228, 2528329, 2528330, 2528229, 2528331, 2528332, 2528333, 2528249, 2528334, 2528339, 2528342).

The State Water Board identified that the values for arsenic, cadmium, cyanide, copper, lead, molybdenum, nickel, selenium, silver, thallium, and zinc were submitted with incorrect units and calculated values.

On December 1, 2022, the State Water Board withdrew six of the submitted reports (April 2022 through September 2022) and directed the Discharger to re-submit the self-monitoring reports with the corrected units and values.

On January 18, 2024, the Discharger requested that self-monitoring reports for the months of May 2022 through November 2023 and all quarters listed above be withdrawn, so the Discharger could re-submit with corrected values.

¹ Exhibit A, List of Violations

Dr. Maria-Elena Giner
USIBWC

-3-

April 23, 2024

The self-monitoring report violations were included in Notice of Violation No. R9-2024-0045, which the San Diego Water Board issued to the Discharger on February 14, 2024.

The Discharger has not re-submitted the self-monitoring reports to CIWQS with appropriate units and values consistent with the Order. However, the Discharger is currently working with the San Diego Water Board in correcting the reports.

3. Potential Enforcement Actions

The alleged violations may subject the Discharger to additional enforcement by the San Diego Water Board or the State Water Board. The San Diego Water Board intends and desires to continue to engage proactively and constructively with the Discharger through judicious and progressive enforcement efforts.

For questions or concerns regarding this NOV, please contact Melissa Corona by phone at 619-521-8921 or by email at melissa.corona@waterboards.ca.gov. In the subject line of any written response, please include the following: 257821:MCorona.

Respectfully,

Brandi Outwin-Beals, P.E.
Senior Water Resource Control Engineer
Source Control Regulation Unit

Attachment: Exhibit A, Record of Violations

Copies to:

Morgan Rogers, Area Operations Manager, International Boundary and Water Commission, U.S. Section, morgan.roger@ibwc.gov

Isela Canava, International Boundary and Water Commission, U.S. Section, Isela.canava@ibwc.gov

Rebecca Rizzuti, International Boundary and Water Commission, U.S. Section, rebecca.rizzuti@ibwc.gov

David Gibson, San Diego Water Board, david.gibson@waterboards.ca.gov

Laurie A. Walsh, San Diego Water Board, laurie.walsh@waterboards.ca.gov

Brandi Outwin-Beals, San Diego Water Board, brandi.outwin-beals@waterboards.ca.gov

Vicente Rodriguez, San Diego Water Board, vicente.rodriguez@waterboards.ca.gov

Dr. Maria-Elena Giner
USIBWC

-4-

April 23, 2024

| Tech Staff Info & Use | |
|---|---|
| Technical Information | Number |
| Order No. | R9-2021-0001 |
| NPDES No. | CA0108928 |
| CW Place ID (South Bay International WTP) | CW-257821 |
| CW Party/Organization ID (IBWC-US & Mexico Section) | 21523 |
| CW Party/Person ID (Dr. Maria-Elena Giner) | 634777 |
| CW Regulatory Measure (Order No. R9-2021-0001) | 442331 |
| CW Regulatory Measure (NOV R9-2024-0084) | 456626 |
| WDID | 9 000000732 |
| Violation IDs | 1125379, 1125376, 1125382, 1125387, 1125389, 1125386, 1125385, 1125378, 1125390, 1125377, 1125375, 1125388, 1125380, 1125374, 1125383, 1125381, 1124276, 1125384, 1124534, 1124527, 1124535, 1124528, 1124522, 1124532, 1124525, 1124526, 1124521, 1124519, 1124533, 1124523, 1124530, 1124531, 1124529, 1124520, 1124524 |

EXHIBIT A
RECORD OF VIOLATIONS
NOTICE OF VIOLATION NO. R9-2024-0084

United State International Boundary and Water Commission
South Bay International Wastewater Treatment Plant
RECORD OF VIOLATIONS (January 1, 2024 – February 29, 2024)
Data reported under Monitoring and Reporting Program No. R9-2021-0001

Table A. Effluent Violations^{2,3}

| Item | Date | Parameter | Units | Permit Limit | Reported Value | Period | Violation Type | CIWQS Violation ID |
|------|-----------|-------------------|--------|--------------|----------------|-----------------------|----------------|--------------------|
| 1 | 1/11/2024 | Settleable Solids | ml/L | 3 | 55 | Instantaneous Maximum | OEV | 1124524 |
| 2 | 1/12/2024 | Turbidity | NTU | 225 | 719 | Instantaneous Maximum | OEV | 1124520 |
| 3 | 1/13/2024 | Turbidity | NTU | 100 | 270.76 | Average Weekly | OEV | 1124519 |
| 4 | 1/13/2024 | Settleable Solids | ml/L | 9.5 | 1.5 | Average Weekly | OEV | 1124523 |
| 5 | 1/13/2024 | CBOD | mg/L | 40 | 138.86 | Average Weekly | CAT1 | 1124529 |
| 6 | 1/13/2024 | CBOD | lb/day | 8,340 | 31,283 | Average Weekly | CAT1 | 1124530 |
| 7 | 1/13/2024 | TSS | lb/day | 9,383 | 74,527 | Average Weekly | CAT1 | 1124531 |
| 8 | 1/13/2024 | TSS | mg/L | 45 | 330 | Average Weekly | CAT1 | 1124533 |
| 9 | 1/13/2024 | CBOD | lb/day | 5,213 | 23,362 | Average Monthly | CAT1 | 1124535 |
| 10 | 1/31/2024 | TSS | mg/L | 30 | 251 | Average Monthly | CAT1 | 1124521 |
| 11 | 1/31/2024 | CBOD | % | 85 | 64.45 | Average Monthly | CAT1 | 1124522 |
| 12 | 1/31/2024 | Turbidity | NTU | 75 | 186.6 | Average Monthly | OEV | 1124525 |
| 13 | 1/31/2024 | Flow | MGD | 25 | 26.57 | Average Monthly | OEV | 1124526 |
| 14 | 1/31/2024 | TSS | % | 85 | 34.46 | Average Monthly | CAT1 | 1124527 |
| 15 | 1/31/2024 | Settleable Solids | ml/L | 1 | 3.12 | Average Monthly | OEV | 1124528 |

² See Exhibit A, Table C for definitions of abbreviations.

³ The CIWQS violation entries corresponding to Items 4, 10, and 24 are incorrect.

EXHIBIT A
RECORD OF VIOLATIONS
NOTICE OF VIOLATION NO. R9-2024-0084

| <u>Item</u> | <u>Date</u> | <u>Parameter</u> | <u>Units</u> | <u>Permit Limit</u> | <u>Reported Value</u> | <u>Period</u> | <u>Violation Type</u> | <u>CIWQS Violation ID</u> |
|-------------|-------------|-------------------|--------------|---------------------|-----------------------|-----------------------|-----------------------|---------------------------|
| 16 | 1/31/2024 | TSS | lb/day | 6,255 | 59,386 | Average Monthly | CAT1 | 1124532 |
| 17 | 1/31/2024 | CBOD | mg/L | 25 | 100 | Average Monthly | CAT1 | 1124534 |
| 18 | 2/2/2024 | Turbidity | NTU | 225 | 579 | Instantaneous Maximum | OEV | 1125384 |
| 19 | 2/21/2024 | Settleable Solids | ml/L | 3 | 55 | Instantaneous Maximum | OEV | 1125381 |
| 20 | 2/24/2024 | TSS | mg/L | 45 | 287 | Average Weekly | CAT1 | 1125374 |
| 21 | 2/24/2024 | Settleable Solids | ml/L | 1.5 | 7.94 | Average Weekly | OEV | 1125380 |
| 22 | 2/24/2024 | Turbidity | NTU | 100 | 197.27 | Average Weekly | OEV | 1125383 |
| 23 | 2/24/2024 | CBOD | mg/L | 40 | 90.46 | Average Weekly | CAT1 | 1125388 |
| 24 | 2/29/2024 | Flow | % | 25 | 26.57 | Average Monthly | OEV | 1125375 |
| 25 | 2/29/2024 | CBOD | % | 85 | 73.95 | Average Monthly | CAT1 | 1125376 |
| 26 | 2/29/2024 | TSS | mg/L | 30 | 210 | Average Monthly | CAT1 | 1125377 |
| 27 | 2/29/2024 | CBOD | mg/L | 25 | 67 | Average Monthly | CAT1 | 1125378 |
| 28 | 2/29/2024 | CBOD | lb/day | 5,213 | 17,091 | Average Monthly | CAT1 | 1125379 |
| 29 | 2/29/2024 | Turbidity | NTU | 75 | 136.25 | Average Monthly | OEV | 1125382 |
| 30 | 2/29/2024 | TSS | lb/day | 9,383 | 70,150 | Average Weekly | CAT1 | 1125385 |
| 31 | 2/29/2024 | Settleable Solids | ml/L | 1 | 3.33 | Average Monthly | OEV | 1125386 |
| 32 | 2/29/2024 | TSS | % | 85 | 50.32 | Average Monthly | CAT1 | 1125387 |
| 33 | 2/29/2024 | CBOD | lb/day | 8,340 | 25,298 | Average Weekly | CAT1 | 1125389 |
| 34 | 2/29/2024 | TSS | lb/day | 6,255 | 54,123 | 1-Hour Average | CAT1 | 1125390 |

**EXHIBIT A
RECORD OF VIOLATIONS
NOTICE OF VIOLATION NO. R9-2024-0084**

Table B. January 1, 2024 – February 29, 2024 Reporting Violation

| <u>Item</u> | <u>Report</u> | <u>Document ID</u> | <u>Due Date</u> | <u>Date Submitted</u> | <u>Date Withdrawn</u> | <u>CIWQS Violation ID</u> |
|-------------|---|--------------------|-----------------|-----------------------|-----------------------|---------------------------|
| 1 | Pollutant Minimization Program Annual Status Report | 2528255 | 02/01/2024 | 02/27/2024 | Not Applicable | 1124276 |

EXHIBIT A
RECORD OF VIOLATIONS
NOTICE OF VIOLATION NO. R9-2024-0084

Table C - Definitions

| TERM | DEFINITION |
|--------------|---|
| CAT1 | Category 1 violation type. This violation type is identified when the water quality effluent parameter is part of the Group I pollutant. |
| CAT2 | Category 2 violation type. This violation type is identified when the water quality effluent parameter is part of the Group II pollutant. |
| CBOD | Carbonaceous Biochemical Oxygen Demand 5-day @ 20°C |
| CIWQS | California Integrated Water Quality System database. |
| GROUP | The list of pollutants is based on Appendix A to section 123.45 of title 40 of the Code of Federal Regulations. |
| lb/day | pounds per day |
| mg/L | milligrams per liter |
| MGD | million gallons per day |
| ml/L | milliliters per liter |
| NTU | Nephelometric Turbidity Units |
| Date | Date that a violation occurred. For continuing violations, such as a monthly average, the last day of the reporting period is used. If the occurrence date is unknown, the date is entered as the day it was first discovered by staff, the discharger, or a third party. For deficient or late reports, the occurrence date is the day after the report was due. |
| OEV | Violation of any constituent-specific effluent limitation not included in Group I or Group II. |
| TSS | Total Suspended Solids |
| Violation ID | Identification number assigned to a violation in CIWQS. |

Table 1: February 2024 – Summary of Public and Federal Sanitary Sewer Overflow Events¹

| Responsible Collection System Agency | Total Volume (Gallons) ² | Total Recovered (Gallons) ³ | Total Reaching Surface Waters (Gallons) ⁴ | Total Reaching Separate Storm Drain and Recovered (Gallons) ⁵ | Total Discharged to Land (Gallons) ⁶ | Surface Water Body Affected ⁷ | Miles of Pressure Sewer | Miles of Gravity Sewer | Population in Service Area ⁸ |
|--------------------------------------|-------------------------------------|--|--|--|---|--|-------------------------|------------------------|---|
| City of Carlsbad | 341 | 341 | 0 | 17 | 0 | Not Applicable | 3.9 | 282.00 | 85,000 |
| City of Chula Vista | 350 | 300 | 0 | 0 | 0 | Not Applicable | 3.0 | 515.00 | 277,220 |
| City of Coronado | 38,250 | 0 | 38,250 | 0 | 0 | San Diego Bay | 8.5 | 42.80 | 20,627 |
| City of Coronado | 589,305 | 0 | 589,305 | 0 | 0 | San Diego Bay | 8.5 | 42.80 | 20,627 |
| City of San Diego | 420 | 0 | 420 | 0 | 0 | Chollas Creek | 112.2 | 2944.92 | 2,380,000 |

¹ Table 1 may not include information on public SSOs that were less than 50 gallons in volume and that did not reach surface waters.

² Total Volume = total amount that discharged from sanitary sewer system to a separate storm drain, drainage channel, surface water body, and/or land.

³ Total Recovered = total amount recovered from a separate storm drain, drainage channel, surface water body, and/or land.

⁴ Total Reaching Surface Waters = total amount reaching separate storm drain (not recovered), drainage channel, and/or surface water body, but does not include amount reaching separate storm drain that was recovered.

⁵ Total Reaching Separate Storm Drain and Recovered = total amount reaching separate storm drain that was recovered.

⁶ Total Discharged to Land = total amount reaching land.

⁷ Agencies are only required to note the surface water body affected if the discharge reaches or has the potential to reach a surface water. If the discharge did not reach a surface water and does not have a potential to reach a surface water (i.e., a discharge to land or a discharge to a separate storm drain that is fully recovered) the surface water body affected is listed as "Not Applicable." If the discharge was to a surface water body or to a separate storm drain and was not fully recovered, and the surface water body was not reported, the surface water body affected is listed as "Not Reported."

⁸ As reported in the Collection System Questionnaire required under Order No. 2006-0003-DWQ.

| Responsible Collection System Agency | Total Volume (Gallons)¹ | Total Recovered (Gallons)² | Total Reaching Surface Waters (Gallons)³ | Total Reaching Separate Storm Drain and Recovered (Gallons)⁴ | Total Discharged to Land (Gallons)⁵ | Surface Water Body Affected⁶ | Miles of Pressure Sewer | Miles of Gravity Sewer | Population in Service Area⁷ |
|---|---|--|--|--|---|--|--------------------------------|-------------------------------|---|
| City of San Diego | 1,350 | 0 | 1,350 | 0 | 0 | Switzer Creek | 112.2 | 2944.92 | 2,380,000 |
| City of San Diego | 77,050 | 4,400 | 72,650 | 0 | 0 | San Diego Bay & River | 112.2 | 2944.92 | 2,380,000 |
| City of Vista | 360 | 0 | 360 | 0 | 0 | Not Reported | 0.3 | 214.50 | 90,000 |
| Eastern Municipal Water District | 810 | 0 | 0 | 0 | 810 | Not Applicable | 30.0 | 609.00 | 258,132 |
| City of Carlsbad | 341 | 341 | 0 | 17 | 0 | Not Applicable | 3.9 | 282.00 | 85,000 |

Table 2: February 2024 – Summary of Private Lateral Sewage Discharge Events

| Responsible Collection System Agency | Total Volume (Gallons)¹ | Total Recovered (Gallons)² | Total Reaching Surface Waters (Gallons)³ | Total Reaching Separate Storm Drain & Recovered and/or Discharged to Land (Gallons)⁴ | Surface Water Body Affected⁵ | Population in Service Area⁶ | Number of Lateral Connections |
|---|---|--|--|--|--|---|--------------------------------------|
| City of Carlsbad | 91 | Not Reported | 0 | 0 | Not Applicable | 85,000 | 24,025 |
| City of Coronado | 50 | Not Reported | 0 | 0 | Not Applicable | 20,627 | 10,000 |
| City of El Cajon | 5 | Not Reported | 0 | 0 | Not Applicable | 101,709 | 17,100 |
| City of El Cajon | 45 | Not Reported | Not Reported | 0 | Forester Creek | 101,709 | 17,100 |
| City of National City | 175 | Not Reported | 0 | 0 | Not Applicable | 58,967 | 8,000 |
| City of San Diego | 8 | Not Reported | 0 | 0 | Not Applicable | 2,380,000 | 267,188 |
| City of San Diego | 60 | 60 | 0 | 0 | Not Applicable | 2,380,000 | 267,188 |

¹ Total Volume = total amount that discharged from private lateral to a separate storm drain, drainage channel, surface water body, and/or land.

² Total Recovered = total amount recovered from a separate storm drain, drainage channel, surface water body, and/or land.

³ Total Reaching Surface Waters = total amount reaching separate storm drain (not recovered), drainage channel, and/or surface water body, but does not include amount reaching separate storm drain that was recovered.

⁴ Total Reaching Separate Storm Drain & Recovered and/or Discharged to Land = total amount reaching separate storm drain that was recovered and/or total amount reaching land.

⁵ Agencies are only required to note the surface water body affected if the discharge reaches or has the potential to reach a surface water. If the discharge did not reach a surface water and does not have a potential to reach surface water (i.e., a discharge to land or a discharge to a separate storm drain that is fully recovered) the surface water body affected is listed as "Not Applicable." If the discharge was to a surface water body or to a separate storm drain and was not fully recovered, and the surface water body was not reported, the surface water body affected is listed as "Not Reported."

⁶ As reported in the Collection System Questionnaire required under Order No. 2006-0003-DWQ.

| Responsible Collection System Agency | Total Volume (Gallons) ¹ | Total Recovered (Gallons) ² | Total Reaching Surface Waters (Gallons) ³ | Total Reaching Separate Storm Drain & Recovered and/or Discharged to Land (Gallons) ⁴ | Surface Water Body Affected ⁵ | Population in Service Area ⁶ | Number of Lateral Connections |
|--------------------------------------|-------------------------------------|--|--|--|--|---|-------------------------------|
| Eastern Municipal Water District | 25 | Not Reported | 0 | 0 | Not Applicable | 258,132 | 57,153 |
| Padre Dam Municipal Water District | 22,370 | 0 | 0 | 22,370 | Not Applicable | 69,641 | 15,568 |

Table 3: February 2024 – Summary of Sewage Discharges by Source⁷

| Spill Type | Month/Year | Number of Spills | Total Volume (Gallons) ⁸ | Total Recovered (Gallons) ⁹ | Total Reaching Surface Waters (Gallons) ¹⁰ | Total Reaching Separate Storm Drain & Recovered and/or Discharged to Land (Gallons) ¹¹ |
|----------------|---------------|------------------|-------------------------------------|--|---|---|
| Public Spills | February 2024 | 9 | 708,236 | 5,041 | 702,335 | 827 |
| Federal Spills | February 2024 | 0 | 0 | 0 | 0 | 0 |
| Private Spills | February 2024 | 9 | 22,829 | 60 | 0 | 22,370 |
| All Spills | February 2024 | 18 | 731,065 | 5,101 | 702,335 | 23,197 |

⁷ Information displayed may not include public SSOs that were less than 50 gallons in volume that did not reach surface waters.

⁸ Total Volume = total amount that discharged from sanitary sewer system to a separate storm drain, drainage channel, surface water body, and/or land.

⁹ Total Recovered = total amount recovered from a separate storm drain, drainage channel, surface water body, and/or land.

¹⁰ Total Reaching Surface Waters = total amount reaching separate storm drain (not recovered), drainage channel, and/or surface water body, but does not include amount reaching separate storm drain that was recovered.

¹¹ Total Reaching Separate Storm Drain & Recovered and/or Discharged to Land = total amount reaching separate storm drain that was recovered and/or total amount reaching land.

Figure 1: The number of public, federal, and private sewage spills per month from February 2023 through February 2024. Note total number of spills per month may not include public SSOs that were less than 50 gallons in volume that did not reach surface waters.




Figure 2: The volume of SSOs from public agencies per month from February 2023 through February 2024. Note, spill totals may not include public SSOs that were less than 50 gallons in volume that did not reach surface waters. Also, note the logarithmic scale on the vertical axis showing the wide variation in spill volumes.




Figure 3: The volume of SSOs from federal agencies per month from February 2023 through February 2024. Note the logarithmic scale on the vertical axis showing the wide variation in spill volumes.




Figure 16: The volume of PLSDs per month from February 2023 through February 2024. Note the logarithmic scale on the vertical axis showing the wide variation in spill volumes.




Table 1: January and February 2024 – Summary of Transboundary Flows from Mexico by Event¹

| Location | Transboundary Flow Start Date | Transboundary Flow End Date | Weather Condition ² | Total Volume (Gallons) ³ | Total Volume Recovered (Gallons) ³ | Total Volume Reaching Surface Waters (Gallons) ³ | Additional Details Reported By USIBWC |
|----------------------------|-------------------------------|-----------------------------|--------------------------------|-------------------------------------|---|---|--|
| Tijuana River Main Channel | 10/11/2023 | 02/29/2024 (ongoing) | Wet | 22.7 billion gallons | 0 | 22.7 billion gallons | Wet and dry weather flows from various sources in Mexico. |
| Smugglers Gulch | 01/18/2024 | 01/18/2024 | Dry | 22,500 | 0 | 0 | Back-up of flow from Hollister pump station due to shutdown of overheated pump. Infiltrated into soil. |
| Goat Canyon Pump Station | 01/19/2024 | 01/19/2024 | Dry | 1,570 | 0 | 0 | Back-up of flow from Hollister pump station due to shutdown of overheated pump. Infiltrated into soil. |

¹ Transboundary flow volumes are obtained from self-monitoring reports submitted by USIBWC pursuant to Order No. R9-2021-0001.

² Order No. R9-2021-0001 defines wet weather as the period of time when a storm event produces 0.1 inches or greater within a 24-hour period plus 72 hours after, based on the Goat Canyon Pump Station rain gauge. USIBWC reported that there was precipitation of 2.84 inches and 1.58 inches as recorded at Marron Valley for the months of January and February 2024, respectively. The rain gauges at Goat Canyon and Smugglers Gulch were not operable and are scheduled for maintenance and repair.

³ Total transboundary flow volume, total volume recovered, and total volume reaching surface waters is an estimate provided by USIBWC.

Table 2: January and February 2024 - Summary of Transboundary Flows from Mexico¹

| Location | Month/Year | Number of Transboundary Flows | Total Volume (Gallons) | Total Volume Recovered (Gallons) | Total Volume Reaching Surface Waters (Gallons) |
|----------------------------|--|--------------------------------------|-------------------------------|---|---|
| Tijuana River Main Channel | October 2023 through February 2024 (ongoing) | 1 | 22.7 billion gallons | 0 | 22.7 billion gallons |
| Canyon Collectors | January 2024 | 1 | 22,500 | 0 | 0 (infiltrated into soil) |
| Goat Canyon Pump Station | January 2024 | 1 | 0 | 0 | 0 (infiltrated into soil) |

¹ For transboundary flows that start and end in different months, Table 2 includes the transboundary flow in the month the transboundary flow started.

Figure 1: Number of reported new transboundary flows per month from January 2023 through February 2024 at the canyon collector systems and the Tijuana River main channel. For transboundary flows that start and end in different months, the figure includes the transboundary flow in month the transboundary flow started. For example, the main channel flow in February 2024 that started in October 2023 is only shown in October 2023.

Figure 1: Number of Transboundary Flows




Figure 2: Volume of reported transboundary flows per month from January 2023 through February 2024 at the Tijuana River main channel. For transboundary flows that start and end in different months, the figure includes the total volume of the transboundary flow in the month the transboundary flow started. For example, the main channel flow in February 2024 that started in October 2023 is only shown in October 2023. Note the logarithmic scale on the vertical axis to accommodate the variation in transboundary flow volumes.

Figure 2: Tijuana River Transboundary Flow Volume




Figure 1: Volume of reported transboundary flows per month from January 2023 through February 2024 at the canyon collector systems. Note the logarithmic scale on the vertical axis to accommodate variation in transboundary flow volumes.

Figure 3: Canyon Collector Transboundary Flow Volume

