

---

**From:** Pettit, Tracy@DWR

**Sent:** Thursday, July 09, 2015 3:51 PM

**To:** Howard, Tom; Evoy, Barbara@Waterboards; Grober, Les@Waterboards; Riddle, Diane@Waterboards; Fernandez, Patricia@Waterboards; Rico, Christine@Waterboards; George, Michael@Waterboards

**Cc:** Leahigh, John@DWR; Pettit, Tracy@DWR; Chu, Andy@DWR; Miller, Aaron@DWR; Giorgi, Bryant@DWR; Hinojosa, Tracy@DWR; Yamanaka, Dan@DWR; Masier, Guy@DWR; Ford, John@DWR; Mizell, James@DWR;

[RMILLIGAN@usbr.gov](mailto:RMILLIGAN@usbr.gov); [pfujitani@usbr.gov](mailto:pfujitani@usbr.gov); [ekiteck@usbr.gov](mailto:ekiteck@usbr.gov); [rsahlberg@usbr.gov](mailto:rsahlberg@usbr.gov); Aufdemberge, Amy (Email); [ngmplcs@pacbell.net](mailto:ngmplcs@pacbell.net); E-mail:; [tshephard@neumiller.com](mailto:tshephard@neumiller.com); Herrick, John @[aol.com](mailto:aol.com)

**Subject:** Notification of Exceedence of One of the Western Delta Objectives Modified under the Temporary Urgency Change Petition

Dear Mr. Howard,

Pursuant to our January 24, 2013, letter "Protocol to Provide Earlier Notification to the State Water Resources Control Board and Partner Fisheries Agencies", this email serves as notification that the 14-day running average EC value at Three Mile Slough (as modified from Emmaton under the July 3 TUCP Order) has exceeded 2.78 mmhos/cm since Tuesday, July 7, 2015. The 14-day average value reached 2.85 mmhos/cm on that day.

Water quality information can be found on the Department of Water Resources' website at the following link: <http://www.dwr.water.ca.gov/swp/operationscontrol/deltaops.cfm>.

A formal notification letter is forthcoming. Please let me know if you have any questions.

Take care.

Tracy

**Tracy Pettit-Polhemus, P.E.**  
**SWP Operations Control Office**  
**Department of Water Resources**  
**Phone: (916) 574-2662**  
**Fax: (916) 574-2785**  
[Tracy.Pettit@water.ca.gov](mailto:Tracy.Pettit@water.ca.gov)